

**GB FREQUENCY HVDC FREQUENCY RESPONSE PARAMETERS  
REMOTE END HVDC CONVERTERS (TITLE III)**

HVDC Article	Requirement	Range	Suggested GB Value	Comments	Policy Req'd? (e.g. Non-compatibility to be defined)	Code Change req'd?
46	All Frequency related aspects eg Frequency Range, LFSM, FSM, Active Power Controlability	As per HVDC Interconnectors – Title II				
47(1)	Frequency communication Signals and co-ordianiton	Specified by TSO	As per DC Connected PPM's	Amend CC.6.3.3 and CC.6.3.6	No	Yes