






Daily Balancing Costs

BSUoS Charge Estimate: £1.51/MWh
Total Outturn: £2.08m

BM Cost (Indicative)
AS Cost (Estimate)



Commentary

350 MW of STOR was run in the morning and 750MW required for Dark Peak
Wind generation increasing rapidly through Sunday, darkness peak margins remained healthy. Overnight a BMU required for voltage management and interconnector trades were required for RoCoF. Additional voltage BM actions executed the early afternoon.