

Constant Terminal Voltage



Working Group Meeting 4
19th September 2014

Overview


- Options summary
- System under investigation
- Options analysis
- Discussion

Options

- Option 1 – Constant Terminal Voltage controlled to 1 p.u with full Transformer Tapping
- Option 2 - Adjustable Terminal Voltage with a limited Transformer Tapping Range
- Option 3 – Limited Transformer Tapping Range only

System under consideration

- 1770MW Unit (1097/-582 MVar range)
- 2100MVA Transformer
- 0.13pu transformer reactance
- No transformer copper losses and no tap dependant reactance



System under consideration


- Following last meeting, further study work has shown complete agreement between equations, Matlab models, and Power Factory simulations.
- Range for off-nominal turns ratio:
 - 1:1.120 to inject 1097MVA_r at 1.05pu
 - 1:0.912 to absorb 582 MVA_r at 0.95pu
- 0.20% voltage/tap to meet the +/-25MVA_r tolerance.
 - Maximum MVA_r step is 38MVA_r

$$a = \frac{V_s V_g}{X_{tr} \sqrt{\left(\frac{V_g^2}{X_{tr}} - Q_g \right)^2 + P_g^2}}$$

$$\frac{\partial Q_g}{\partial a} = \frac{V_s^2 V_g^2}{a^2 X_{tr} \sqrt{V_s^2 V_g^2 - a^2 X_{tr}^2 P_g^2}}$$

Option 1

- 1.0pu Terminal Voltage with full tap range.
- +60/-44taps are required to meet the full reactive range.




Option 1

- Feasibility of the 0.2% voltage/tap
- Implications of the large number of taps on
 - Capital cost
 - Reliability/availability (and costs associated with it)
 - Time to respond to an instruction
- Feasibility of having two tap changers in series (Coarse adjustment and fine tuning)
- Reducing MVar tolerance to +/-80MVar would allow provision of the full range of reactive capability with -19/+24taps
- Any change of MVar should be considered in conjunction with the Grid Code/P28 restrictions on voltage step changes


Option 2

- The upper figure shows the reactive power output of the generating unit
- The lower figure shows the reactive power delivered to the system
- The three curves in each plot correspond to 0.95pu, 1.0pu, and 1.05pu voltage at the grid entry point.
- Tap control is shown by the middle figures.
- Terminal voltage control at the upper tap is shown on the right
- Terminal voltage control at the lower tap is shown on the left




Option 2

- Limited tap range (+23/-19taps). 1.0pu terminal voltage at taps from -18 to +22. Terminal voltage controlled between +/-0.03pu at tap -19 and tap 22.
- The current Grid Code requirements are not met.




Option 2

- Implications on reactive range
- Terminal voltage will need to vary within +/-6.3% instead of 3% as originally thought to achieve full Grid Code requirement.
- Full reactive range available at the machine terminals.
- Marginal gain on the reactive range available at the Grid Entry Point



Option 2

- **Implications on post fault response**
- Start with a tap position that falls outside the restricted tap range.
- Limit the tap range and maintain a 1.0 pu terminal voltage.
- Change the terminal voltage to restore the original reactive power output.
- In the three cases, compare the response of reactive power output to a change in the system voltage



Option 2 – Implications on post fault response

- Implications on post fault response: Lagging MVARs
 - Qg response: Improves for operation at lower tap position and for operation at higher terminal voltage
 - Qo response Improves for operation at lower tap position, deteriorates for operation at higher terminal voltage, varies for a combination of both – there was an overall improvement in the case study here.

| | Pre fault Vs=1.05pu | | Post fault Vs=1.0pu | | Change | |
|---------------------------------|------------------------|------------|---------------------|------------|---------------------|---------------------|
| | Qg MVar | Qo MVar | Qg MVar | Qo MVar | Δ Qg MVar | Δ Qo MVar |
| Point 1 Tap 33 Vg=1.0 | 341.21 | 140.07 | 1103.9 | 834.5 | 762.69 | 694.43 |
| Point 2 Tap 23 Vg=1.0 | 35.117 | -158.9 | 812.17 | 577.39 | 777.05 | 736.29 |
| Point 3 Tap 23 Vg= 1.0188 | 341.21 | 147.41 | 1132.7 | 869.29 | 791.49 | 721.88 |

Option 2

- **Implications on post fault response:** Leading MVARs
 - Qg response: deteriorates for operation at higher tap position and for operation at higher terminal voltage
 - Qo response deteriorates for operation at lower tap position, deteriorates for operation at lower terminal voltage, varies for a combination of both – there was an overall deterioration in the case study here.


| | Pre fault Vs=0.95pu | | Post fault Vs=0.973pu | | Change | |
|----------------------------------|------------------------|------------|--------------------------|------------|---------------------|---------------------|
| | Qg MVar | Qo MVar | Qg MVar | Qo MVar | Δ Qg MVar | Δ Qo MVar |
| Point 1 Tap -33 Vg=1.0 | -181.11 | -377.08 | -581.18 | -796.03 | -400.1 | -419 |
| Point 2 Tap -19 Vg=1.0 | 300 | 100.49 | -88.554 | -282.98 | -388.6 | -383.5 |
| Point 3 Tap -19 Vg= 1.0188 | -181.11 | -389.62 | -557.95 | -784.8 | -376.8 | -395.2 |

Option 2

- **Implications on transient stability:**
 - Addressed by EdF presentation


Option 3

- 1.0pu Terminal Voltage with limited tap range (+23/-19taps).
- **The full reactive range is not available at 1.0pu voltage**
- Reducing MVAR tolerance to +/-80MVAR would allow provision of the full range of reactive capability with -19/+24taps




Option 3

- Not the favourite option as it reduces the reactive range available.
- Issue appears when a fault results in demand being supplied through a long OHL
- Post fault, preference is to supply the reactive demand from the generator rather than from the system
- Due to line length, the pu voltage at the generator terminals will need to be maintained at 1.05pu when the generator is delivering MVARs or at 0.95 when absorbing MVARs
- Records of Drax absorbing maximum MVAR at 388kV to bring high volts down in the North East
- An illustration of what the issue would be is provided
- Currently looking for further evidence



Option 3

- **Illustration – MVar Injection**
- 200km line – maybe not a single line in reality but a stretch of substations with demand only and not a lot of reactive compensation
- High demand conditions
- Voltage at the system busbar needs to be kept between 1.04pu and 1.05pu.



Additional Consideration

Relaxing the 25MVA_r tolerance

- Potential difficulty in setting up a reasonable voltage profile especially at minimum demand conditions.
 - *Tap hunting*
 - *Larger voltage excursions*
 - *Even larger voltage excursions just prior to minimum demand and maximum demand*
- Restrictions due to voltage step limit (1%).
- Additional investment (small STATCOMs/SVCs)
- Additional operational costs for reactive power instruction above the value instructed by the SO.

Discussion
