

Risk Assessment of Loss of Mains Protection

11 April 2013

Dr. Adam Dyśko
University of Strathclyde
Glasgow, UK
e-mail: a.dysko@strath.ac.uk

Outline




- DNO data (including questions)
- Progress to date
 - WP1: Laboratory testing of NDZ assessment
 - WP2: Initial risk calculations

DNO Data


SSE Load Data – Load Case 1

- Mixed residential industrial load – 6 days over 1 year
- Sampling period 5s – resampled to 1s with linear interpolation




SPM Load Data

- 3 rural primes – 1 day
- Sampling period 5s – resampled to 1s with linear interpolation




SPM Load Data

- 3 rural primes – 1 day
- Sampling period 5s – resampled to 1s with linear interpolation




SPM Load Data

- 3 rural primes – 1 day
- Sampling period 5s – resampled to 1s with linear interpolation




SPM Load Data

- 3 rural primes – 1 day
- Sampling period 5s – resampled to 1s with linear interpolation




SPM Load Data – Load Case 2

- Combined 3 rural primes – 1 day
- Sampling period 5s – resampled to 1s with linear interpolation




SPM Load Data – Liverpool

- Combined 9 primary transformers (T1,...,T9) – 1 year
- Sampling period 30min




SPM Load Data – Load Case 3

- Combined 9 primary transformers (T1,...,T9) – 1 year
- Sampling period 30min – resampled to 1min with linear interpolation




SPM Generation Data

- 30MW DG – 1 year
- Sampling period 30min
- Average pf = 0.994 (lagging)
- Mostly constant output and pf




SPM Load Data

- 1 primary transformer (T7) – 1 year
- Sampling period 30min – resampled to 1min with linear interpolation




SPM Load Data – Load Case 4

- 2 combined primary transformers (T7, T8) – 1 year
- Sampling period 30min – resampled to 1min with linear interpolation




SPM Load Data – Load Case 5

- 4 combined primary transformers (T4, T5, T7, T8) – 1 year
- Sampling period 30min – resampled to 1min with linear interpolation



SPM Load Data – Load Case 6

- 6 combined primary transformers (T2, T3, T4, T5, T7, T8) – 1 year
- Sampling period 30min – resampled to 1min with linear interpolation




Requested data



- 1) Examples of load profiles (both P and Q) recorded at a primary substation over a period of minimum 1 day with sampling period of 5s or less. – *more examples received, high resolution data would still be recommended.*
- 2) Total number of DGs and amount of installed DG capacity in the range between 5MW and 50MW, as well as the envisaged DG numbers and capacity in 5 years' time. – *extracted from DCRP_12_02_04*
- 3) Total **number** of primary substations, typical **size** (ideally distribution of sizes) and **frequency of occurrence** of losing a primary substation, i.e. frequency of potential islanding conditions – *continues.*
ENW – lost supply to primary 11kV or BSP 33kV bars 96 times from 2006 up to the present. These are only the >3 minute events – there will be some (not many) to add on. 350 primary substations; 90 BSPs
- 4) Current LOM practice for generators between 5MW and 50MW (ROCOF, VS or Intertripping) and estimated amount of DG with ROCOF protection. – *continues*
ENW – 90%+ of DG has RoCoF... and probably most set to 0.2Hz/s. No intertripping.

Requested data



- 5) Typical (or average or min/max) size of network fed from a primary substation (i.e. potentially islanded) in terms, overall length of lines (cables and OHLs) at 33kV and 11kV, and number of transformers (33/11kV). – *not crucial in Phase I, continues.*

ENW – downstream of the 33kV bars about 750 33kV circuits; downstream of the 11kV bars we have 3000 11kV circuits. There are 16000 ground mounted substations and 16000 pole mounted transformers. 120000 LV circuits. 2000km of LV OH line; 28500km of LV UG cable 7800km of 11kV OH line; 13000km of HV UK cable 1000km of 33kV OH line; 2200km of 33kV UG cable.

- 6) Typical DG connections for sizes between 5MW and 50MW (choose from the four types as shown below) – *Discussed at WG meeting. Accurate information not crucial.*

WP1 – NDZ assessment


WP1 - Simulation based assessment of Non Detection Zone (NDZ)

- RTDS real-time model of 30MVA machine connected to 33kV level (3MVA also machine considered for 'spot' checks)
- Laboratory hardware testing using a commercial relay with 11 setting options
- Load modelling as fixed impedance and fixed power
- Generator control considered as P/pf and P/V

Setting Option	ROCOF [Hz/s]	Time Delay [s]	Dead Band applied
1	0.5	0.0	No
2	0.5	0.5	No
3	1.0	0.0	No
4	1.0	0.5	No
5	0.5	0.0	Yes
6	0.5	0.5	Yes
7	1.0	0.0	Yes
8	1.0	0.5	Yes
9	0.12	0.0	No
10	0.13	0.0	No
11	0.2	0.0	No

RTDS Model – network diagram

Grid infeed



Adjustable loads

Generator with controllers

WP1 – Results (Real Power NDZ)

Setting Option	ROCOF [Hz/s]	Time Delay [s]	Dead Band applied	NDZ [%]			
				P/V control		P/pf control	
				Fixed power load	Fixed imp. load	Fixed power load	Fixed imp. load
1	0.5	0.0	No	-6.1,5.9			
2	0.5	0.5	No	-7.2,7.2	-7.6,7.6	-7.7,0.0	-0.5,0.6
3	1.0	0.0	No	-12.4,11.5			
4	1.0	0.5	No	-14.6,14.6			
5	0.5	0.0	Yes	-8.4,8.4			
6	0.5	0.5	Yes	-10.6,10.2			
7	1.0	0.0	Yes	-13.1,12.5			
8	1.0	0.5	Yes	-17.7,18.9			
9	0.12	0.0	No	-1.3,1.2			
10	0.13	0.0	No	-1.6,1.5	-1.8,1.8		
11	0.2	0.0	No	-2.4,2.4			

WP2 – Risk level calculation

WP2 – Risk level calculation at varying NDZ

- Assumptions for preliminary studies
 - ❑ Generation range considered 5MW – 50MW
 - ❑ Existing Synchronous DG Generation included only
 - ❑ 6 different load profiles included
 - ❑ Generator output is fixed and $pf=0.99$ (lagging) – based on SPM generation record
 - ❑ Max. permissible length of undetected island is 3s.
 - ❑ Loss of supply occurrence – 96 times in 7 years a population of 440 substations.
 - ❑ P and Q NDZ assumed equal and symmetrical (will be verified with WP1 results later)
 - ❑ All SM generators have ROCOF

WP2 – Initial Results

- Setting option 10 – 0.13Hz/s, 0.0s, No Dead Band
- NDZ=1.8% (assumed for both P and Q)

Load Case	Max load [MW]	Analysed Period [days]	Time step - actual /resampled	$P_{LOM, 1DG}$ (individual generator)	P_{LOM} (overall)
1	15	6	5s / 1s	$4.55 \cdot 10^{-9}$	$8.33 \cdot 10^{-7}$
2	7.8	1	5s / 1s	$3.75 \cdot 10^{-13}$	$6.86 \cdot 10^{-11}$
3	40	8760	30min / 60s	$5.31 \cdot 10^{-9}$	$9.72 \cdot 10^{-7}$
4	10	8760	30min / 60s	$5.25 \cdot 10^{-10}$	$9.61 \cdot 10^{-8}$
5	19	8760	30min / 60s	$3.20 \cdot 10^{-9}$	$5.85 \cdot 10^{-7}$
6	26	8760	30min / 60s	$2.08 \cdot 10^{-10}$	$3.80 \cdot 10^{-8}$

WP2 – Initial Results



- Setting option 10 – 0.13Hz/s, 0.0s, No Dead Band
- NDZ=1.8% (assumed for both P and Q)

Load Case	pf	NDZ	Network length	T_{NDZavr} [min]	$N_{LOM,1DG}$	$P_{LOM,1DG}$	P_{LOM}
1	-0.99	1.8	0	31.5	7.60661E-05	4.55E-09	8.33E-07
2	-0.99	1.8	0	0.3	8.86524E-07	3.75E-13	6.86E-11
3	-0.99	1.8	0	32.6	8.56412E-05	5.31E-09	9.72E-07
4	-0.99	1.8	0	26.9	1.02714E-05	5.25E-10	9.61E-08
5	-0.99	1.8	0	24.5	6.86107E-05	3.20E-09	5.85E-07
6	-0.99	1.8	0	31.9	3.42315E-06	2.08E-10	3.80E-08

- High risk results especially when low resolution profile is used

WP2 – Initial Results

- Setting option 2 – 0.5Hz/s, 0.5s, No Dead Band
- NDZ=7.6% (assumed for both P and Q)

Load Case	Max load [MW]	Analysed Period [days]	Time step - actual /resampled	$P_{LOM, 1DG}$ (individual generator)	P_{LOM} (overall)
1	15	6	5s / 1s	$7.76 \cdot 10^{-7}$	$1.42 \cdot 10^{-4}$
2	7.8	1	5s / 1s	$1.17 \cdot 10^{-8}$	$2.14 \cdot 10^{-6}$
3	40	8760	30min / 60s	$3.07 \cdot 10^{-7}$	$5.63 \cdot 10^{-5}$
4	10	8760	30min / 60s	$3.54 \cdot 10^{-8}$	$6.48 \cdot 10^{-6}$
5	19	8760	30min / 60s	$2.20 \cdot 10^{-7}$	$4.02 \cdot 10^{-5}$
6	26	8760	30min / 60s	$3.81 \cdot 10^{-8}$	$6.98 \cdot 10^{-6}$

WP2 – Initial Results



- Setting option 2 – 0.5Hz/s, 0.5s, No Dead Band
- NDZ=7.6% (assumed for both P and Q)

Load Case	pf	NDZ	Network length	T_{NDZavr} [min]	$N_{LOM,1DG}$	$P_{LOM,1DG}$	P_{LOM}
1	-0.99	7.6	0	166.1	0.00245628	7.76E-07	1.42E-04
2	-0.99	7.6	0	3.7	0.00169045	1.17E-08	2.14E-06
3	-0.99	7.6	0	134.1	0.00120577	3.08E-07	5.63E-05
4	-0.99	7.6	0	77.2	0.000241119	3.54E-08	6.48E-06
5	-0.99	7.6	0	103.0	0.00112225	2.20E-07	4.02E-05
6	-0.99	7.6	0	84.9	0.00023623	3.81E-08	6.98E-06

- High risk results especially when low resolution profile is used

WP2 – Initial Results



- Setting option 8 – 1Hz/s, 0.5s, Dead Band 49.5Hz-50.5Hz
- NDZ=18% (assumed for both P and Q)

Load Case	Max load [MW]	Analysed Period [days]	Time step - actual /resampled	$P_{LOM, 1DG}$ (individual generator)	P_{LOM} (overall)
1	15	6	5s / 1s	$4.47 \cdot 10^{-6}$	$8.18 \cdot 10^{-4}$
2	7.8	1	5s / 1s	$3.23 \cdot 10^{-8}$	$5.90 \cdot 10^{-6}$
3	40	8760	30min / 60s	$2.08 \cdot 10^{-6}$	$3.80 \cdot 10^{-4}$
4	10	8760	30min / 60s	$1.04 \cdot 10^{-6}$	$1.90 \cdot 10^{-4}$
5	19	8760	30min / 60s	$2.66 \cdot 10^{-6}$	$4.86 \cdot 10^{-4}$
6	26	8760	30min / 60s	$1.50 \cdot 10^{-6}$	$2.75 \cdot 10^{-4}$

- High risk results especially when low resolution profile is used

WP2 – Initial Results




- Setting option 8 – 1Hz/s, 0.5s, Dead Band 49.5Hz-50.5Hz
- NDZ=18% (assumed for both P and Q)

Load Case	pf	NDZ	Network length	T_{NDZavr} [min]	$N_{LOM,1DG}$	$P_{LOM,1DG}$	P_{LOM}
1	-0.99	18	0	405.0	0.00580278	4.47E-06	8.18E-04
2	-0.99	18	0	12.0	0.00142032	3.23E-08	5.90E-06
3	-0.99	18	0	336.4	0.00324589	2.08E-06	3.80E-04
4	-0.99	18	0	208.5	0.0026191	1.04E-06	1.90E-04
5	-0.99	18	0	272.9	0.00512102	2.66E-06	4.86E-04
6	-0.99	18	0	225.4	0.00349866	1.50E-06	2.75E-04

- High risk results especially when low resolution profile is used


SPM Load Data – Load Case 2

- Combined 3 rural primes – 1 day
- Sampling period 5s – resampled to 1s with linear interpolation




SPM Load Data

- 2 combined primary transformers (T7, T8) – 1 day
- Sampling period 30min – resampled to 1min with linear interpolation



What level of risk can be accepted?

Health and Safety at Work Act 1974



Progress summary



- Samples of load profiles have been obtained and analysed
- WP1: NDZ assessment is ongoing – NDZ may be as high as 18% for ROCOF setting of 1Hz/s, delay of 0.5s and Dead Band enabled.
- WP2: Risk assessment is ongoing – some results reach unacceptable risk level, but this is likely to be due to low resolution of the load data. More high resolution data is needed to verify this.

Thank you!