

# Fault Ride Through



Antony Johnson / Richard Ierna  
*National Grid – TNS Technical Policy*

# Summary

---

- Resume of Actions
- Effect on Large Nuclear Generators
- Voltage against time curves
- RfG Voltage against time curve issues
- Review of RfG Requirements / Interpretation
- RfG Frequently Asked Questions Document
- Next Steps

# Actions

---


- A summary of the workgroup findings and proposal, as a slide pack, for discussion – *Completed – See separate Slide Pack*
- Consider the impact on the new large nuclear fleet of Generators – *Included in slide pack / Discussion*
- Consider further the requirement of specifying the fault-level at either a local or global level – *Discussion – Current basis is towards site specific requirement similar to that for Excitation Performance.*
- Superimpose the orange voltage against time curve on top of the RfG requirement – *Completed – Included in slide pack.*
- Change the date in the terms of Reference to March 2015 instead of March 2014 – *In progress / Completed*
- Industry parties are asked to consider the stability of their station auxiliaries against the proposed curve. – *Discussion - covered as a specific agenda item.*
- Industry Parties where possible, to do some further analysis – particularly of large plant – against the proposed GB curve. - *Discussion*
- Expansion of the group to consider the requirements for Embedded Plant - *covered as a specific agenda item.*

# Effect on Large Nuclear Generators

---

- Detailed studies undertaken
- Noted issues
- Open Circuit Response – Non Grid Code Compliant
  - Believed to be an issue with model / parameters
  - Model evaluation being undertaken
- Application of faults on this model results in undamped oscillations.
- Need to work with individual manufacturers to ensure the models are correct (especially EDF, Horizon and NuGen)

# ENTSO-E RfG - Voltage Duration Profile – Possible GB Option (3)




# Proposed Option


---

- Based on the extensive study work completed to date option 3 (Orange Curve) was the preferred option
- However it has subsequently been identified that Table 7.1 of the RfG for Type D Generators includes certain deadzones between RfG MIN and RfG MAX which would prevent the suggested curve from being used
- Limitations in the range of voltage parameters identified within Table 7.1 of the RfG document
- Clarification sought from ENTSO-E drafting team.
- Checks need to be made with the smaller units (Band B and C)

# Options for Voltage Against Time Curves



# ENTSO-E RfG - Fault Ride Through Requirements – Voltage Against Time Profile – Figure 3






# ENTSO-E RfG - Voltage Against Time Parameters – Table 7.1 – Type D Synchronous Power Generating Units

Voltage parameters [pu]		Time parameters [seconds]	
Uret:	0	tclear:	0.14 – 0.25
Uclear:	0.25	trec1:	tclear
Urec1:	0.5 – 0.7	trec2:	trec1 – 0.7
Urec2:	0.85 – 0.9 and $\geq$ Uclear	trec3:	trec2 – 1.5



Table 7.1 – Fault Ride Through Capability of Synchronous Power Generating Modules

# ENTSO-E RfG - Voltage Duration Profile – Table 7.1 – Limitation on TSO selections



- 
- Review of RfG requirements and Frequently Asked Questions document to be reviewed to ensure correct interpretation
  - System studies have been run on the basis of identifying
    - Stable operating conditions
    - Post fault voltage recovery – especially for onerous faults cleared in backup operating times and the effect on generation remote from the fault
    - Generator operating conditions (ie full lead and max output)
    - Effect of Generation on fault level
  - Recap of RfG Fault Ride Through requirements – working group discussion

## Drax – Thorpe Marsh - Double Circuit fault



# Next Steps

---

- Ensure NGET and working group assumptions are consistent with RfG Fault Ride Through Requirements
- Re-assess and finalise RfG Voltage against time curve
- Develop Grid Code Legal Text
- Finalise how compliance simulations would be demonstrated
- Consider changes on other documents – eg Guidance Notes for Synchronous Generators?
- Extend the remit and representation of the Working Group to consider the Fault Ride Through requirements for Embedded Synchronous Generators