

Fundamental NETS SQSS Review

Industry Review Group

Progress Update & Consultation Report Briefing



Outline

- ◆ Introductions
- ◆ Background Drivers
- ◆ Open Letter (including Revised Workplan)
- ◆ Update & Consultation Document
 - ◆ Revised Minimum Generation Connections
 - ◆ Contingency Criteria
 - ◆ Voltage Criteria
 - ◆ Embedded Generation
 - ◆ Intertrip Schemes
 - ◆ Stability Criteria
 - ◆ Clarifications
- ◆ Work in Progress
- ◆ Integration of Wind

Background – Drivers for the Review


- ◆ Growth in intermittent generation
- ◆ Increase in external interconnections
- ◆ Development of offshore networks
- ◆ SMART transmission and distribution technologies
- ◆ TSORG review
- ◆ Regional Inconsistencies

Open Letter

- ◆ Significant work accomplished... but much remains
- ◆ Benefit in implementing work done so far, and establishing an ongoing programme of work
- ◆ Differentiate between immediate issues and complex longer-term considerations
- ◆ Enhanced engagement with industry
 - ◆ Review governance arrangements
 - ◆ Consultation on different phases of work
 - ◆ Increased customer engagement

Revised Workplan

Two phases of work: **Immediate Focus** & **Longer Term Focus**



Fundamental Review - Update & Consultation

- ◆ Published April 23
- ◆ Presents the findings of the five working groups:
 - ◆ WG1 – International Benchmarking
 - ◆ WG2 – Transmission Entry & Exit Principles
 - ◆ WG3 – Main Interconnected Transmission System Principles
 - ◆ WG4 – Planning and Operational Contingency Criteria
 - ◆ WG5 – Offshore Transmission Systems
- ◆ Contains several major proposals

Revised Minimum Generation Connections

- ◆ One size doesn't fit all
- ◆ Basing **minimum generation criteria** on the **aggregate generation capacity** and expected **source fuel load factor** of new generation:
- ◆ Implementation would follow a review of charging procedures

Generation Group	Group Aggregate Generation Capacity (TEC)		Source Fuel Load Factor	Connection Type
	Minimum	Maximum		
A	0	< 50	<= 40%	A
			40 – 70%	A
			70 – 100%	A
B	≥50	< 100	<= 40%	B
			40 – 70%	B
			70 – 100%	B
C	≥100	<300	<= 40%	C
			40 – 70%	C
			70 – 100%	D
D	≥300	<700	<= 40%	D
			40 – 70%	D
			70 – 100%	E
E	≥700	Normal Infeed Loss (1,320)	<= 40%	E
			40 – 70%	E
			70 – 100%	F
F	≥Normal Infeed Loss (1,320)	<Infrequent Infeed Loss Risk (1,800)	<= 40%	F
			40 – 70%	F
			70 – 100%	G
G	>=Infrequent Infeed Loss Risk (1800)	<2 x Infrequent Infeed Loss Risk (3,600)	<= 40%	G
			40 – 70%	G
			70 – 100%	G
H	>=2 x Infrequent Infeed Loss Risk (3,600)	-	<= 40%	H
			40 – 70%	H
			70 – 100%	H


Revised Minimum Generation Connections

Possible implementation:

Minimum	Maximum		Timescale	Planned outage of a single transmission circuit or single section of busbar	Planned outage of a single generator circuit	Fault of a single transmission circuit
>=50	< 100	<= 40%	Immediately	Nil	Nil	Nil
			In time to restore outage	Total Group Generation Capacity	Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore fault			Total Group Generation Capacity
		40 – 70%	Immediately	Nil	Nil	Nil
			In time to restore outage	Total Group Generation Capacity	Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore fault			Total Group Generation Capacity
		70 – 100%	Immediately	Nil	Nil	Nil
			In time to restore outage	Total Group Generation Capacity	Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore fault			Total Group Generation Capacity
>=100	<300	<= 40%	Immediately	Nil	Nil	Nil
			In time to restore outage	Total Group Generation Capacity	Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore fault			Total Group Generation Capacity
		40 – 70%	Immediately	Nil	Nil	Nil
			In time to restore outage	Total Group Generation Capacity	Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore fault			Total Group Generation Capacity
		70 – 100%	Immediately	50% of Total Group Generation Capacity	Nil	50% of Total Group Generation Capacity
			In time to restore outage	Total Group Generation Capacity	Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore fault			Total Group Generation Capacity
>=300	<700	<= 40%	Immediately	50% of Total Group Generation Capacity	Nil	50% of Total Group Generation Capacity
			In time to restore outage	Total Group Generation Capacity	Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore fault			Total Group Generation Capacity
		40 – 70%	Immediately	50% of Total Group Generation Capacity	Nil	50% of Total Group Generation Capacity
			In time to restore outage	Total Group Generation Capacity	Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore fault			Total Group Generation Capacity
		70 – 100%	Immediately	Total Group Generation Capacity	50% of Total Group Generation Capacity	Total Group Generation Capacity
			In time to restore outage		Total Group Generation Capacity	
			In time to restore fault			


Contingency Criteria

- ◆ Existing criteria is largely appropriate and consistent with comparable overseas networks, except for...
- ◆ the 'N-1-1 at peak demand' criteria that applies to the MITS within England & Wales in design timescales
- ◆ Propose to remove this requirement, except for circuits containing transformers or cable outside a substation




Contingency Criteria

- ◆ Existing criteria is largely appropriate and consistent with comparable overseas networks, except for...
- ◆ the 'N-1-1 at peak demand' criteria that applies to the MITS within England & Wales in design timescales
- ◆ Propose to remove this requirement, except for circuits containing transformers or cable outside a substation




Contingency Criteria

- ◆ Existing criteria is largely appropriate and consistent with comparable overseas networks, except for...
- ◆ the 'N-1-1 at peak demand' criteria that applies to the MITS within England & Wales in design timescales
- ◆ Propose to remove this requirement, except for circuits containing transformers or cable outside a substation




Contingency Criteria

- ◆ Existing criteria is largely appropriate and consistent with comparable overseas networks, except for...
- ◆ the 'N-1-1 at peak demand' criteria that applies to the MITS within England & Wales in design timescales
- ◆ Propose to remove this requirement, except for circuits containing transformers or cable outside a substation



Contingency Criteria

- ◆ Existing criteria is largely appropriate and consistent with comparable overseas networks, except for...
- ◆ the 'N-1-1 at peak demand' criteria that applies to the MITS within England & Wales in design timescales
- ◆ Propose to remove this requirement, except for circuits containing transformers or cable outside a substation



Voltage Criteria

- ◆ 'Hard Limits' and 'Soft Limits'
- ◆ Greater flexibility in operational pre-fault voltage
- ◆ GB-wide step-change limits for operational switching
- ◆ Consideration of the loss of a generating unit and failure of a circuit breaker as secured events where this could cause the voltage to increase beyond the upper planning limits.

Demand Groups / Embedded Generation

- ◆ Recommend procedural changes to:
 - ◆ improve transparency in the estimation of demand group requirements,
 - ◆ introduce a more thorough assessment of the contribution of embedded generation to demand security
- ◆ Followed by a joint review with the P2/6 standard, to improve harmonisation of the two standards

Stability Criteria

- ◆ Considered opportunities to increase network utilisation by relaxing stability criteria:
 - ◆ Assuming single-phase-to-earth or two-phase-to-earth faults, rather than three-phase faults
 - ◆ Reducing the assumed fault clearance time (i.e. utilising faster protection)
- GB power system already fully utilising its stable operating envelope. No material benefit to be gained by relaxing stability criteria.

Intertrip Schemes

- ◆ Demand and generation intertrip schemes already used extensively (~30 schemes in operation)
 - ◆ Generally only of benefit in managing outages
 - ◆ Need to ensure the network retains sufficient flexibility to accommodate outages offpeak to facilitate maintenance and development
- Retain current practice, that intertrips do not generally provide an alternative to reinforcement to support winter peak demand, but should be considered to support year-round operation.

SMART Networks

- ◆ Recognise the increasing role of:
 - ◆ Demand management
 - ◆ Dynamic circuit ratingsin providing additional network capability
- ◆ Proposals to reflect this in the SQSS where these services can be reasonably relied upon to be available throughout the timeframe under consideration

- ◆ Balance between costs of developing and operating the network and the level of service it provides
- ◆ Procedures for deciding inputs to cost benefit analyses
- ◆ Ensuring alignment of SQSS with charging & access arrangements
- ◆ Determining the appropriate balance between user commitment and anticipatory investment
- ◆ Managing greater interconnection and market-coupling with Europe

- ◆ Increased availability of demand side management
- ◆ Managing the risk associated with increasing levels of complexity within the power system
- ◆ The risks & costs associated with low-likelihood but high-impact cascading faults
- ◆ The implications of other industry initiatives (e.g. Ofgem's RPI-X@20 review)
- ◆ Ongoing consideration of emerging technologies

Wind Integration - background

GSR001 consultation

- ◆ Proposal to maintain current SQSS approach:
 - Scale wind by 40% in ranking process – 120% margin
 - Scale wind by 72% as input to studies
 - Scale all generation to Gen = Demand
- ◆ But merit in applying different factors in export/import groups
- ◆ Other options needed further work
- ◆ Consultation responses:
 - Not well understood
 - Scaling factor not right
- ◆ Work became part of Fundamental Review

Wind Integration – current position

- ◆ Limited progress to date
- ◆ Agreement with OFGEM to report on recommendations in July 2010
- ◆ Working group established – TOs + economic consultants
- ◆ Will hold industry review group meeting late May / early June
- ◆ Intend to consult with industry throughout June

Wind Integration considerations

- ◆ Recognition that wind contribution to demand security is limited
- ◆ Pros and cons of CBA
- ◆ Can snapshot studies be sufficient?
- ◆ How should generation group size be accounted for?
- ◆ Is the current ranking process appropriate?

Wind integration analysis

- ◆ Actual wind data / anticipated generation
 - Annual / seasonal energy
 - Averaging across different area sizes
 - Informs profiles for CBA and scaling factors for snapshot
- ◆ Economic analysis
 - Comparison of economic transmission with scaling option results
 - Sensitivity to input assumptions

Wind integration next steps

- ◆ Development of options – mid May
- ◆ Write consultation report – end May
- ◆ Industry review group – late May / early June
- ◆ Consultation – June
- ◆ Report to OFGEM – mid July
- ◆ Development of charging proposals in parallel

Questions / Discussion