

STCP 26-1 Issue 002 Active Network Management

STC Procedure Document Authorisation

Party	Name of Party Representative	Signature	Date
National Grid Electricity System Operator Ltd <u>The Company</u>			
National Grid Electricity Transmission plc			
SP Transmission plc			
Scottish Hydro Electric Transmission plc			
Offshore Transmission Owners			

STC Procedure Change Control History

Issue 001	04/11/2015	New STCP– PM080
Issue 002	01/04/2019	Issue 02 incorporating National Grid Legal Separation changes
<u>Issue 003</u>	<u>X/X/2023</u>	<u>Issue 003 incorporating use of 'The Company' definition as made in the STC</u>

1 Introduction

1.1 Scope

- 1.1.1 This procedure defines the interactions required between NGESO The Company, as defined in the STC and meaning the licence holder with system operator responsibilities, and the TO(s) for the purpose of introduction and management of Active Network Management (ANM) schemes.
- 1.1.2 This procedure describes the process for the agreement of the design requirements of ANM schemes and the subsequent verification that the operation of the ANM will discharge the responsibilities of the System Operator satisfactorily, including its functional performance.
- 1.1.3 NGESO The Company is responsible for System Operation and thus where the ANM scheme performs actions that would traditionally have been performed by NGESO The Company as System Operator (SO) and thus NGESO The Company must accept ultimate responsibility for the actions of the ANM scheme.
- 1.1.4 Each TO is responsible for the design of the connection and the infrastructure of its Transmission System, including that of the monitoring, signalling and automated control systems therein.
- 1.1.5 This procedure applies to NGESO The Company and each TO.
- 1.1.6 For the purposes of this document, the TOs are
NGET;
SPT;
SHET.
All Offshore Transmission Licence holders as appointed from time to time by the Authority.
- 1.1.7 It is anticipated that ANM schemes would initially only be considered where inter-tripping would be too complex or impractical. Additionally, ANMs may be used to regulate generation in highly congested areas of the network where a methodology for the apportionment of TEC between affected generators has been agreed.
- 1.1.8 ANM schemes would normally be employed:
 - 1.1.8.1 To manage shorter term conditions that may apply in advance of network reinforcement.
 - 1.1.8.2 to manage enduring operation of generators where reinforcement of the Transmission System may not be economic.
- 1.1.9 An ANM scheme developed in accordance with this procedure would not perform any predictive functions as these would be carried out within the Energy Balancing System owned by NGESO The Company. This would be reviewed periodically as the technology advances.
- 1.1.10 An ANM scheme may be proposed by a TO to facilitate connection of generation or by NGESO The Company to manage system operation issues. Where generation constraints may be a determinant in the suitability of an ANM scheme, an estimation of that cost shall be provided by NGESO The Company. Such a request by NGESO The Company would be made via a Planning Request in accordance with STCP16-1.

1.2 Objectives

- 1.2.1 The objective of this procedure is to detail:-how the TO(s) and ~~NGESO~~The Company will agree the initial design requirements of an ANM scheme:-
- 1.2.2 how the TO(s) and ~~NGESO~~The Company will agree the final design of an ANM scheme.
- 1.2.3 how the TO(s) and ~~NGESO~~The Company will agree the final testing and commissioning of an ANM scheme.
- 1.2.4 how updates to the design of an ANM scheme will be implemented as a result of operational issues, network changes, connection of new generation etc.
- 1.2.5 the operational lines of communication to be used.

2 Key Definitions

2.1 For the purposes of this STCP:

- 2.1.1 An ANM scheme is a system which manages generator outputs such that circuit loading in steady state pre and post-fault conditions are managed within agreed limits.
- 2.1.2 **Type 1: ANM(Distribution)** means an Active Network Management scheme that monitors and acts on plant within the Distribution Network Operator's (DNO's) system. This type of ANM will not be subject to the requirements of this STCP.
- 2.1.3 **Type 2: ANM(Local, Non BM)** means an Active Network Management scheme that acts on plant on the Network Operator's side of Grid Supply Point busbars but regulates power flows on the Transmission System. This scheme will not act upon BM participants. This type of ANM may be subject to the requirements of this STCP.
- 2.1.4 **Type 3: ANM(Local, BM)** means an Active Network Management scheme that acts on plant on the Network Operator's side of Grid Supply Point busbars and regulates power flows on the Transmission System. This scheme would impact on a BMU or the operation of the BM.
- 2.1.5 **Type 4: ANM(RadialWider, BM)** means an Active Network Management scheme that acts on plant on a wholly radial section of the transmission network including participants within the BM and does regulate power flows on Transmission Circuits. In this case the load sharing of the circuits may be predetermined and thus not require further analysis.
- 2.1.6 **ANM Steering Group** means a team made up of named representatives from ~~NGESO~~The Company, Host TO, Affected TO and other Affected TOs as appropriate within the Boundary of Influence. The ANM Steering Group shall be formed to oversee the design, development and implementation of ANM schemes including the overall programme. It shall be responsible for resolving any disagreements that may occur at their first instance in order that escalation may be minimised. Dialogue shall take place in person, by e-mail, telephone or video conference as appropriate whether relating to individual or multiple schemes.
- 2.1.7 **Network Operator** (Replicated from Grid Code for completeness) A person with a User System directly connected to the National Electricity Transmission System to which Customers and/or Power Stations (not forming part of the User System) are connected, acting in its capacity as an operator of the User System, but shall not include a person acting in the capacity of an Externally Interconnected System Operator or a Generator in respect of OTSUA.

3 Procedure

3.1 Setting of ANM Design Requirements

- 3.1.1 It is anticipated that the agreement of outline design requirements would necessarily take place within the 3 month generation application timescale. This shall be the responsibility of the TO but ~~NGESO~~The Company as SO shall be consulted in cases where generators within the Balancing Market may be impacted. In these cases, the functional specification shall be developed jointly between the TO and ~~NGESO~~The Company before being submitted to ~~NGESO~~The Company for final approval. ~~NGESO~~The Company shall respond in accordance with the timetable in Appendix A. ~~NGESO~~The Company will liaise with the TO if changes are required to ensure that its obligations as System Operator would be discharged fairly and economically. The detailed design of the ANM would take place on a timescale agreed between the TO and ~~NGESO~~The Company on a project specific basis.
- 3.1.2 When required, the functional specification of a specific ANM scheme shall detail performance in the event of loss of communication between the ANM and generator(s) or mal-operation of the ANM that the generator(s) output shall ramp down to zero, or a pre-determined level, over an agreed and pre-determined period. The post-event generation output value shall be set taking due cognizance of voltage issues and circuit loading. It is anticipated that in some circumstances, the use of inter-tripping may also be required if the ANM response time would be unacceptable.
- 3.1.3 The ANM scheme shall provide agreed alarm/status indications to the IEMS/ Energy Balancing System (EBS).
- 3.1.4 Single points of failure causing the loss of ANM functionality such as those detailed in 3.1.2 shall be eliminated as far as reasonably practicable.
- 3.1.5 Consideration shall be given to avoidance of spurious overload alarm creation in ~~the~~ ~~NGESO~~The Company Control Room by the incorporation of damping and allowance for metering-tolerances into the ANM design.
- 3.1.6 Consideration shall be given to the use of state estimation and checks using correlation of data items to alleviate the risks caused by metering errors.
- 3.1.7 The usage of pre-fault, post-fault and short term overload rating of circuits by the ANM scheme shall be agreed between the TO and ~~NGESO~~The Company.

3.2 Interface of ANM Scheme with ~~the~~ ~~NGESO~~The Company Energy Balancing System

- 3.2.1 It is anticipated that ANMs of Type 3 and Type 4 would require an interface with ~~the~~ ~~NGESO~~The Company Energy Balancing System (EBS) whether this is direct or indirect via an interface unit. The technical requirements of the interface shall be specified and agreed in advance of detailed ANM design. It is envisaged that a standardised interface will be developed.

3.3 Approval of ANM Design

- 3.3.1 In applicable cases, namely Types 2, 3 and 4, once a design has been finalised this shall be submitted to ~~NGESO~~The Company for approval. ~~NGESO~~The Company shall respond in accordance with the timetable in Appendix A. ~~NGESO~~The Company will

liaise with the TO if changes are required to ensure that its obligations as System Operator would be discharged fairly and economically in accordance with its licence.

- 3.3.2 The content of the Design Specification shall comprise of the following as a minimum:-
- 3.3.3 Block/functional diagram and detailed description of modes of operation.
- 3.3.4 Fall-back modes of operation in the event of communication failure and timescale of action.
- 3.3.5 Generation plant within scope.
- 3.3.6 Circuits monitored for loading.
- 3.3.7 Fall-back modes of operation in the event of ANM failure and timescale of action.
- 3.3.8 Generation ranking order input requirements (if applicable).
- 3.3.9 Targets for reliability and mean time between failures of the ANM, including associated systems (eg Communications and SCADA).
- 3.3.10 Duplication of systems to improve reliability.
- 3.3.11 Manual override facilities if required/applicable.
- 3.3.12 Potential for extension of ANM Scheme.
- 3.3.13 Planned unavailability for maintenance; including frequency and duration.
- 3.3.14 Fault rectification methodology including anticipated timescales.
- 3.3.15 Demonstrate that due consideration has been given to the application of Demand Control and to system frequency containment.

3.4 Approval of ANM Algorithm

- 3.4.1 On completion of the design process, the TO shall submit the algorithm to [NGESO](#) ~~The Company~~ for approval of its functionality with respect to the operational

expectations placed on the System Operator in its duty to manage generation in an economic, efficient and coordinated manner.

- 3.4.2 Any issues shall be resolved between ~~NGESO~~The Company and the TO.
- 3.4.3 In the event of dispute, resolution shall be obtained by reference to the Joint Planning Committee.

3.5 *Communication of ANM Implementation to Affected Parties*

- 3.5.1 Generators would be informed through the mechanisms of STCP18-1.
- 3.5.2 Network Operators would be informed via the Joint System Development Liaison group under STCP16-1.

3.6 *Life Cycle of ANM Scheme*

- 3.6.1 Conception
- 3.6.2 Design and Development
 - 3.6.2.1 At this stage the algorithm will be developed and approved by means of liaison between the TO and ~~NGESO~~The Company.
- 3.6.3 Factory Acceptance Test
- 3.6.4 Commissioning and Site Acceptance Testing
 - 3.6.4.1 STCP19-4 refers
- 3.6.5 Production
- 3.6.6 Decommissioning
 - 3.6.6.1 STCP19-4 refers

3.7 *Commissioning of ANM Scheme*

- 3.7.1 Commissioning shall be carried out in accordance with the process detailed in STCP19-4 Commissioning and Decommissioning.
- 3.7.2 In the event of dispute, resolution shall be obtained by reference to the Joint Planning Committee.

3.8 *Modification of ANM Scheme*

- 3.8.1 In the event of a change in network topology or connected generation an existing ANM scheme may need to be amended accordingly. In such cases the same logical sequence of actions shall be taken as previously detailed in this document. The

actual process to be followed in a specific case shall be agreed by the ANM Steering Group.

3.9 ANM Steering Group

3.9.1 In order that ANM schemes may be expedited in an timely and efficient manner the ANM Steering Group shall be convened as early as possible in the development of the TO Construction Offer.

4 Subsidiary Processes

4.1 Definition of Interface Requirements between EBS and TO ANM Systems ANMs

4.1.1 ~~NGESO~~The Company shall agree the interface protocol to/from the EBS such that ANMs shall be designed to interface in a standard way or use a suitable intermediate device.

4.2 Notification of Users of Material Changes in ANM Functionality

4.2.1 Should material changes in the action of a specific ANM scheme be necessary, ~~NGESO~~The Company or Network Operator shall advise the generator of the nature and reason for change as appropriate.

5 Responsibilities of the Parties

5.1 Design Phase

5.1.1 During the conceptualisation and design phase the ANM scheme shall be the responsibility of the host TO.

5.2 Production Phase

5.2.1 During the production phase, the ownership, maintenance and availability of the ANM and its subsidiary communication and control system shall be the responsibility of the TO and/or Network Operator as appropriate. After adoption by ~~NGESO~~The Company, the functionality of the algorithm within the ANM shall be the responsibility of ~~NGESO~~The Company, but any shortfall in performance against its specification would remain the responsibility of the TO and/or Network Operator as appropriate.

Appendix A: Information Exchange Timetable

TO Active Network Management Scheme

All day references are working days

ITEM	ACTIVITY	SOURCE	TARGET TIMESCALE
------	----------	--------	------------------

1	Functional Specification submission to SO	TO	Phase 1 day 1
2	Functional Specification approval by SO	SO	Phase 1 day 15 unless otherwise agreed
3	Design Specification submission to SO	TO	Phase 2 day 1
4	Functional Specification approval by SO	SO	A) Phase 2 day 25 Type 1 ANM B) Phase 2 day 50 Type 2, 3 and 4 ANM
5	Algorithm submission to SO	TO	Phase 3 day 1
6	Algorithm approval by SO	SO	A) Phase 3 day 25 Type 1 ANM B) Phase 3 day 50 Type 2, 3 and 4 ANM
7	Commissioning Plan	TO	In accordance with STCP19-4
8	Revision to existing ANM	TO	Depending on type of revision use timetable above as agreed between parties

Appendix B: Abbreviations & Definitions

Abbreviations

BM	Balancing Mechanism
Other Affected TO	Other Affected Transmission Owner
SCADA	Supervisory Control And Data Acquisition
SHET	Scottish Hydro Electric Transmission plc
SPT	SP Transmission plc
TO	Transmission Owner

Definitions

STC definitions used:

[NGESO The Company](#)

NGET

Transmission Owner

Transmission System

Definitions used from other STCPs:

Joint Planning Committee As defined in STCP16-1 Investment Planning

Boundary of Influence As defined in STCP22-1 Production of Models for NETS System Planning