

**DATA REGISTRATION CODE  
(DRC)  
GRID CODE MODIFICATION GC0156  
DATED ~~521 APRIL NOVEMBER 2023~~ 1420 JUNE 2023**

Text taken from GC0148 when submitted to Ofgem in October 2022

## CONTENTS

(This contents page does not form part of the Grid Code)

<u>Paragraph No/Title</u>	<u>Page Number</u>
DRC.1 INTRODUCTION .....	3
DRC.2 OBJECTIVE .....	3
DRC.3 SCOPE .....	3
DRC.4 DATA CATEGORIES AND STAGES IN REGISTRATION .....	4
DRC.4.2 Standard Planning Data .....	4
DRC.4.3 Detailed Planning Data .....	4
DRC.4.4 Operational Data .....	4
DRC.5 PROCEDURES AND RESPONSIBILITIES .....	4
DRC.5.1 Responsibility For Submission And Updating Of Data .....	4
DRC.5.2 Methods Of Submitting Data .....	4
DRC.5.3 Changes To Users Data .....	6
DRC.5.4 Data Not Supplied .....	6
DRC.5.5 Substituted Data .....	6
DRC.6 DATA TO BE REGISTERED .....	6
SCHEDULE 1 - GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE AND DC CONVERTER TECHNICAL DATA .....	12
SCHEDULE 2 - GENERATION PLANNING PARAMETERS .....	39
SCHEDULE 3 - LARGE POWER STATION OUTAGE PROGRAMMES, OUTPUT USABLE AND INFLEXIBILITY INFORMATION .....	43
SCHEDULE 4 - LARGE POWER STATION DROOP AND RESPONSE DATA .....	44
SCHEDULE 5 - USERS SYSTEM DATA .....	45
SCHEDULE 6 - USERS OUTAGE INFORMATION .....	57
SCHEDULE 7 - LOAD CHARACTERISTICS AT GRID SUPPLY POINTS .....	61
SCHEDULE 8 - DATA SUPPLIED BY BM PARTICIPANTS .....	62
SCHEDULE 9 - DATA SUPPLIED BY NGET TO USERS .....	63
SCHEDULE 10 - DEMAND PROFILES AND ACTIVE ENERGY DATA .....	65
SCHEDULE 11 - CONNECTION POINT DATA .....	67
SCHEDULE 12 - DEMAND CONTROL .....	74
SCHEDULE 13 - FAULT INFEEED DATA .....	78
SCHEDULE 13 - FAULT INFEEED DATA .....	79
SCHEDULE 14 - FAULT INFEEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS) .....	80

SCHEDULE 16 - ~~SYSTEM RESTORATION~~~~BLACK START~~ INFORMATION.....88

SCHEDULE 16 - ~~SYSTEM RESTORATION~~~~BLACK START~~ INFORMATION.....89

SCHEDULE 16 - ~~SYSTEM RESTORATION~~~~BLACK START~~ INFORMATION.....90

SCHEDULE 16 - ~~SYSTEM RESTORATION~~~~BLACK START~~ INFORMATION..... ~~929291~~

SCHEDULE 17 - ACCESS PERIOD DATA ..... ~~989796~~

SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA..... ~~999997~~

SCHEDULE 19 - USER DATA FILE STRUCTURE ..... ~~130130128~~

SCHEDULE 19 - USER DATA FILE STRUCTURE ..... ~~132132130~~

DRC.1 **INTRODUCTION**

DRC.1.1 The **Data Registration Code** ("DRC") presents a unified listing of all data required by **The Company** from **Users** (~~including Restoration ContractorsService Providers where they are not already a User~~) and by **Users** (~~including Restoration ContractorsService Providers where they are not already a User~~) from **The Company**, from time to time under the **Grid Code**. The data which is specified in each section of the **Grid Code** is collated here in the **DRC**. Where there is any inconsistency in the data requirements under any particular section of the **Grid Code** and the **Data Registration Code** the provisions of the particular section of the **Grid Code** shall prevail.

DRC.1.2 The **DRC** identifies the section of the **Grid Code** under which each item of data is required.

DRC.1.3 The Code under which any item of data is required specifies procedures and timings for the supply of that data, for routine updating and for recording temporary or permanent changes to that data. All timetables for the provision of data are repeated in the **DRC**.

DRC.1.4 Various sections of the **Grid Code** also specify information which **Users** will receive from **The Company**. This information is summarised in a single schedule in the **DRC** (Schedule 9).

DRC.1.5 The categorisation of data into **DPD I** and **DPD II** is indicated in the **DRC** below.

~~DRC.1.6 For the purposes of this DRC, if a User is also a Restoration ContractorService Provider, they shall only need to submit the data once stating on their data submission return that they are also a Restoration ContractorService Provider. If a Restoration ContractorService Provider does not have a CUSC Contract then the data required to be submitted shall be pursuant to the terms of the Anchor Plant Contract or Top Up Restoration Contract.~~

DRC.2 **OBJECTIVE**

The objective of the **DRC** is to:

DRC.2.1 List and collate all the data to be provided by each category of **User** to **The Company** under the **Grid Code**.

DRC.2.2 List all the data to be provided by **The Company** to each category of **User** under the **Grid Code**.

DRC.3 **SCOPE**

DRC.3.1 The **DRC** applies to **The Company**, ~~and to~~ **Users** ~~and~~ **Restoration Contractors**, which in this **DRC** means:-

- (a) **Generators** (including those undertaking **OTSDUW** and/or those who own and/or operate **DC Connected Power Park Modules**);
  - (b) **Network Operators**;
  - (c) **DC Converter Station** owners and **HVDC System Owners**;
  - (d) **Suppliers**;
  - (e) **Non-Embedded Customers**;
  - (f) **Externally Interconnected System Operators**;
  - (g) **Interconnector Users**;
  - (h) **BM Participants**; and
  - (i) **Pumped Storage Generators** and **Generators** in respect of Electricity **Storage Modules**.
- ~~(j) Restoration ContractorsService Providers (which would be pursuant to the requirements of their Anchor Restoration Contract or Top Up Restoration Contract).~~

DRC.3.2 For the avoidance of doubt, the **DRC** applies to both **GB Code Users** and **EU Code Users**.

DRC.4 DATA CATEGORIES AND STAGES IN REGISTRATION

DRC.4.1.1 Within the **DRC** each data item is allocated to one of the following three categories:

- (a) **Standard Planning Data (SPD)**
- (b) **Detailed Planning Data (DPD)**
- (c) **Operational Data**

DRC.4.2 Standard Planning Data (SPD)

DRC.4.2.1 The **Standard Planning Data** listed and collated in this **DRC** is that data listed in Part 1 of the Appendix to the **PC**.

DRC.4.2.2 **Standard Planning Data** will be provided to **The Company** in accordance with PC.4.4 and PC.A.1.2.

DRC.4.3 Detailed Planning Data (DPD)

DRC.4.3.1 The **Detailed Planning Data** listed and collated in this **DRC** is categorised as **DPD I** and **DPD II** and is that data listed in Part 2 of the Appendix to the **PC**.

DRC.4.3.2 **Detailed Planning Data** will be provided to **The Company** in accordance with PC.4.4, PC.4.5 and PC.A.1.2.

DRC.4.4 Operational Data

DRC.4.4.1 **Operational Data** is data which is required by the **Operating Codes** and the **Balancing Codes**. Within the **DRC**, **Operational Data** is sub-categorised according to the Code under which it is required, namely **OC1**, **OC2**, **BC1** or **BC2**.

DRC.4.4.2 **Operational Data** is to be supplied in accordance with timetables set down in the relevant **Operating Codes** and **Balancing Codes** and repeated in tabular form in the schedules to the **DRC**.

DRC.5 PROCEDURES AND RESPONSIBILITIES

DRC.5.1 Responsibility For Submission And Updating Of Data

In accordance with the provisions of the various sections of the **Grid Code**, each **User** must submit data as summarised in DRC.6 and listed and collated in the attached schedules.

DRC.5.2 Methods Of Submitting Data

DRC.5.2.1 Wherever possible, the data schedules to the **DRC** are structured to serve as standard formats for data submission and such format must be used for the written submission of data to **The Company**.

DRC.5.2.2 Data must be submitted to the **Transmission Control Centre** notified by **The Company**, or to such other department or address as **The Company** may from time to time advise. The name of the person at the **User Site** who is submitting each schedule of data must be included.

DRC.5.2.3 Where a computer data link exists between a **User** and **The Company**, data may be submitted via this link. **The Company** will, in this situation, provide computer files for completion by the **User** containing all the data in the corresponding **DRC** schedule.

Data submitted can be in an electronic format using a proforma to be supplied by **The Company** or other format to be agreed annually in advance with **The Company**. In all cases the data must be complete and relate to, and relate only to, what is required by the relevant section of the **Grid Code**.

DRC.5.2.4 Other modes of data transfer, such as magnetic tape, may be utilised if **The Company** gives its prior written consent.

DRC.5.2.5 **Generators, HVDC System Owners and DC Converter Station** owners submitting data for a **Power Generating Module, Generating Unit, DC Converter, HVDC System, Power Park Module** (including **DC Connected Power Park Modules**) or **CCGT Module** before the issue of a **Final Operational Notification** should submit the **DRC** data schedules and compliance information required under the **CP** electronically using the **User Data File Structure** unless otherwise agreed with **The Company**. Data required from **Restoration Contractors Service Providers** where not already provided would be pursuant to the terms of their **Anchor Restoration Contract** or **Top Up Restoration Contract**.

DRC.5.3 Changes To User's Data

DRC.5.3.1 Whenever a **User** becomes aware of a change to an item of data which is registered with **The Company**, the **User** must notify **The Company** in accordance with each section of the Grid Code. The method and timing of the notification to **The Company** is set out in each section of the Grid Code. Data required from Restoration Contractors/Service Providers where not already provided would be pursuant to the terms of their Anchor Restoration Contract or Top Up Restoration Contract.

DRC.5.4 Data Not Supplied

DRC.5.4.1 **Users** and **The Company** are obliged to supply data as set out in the individual sections of the **Grid Code** and repeated in the **DRC**. If a **User** fails to supply data when required by any section of the **Grid Code**, **The Company** will estimate such data if and when, in **The Company's** view, it is necessary to do so. If **The Company** fails to supply data when required by any section of the **Grid Code**, the **User** to whom that data ought to have been supplied, will estimate such data if and when, in that **User's** view, it is necessary to do so. Such estimates will, in each case, be based upon data supplied previously for the same **Plant** or **Apparatus** or upon corresponding data for similar **Plant** or **Apparatus** or upon such other information as **The Company** or that **User**, as the case may be, deems appropriate.

DRC.5.4.2 **The Company** will advise a **User** in writing of any estimated data it intends to use pursuant to DRC.5.4.1 relating directly to that **User's Plant** or **Apparatus** in the event of data not being supplied.

DRC.5.4.3 A **User** will advise **The Company** in writing of any estimated data it intends to use pursuant to DRC.5.4.1 in the event of data not being supplied.

DRC.5.4.4 Data requirements defined in DRC5.4.1 – DRC5.4.3 as applicable to a Restoration Contractor/Service Provider where that Restoration Contractor/Service Provider is a not a User, would be pursuant to the terms of the Anchor Restoration Contract or Top Up Restoration Contract.

DRC.5.5 Substituted Data

DRC.5.5.1 In the case of PC.A.4 only, if the data supplied by a **User** does not in **The Company's** reasonable opinion reflect the equivalent data recorded by **The Company**, **The Company** may estimate such data if and when, in the view of **The Company**, it is necessary to do so. Such estimates will, in each case, be based upon data supplied previously for the same **Plant** or **Apparatus** or upon corresponding data for similar **Plant** or **Apparatus** or upon such other information as **The Company** deems appropriate.

DRC.5.5.2 **The Company** will advise a **User** in writing of any estimated data it intends to use pursuant to DRC.5.5.1 relating directly to that **User's Plant** or **Apparatus** where it does not in **The Company's** reasonable opinion reflect the equivalent data recorded by **The Company**. Such estimated data will be used by **The Company** in place of the appropriate data submitted by the **User** pursuant to PC.A.4 and as such shall be deemed to accurately represent the **User's** submission until such time as the **User** provides data to **The Company's** reasonable satisfaction.

DRC.6 DATA TO BE REGISTERED

DRC.6.1 Schedules 1 to 20 attached cover the following data areas.

DRC.6.1.1 Schedule 1 – Power Generating Module, Generating Unit (or CCGT Module), Power Park Module (including DC Connected Power Park Module and Power Park Unit), HVDC System and DC Converter Technical Data.

Comprising **Power Generating Module, Generating Unit (and CCGT Module), Power Park Module (including DC Connected Power Park Module and Power Park Unit) and DC Converter** fixed electrical parameters. Any data required under DRC Schedule 1 from Restoration Contractors/Service Providers where not already provided, would be pursuant to the terms of their Anchor Restoration Contract or Top Up Restoration Contract.

DRC.6.1.2 Schedule 2 - Generation Planning Parameters

Comprising ~~the Genset~~ parameters and data provided from Restoration Contractors Service Providers parameters required for **Operational Planning** studies.

DRC.6.1.3 Schedule 3 - Large Power Station Outage Programmes, Output Usable and Inflexibility Information.

Comprising generation and storage outage planning in respect of Large Power Stations, Output Usable and inflexibility information at timescales down to the daily **BM Unit Data** submission.- In the case of Restoration Contractors Service Providers, this data needs to only to be provided where such a Resoration Contractor Service Provider has an Anchor Restoration Contract or Top Up Restoration Contract other than in respect of Large Power Stations where the data will already be required.

- DRC.6.1.4 Schedule 4 - Large Power Station Droop and Response Data.  
Comprising data on governor **Droop** settings and **Primary, Secondary** and **High Frequency Response** data for **Large Power Stations**.
- DRC.6.1.5 Schedule 5 – User's System Data.  
Comprising electrical parameters relating to **Plant** and **Apparatus** connected to the **National Electricity Transmission System**.
- DRC.6.1.6 Schedule 6 – Users Outage and Restoration Service Provider Outage Information.  
Comprising the information required by **The Company** for outages on the **User's System**, including outages at **Power Stations** other than outages of **Gensets**. Outages of Plant and Apparatus of Restoration Contractors and key Plant and Apparatus of a Network Operator's System associated with a Distribution Restoration Zone Plan also need to be co-ordinated with outages on the National Electricity Transmission System. The data submitted should therefore also include outages on Restoration Contractors Service Providers Plant and Apparatus and Network Operator's User's Plant and Apparatus which would prevent the operation of a Local Joint Restoration- Plan or Distribution Restoration Zone Plan.
- DRC.6.1.7 Schedule 7 - Load Characteristics.  
Comprising the estimated parameters of load groups in respect of, for example, harmonic content and response to frequency.
- DRC.6.1.8 Schedule 8 - BM Unit Data.
- DRC.6.1.9 Schedule 9 - Data Supplied by The Company to Users.
- DRC.6.1.10 Schedule 10 - Demand Profiles and Active Energy Data  
Comprising information relating to the **Network Operators'** and **Non-Embedded Customers'** total **Demand** and **Active Energy** taken from the **National Electricity Transmission System**
- DRC.6.1.11 Schedule 11 - Connection Point Data  
Comprising information relating to **Demand**, demand transfer capability and the **Small Power Station, Medium Power Station** and **Customer** generation connected to the **Connection Point**
- DRC.6.1.12 Schedule 12 - Demand Control Data  
Comprising information related to **Demand Control**
- DRC.6.1.13 Schedule 13 - Fault Infeed Data  
Comprising information relating to the short circuit contribution to the **National Electricity Transmission System** from **Users** other than **Generators, HVDC System Owners** and **DC Converter Station** owners.
- DRC.6.1.14 Schedule 14 - Fault Infeed Data (Generators Including Unit and Station Transformers)  
Comprising information relating to the Short Circuit contribution to the **National Electricity Transmission System** from **Generators, HVDC System Owners** and **DC Converter Station** owners.
- DRC.6.1.15 Schedule 15 – Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module (including Mothballed DC Connected Power Park Modules), Mothballed HVDC Systems, Mothballed HVDC Converters, Mothballed DC Converters at a DC Converter Station and Alternative Fuel Data  
Comprising information relating to estimated return to service times for **Mothballed Power Generating Modules, Mothballed Generating Units, Mothballed Power Park Modules** (including **Mothballed DC Connected Power Park Modules**), **Mothballed HVDC Systems, Mothballed HVDC Converters** and **Mothballed DC Converters at a DC Converter Station** and the capability of gas-fired **Generating Units** to operate using alternative fuels.
- DRC.6.1.16 Schedule 16 – System Restoration Black Start Information

Comprising information relating to **System Restoration**~~Black Start~~.

DRC.6.1.17 Schedule 17 – Access Period Schedule

Comprising **Access Period** information for **Transmission Interface Circuits** within an **Access Group**.

- DRC.6.1.18 Schedule 18 – Generators Undertaking OTSDUW Arrangements  
Comprising electrical parameters relating to **OTSDUW Plant and Apparatus** between the **Offshore Grid Entry Point** and **Transmission Interface Point**.
- DRC.6.1.19 Schedule 19 – User Data File Structure  
Comprising information relating to the **User Data File Structure**.
- DRC.6.1.20 Schedule 20 – Grid Forming Plant Data  
Comprising information relating to **Grid Forming Plant**
- DRC.6.2 The **Schedules** applicable to each class of **User** are as follows:

<u>User</u>	<u>Schedule</u>
<b>Generators with Large Power Stations</b>	1, 2, 3, 4, 9, 14, 15, 16, 19
<b>Generators with Medium Power Stations</b> (see notes 2, 3, 4)	1, 2 (part), 9, 14, 15, 19
<b>Generators with Small Power Stations</b> directly connected to the <b>National Electricity Transmission System</b>	1, 6, 14, 15, 19
<b>Generators undertaking OTSDUW</b> (see note 5)	18, 19
All <b>Users</b> connected directly to the <b>National Electricity Transmission System</b>	5, 6, 9
All <b>Users</b> connected directly to the <b>National Electricity Transmission System</b> other than <b>Generators</b>	10,11,13,17
All <b>Users</b> connected directly to the <b>National Electricity Transmission System</b> with <b>Demand</b>	7, 9
A <b>Pumped Storage Generator</b> , a <b>Generator</b> in respect of one or more <b>Electricity Storage Modules</b> and an <b>Externally Interconnected System Operator</b> and <b>Interconnector Users</b>	12 (as marked)
All <b>Suppliers</b>	12
All <b>Network Operators</b>	<u>12, 16</u>
All <b>BM Participants</b>	8
All <b>DC Converter Station</b> owners	1, 4, 9, 14, 15, 19
<u>Restoration Contractors</u>	<u>2, 3, 6, 16</u>

Notes:

- (1) **Network Operators** must provide data relating to **Small Power Stations** and/or **Customer Generating Plant Embedded** in their **Systems** when such data is requested by **The Company** pursuant to PC.A.3.1.4 or PC.A.5.1.4.
- (2) The data in schedules 1, 14 and 15 need not be supplied in relation to **Medium Power Stations** connected at a voltage level below the voltage level of the **Subtransmission System** except in connection with a **CUSC Contract** or unless specifically requested by **The Company**.
- (3) Each **Network Operator** within whose **System** an **Embedded Medium Power Station** not subject to a **Bilateral Agreement** or **Embedded DC Converter Station** not subject to a **Bilateral Agreement** is situated shall provide the data to **The Company** in respect of each such **Embedded Medium Power Station** or **Embedded DC Converter Station** or **HVDC System**.

- (4) In the case of Schedule 2, **Generators, HVDC System Owners, DC Converter Station** owners or **Network Operators** in the case of **Embedded Medium Power Stations** not subject to a **Bilateral Agreement** or **Embedded DC Converter Stations** not subject to a **Bilateral Agreement**, would only be expected to submit data in relation to **Standard Planning Data** as required by the **Planning Code**.
- (5) In the case of **Generators** undertaking **OTSDUW**, the **Generator** will need to supply **User** data in accordance with the requirements of **Large** or **Small Power Stations** (as defined in DRC.6.2) up to the **Offshore Grid Entry Point**. In addition, the **User** will also need to submit **Offshore Transmission System** data in between the **Interface Point** and its **Connection Points** in accordance with the requirements of Schedule 18.
- ~~(6) In the case of **Restoration ContractorsService Providers**, data only needs to be provided by a **Restoration ContractorService Provider** where such a **Restoration ContractorService Provider** is not a **CUSC Party** and the data has not been submitted previously. In this case the data to be submitted would be would be pursuant tant to the the terms of the **Anchor Restoration Contract** or **Top Up Restoration Contract**.~~

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

PAGE 1 OF 19

ABBREVIATIONS:

**SPD = Standard Planning Data**

% on MVA = % on Rated MVA

% on 100 = % on 100 MVA

**DPD = Detailed Planning Data**

**RC = Registered Capacity**

**MC = Maximum Capacity**

**OC1, BC1, etc = Grid Code**  
for which data is required

**CUSC Contract = User** data which may be submitted to the **Relevant Transmission Licensees** by **The Company**, following the acceptance by a **User** of a **CUSC Contract**.

**CUSC App. Form = User** data which may be submitted to the **Relevant Transmission Licensees** by **The Company**, following an application by a **User** for a **CUSC Contract**.

Note:

All parameters, where applicable, are to be measured at nominal **System Frequency**

+ these **SPD** items should only be given in the data supplied with the application for a **CUSC Contract**.

\* Asterisk items are not required for **Small Power Stations** and **Medium Power Stations**

Information is to be given on a **Unit** basis, unless otherwise stated. Where references to **CCGT Modules** are made, the columns "G1" etc should be amended to read "M1" etc, as appropriate

□ These data items may be submitted to the **Relevant Transmission Licensees** from **The Company** in respect of the **National Electricity Transmission System**. The data may be submitted to the **Relevant Transmission Licensees** in a summarised form e.g. network model; the data transferred will have been originally derived from data submitted by **Users** to **The Company**.

■ these data items may be submitted to the **Relevant Transmission Licensee** from **The Company** in respect to **Relevant Units** only. The data may be submitted to the **Relevant Transmission Licensee** in a summarised form e.g. network model; the data transferred will have been originally derived from data submitted by **Users** to **The Company**.

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 2 OF 19**

POWER STATION NAME: \_\_\_\_\_

DATE: \_\_\_\_\_

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENERATING UNIT OR STATION DATA								
		RTL CUSC Cont ract	CUSC App. Form		F.Yr. 0	F.Yr. 1	F.Yr. 2	F.Yr. 3	F.Yr. 4	F.Yr. 5	F.Yr. 6		
<p><b>GENERATING STATION DEMANDS:</b>  <b>Demand</b> associated with the <b>Power Station</b> supplied through the <b>National Electricity Transmission System</b> or the <b>Generator's User System</b> (PC.A.5.2)</p> <p>- The maximum <b>Demand</b> that could occur.</p> <p>- <b>Demand</b> at specified time of annual peak half hour of <b>National Electricity Transmission System Demand</b> at <b>Annual ACS Conditions</b>.</p> <p><b>Demand</b> at specified time of annual minimum half-hour of <b>National Electricity Transmission System Demand</b>.</p> <p>(Additional <b>Demand</b> supplied through the unit transformers to be provided below)</p> <p><b>INDIVIDUAL GENERATING UNIT (OR AS THE CASE MAY BE, SYNCHRONOUS POWER GENERATING MODULE OR CCGT MODULE) DATA</b></p> <p>Point of connection to the <b>National Electricity Transmission System</b> (or the <b>Total System</b> if embedded) of the <b>Generating Unit</b> or <b>Synchronous Power Generating Module</b> (other than a <b>CCGT Unit</b>) or the <b>CCGT Module</b>, as the case may be in terms of geographical and electrical location and system voltage (PC.A.3.4.1)</p> <p>If the busbars at the <b>Connection Point</b> are normally run in separate sections identify the section to which the <b>Generating Unit</b> (other than a <b>CCGT Unit</b>) or <b>Synchronous Power Generating Module</b> or <b>CCGT Module</b>, as the case may be is connected (PC.A.3.1.5)</p>	<p>MW MVA MW MVA</p> <p>MW MVA</p>	<p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p>	<p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p>	<p><b>DPD I</b> <b>DPD I</b> <b>DPD II</b> <b>DPD II</b></p> <p><b>DPD II</b> <b>DPD II</b></p>									
					G1	G2	G3	G4	G5	G6	STN		
	Text	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD</b>									
	Section Number	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD</b>									



**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 3 OF 19**

<u>INDIVIDUAL SYNCHRONOUS POWER GENERATING MODULE GENERATING UNIT (OR AS THE CASE MAY BE, CCGT MODULE) DATA</u>					G1	G2	G3	G4	G5	G6	STN
<p>A list of the Generating Units and <b>CCGT Units</b> within a <b>Synchronous Power Generating Module</b> or <b>CCGT Module</b>, identifying each <b>CCGT Unit</b>, and the <b>Power Generating Module</b> or <b>CCGT Module</b> of which it forms part, unambiguously. In the case of a <b>Range CCGT Module</b>, details of the possible configurations should also be submitted. (PC.A.3.2.2 (g))</p>	□	▪	SPD								

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 4 OF 19**

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENERATING UNIT (OR CCGT MODULE, AS THE CASE MAY BE)							
		RTL	App. Form		G1	G2	G3	G4	G5	G6	STN	
Rated MVA (PC.A.3.3.1)	MVA	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+								
Rated MW (PC.A.3.3.1)	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+								
Rated terminal voltage (PC.A.5.3.2.(a) & PC.A.5.4.2 (b))	kV	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								
*Performance Chart at Onshore Synchronous Generating Unit stator terminals (PC.A.3.2.2(f)(i))				SPD	(see OC2 for specification)							
*Performance Chart of the Offshore Synchronous Generating Unit at the Offshore Grid Entry Point (PC.A.3.2.2(f)(ii))												
* Synchronous Generating Unit Performance Chart (PC.A.3.2.2(f))												
* Power Generating Module Performance Chart of the Synchronous Power Generating Module (PC.A.3.2.2(f))												
* Maximum terminal voltage set point (PC.A.5.3.2.(a) & PC.A.5.4.2 (b))	kV	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								
* Terminal voltage set point step resolution – if not continuous (PC.A.5.3.2.(a) & PC.A.5.4.2 (b))	kV	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								
*Output Usable (on a monthly basis) (PC.A.3.2.2(b))	MW			SPD	(except in relation to CCGT Modules when required on a unit basis under the Grid Code, this data item may be supplied under Schedule 3)							
Turbo-Generator inertia constant (for synchronous machines) (PC.A.5.3.2(a))	MW secs /MVA	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+								
Short circuit ratio (synchronous machines) (PC.A.5.3.2(a))		<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+								
Normal auxiliary load supplied by the Generating Unit at rated MW output (PC.A.5.2.1)	MW	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
Rated field current at rated MW and MVA output and at rated terminal voltage (PC.A.5.3.2 (a))	MVA	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
Rated field current at rated MW and MVA output and at rated terminal voltage (PC.A.5.3.2 (a))	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
Field current open circuit saturation curve (as derived from appropriate manufacturers' test certificates): (PC.A.5.3.2 (a))												
120% rated terminal volts	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
110% rated terminal volts	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
100% rated terminal volts	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
90% rated terminal volts	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
80% rated terminal volts	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
70% rated terminal volts	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
60% rated terminal volts	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
50% rated terminal volts	A	<input type="checkbox"/>	<input type="checkbox"/>	DPD II								
<b>IMPEDANCES:</b>												
(Unsatrated)												
Direct axis synchronous reactance (PC.A.5.3.2(a))	% on MVA	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								
Direct axis transient reactance (PC.A.3.3.1(a)& PC.A.5.3.2(a))	% on MVA	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+								
Direct axis sub-transient reactance (PC.A.5.3.2(a))	% on MVA	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								
Quad axis synch reactance (PC.A.5.3.2(a))	% on MVA	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								
Quad axis sub-transient reactance (PC.A.5.3.2(a))	% on MVA	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								
Stator leakage reactance (PC.A.5.3.2(a))	% on MVA	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								
Armature winding direct current resistance. (PC.A.5.3.2(a))	% on MVA	<input type="checkbox"/>	<input type="checkbox"/>	DPD I								



**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 5 OF 19**

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENERATING UNIT OR STATION DATA						
		CUSC Contract	CUSC App. Form		G1	G2	G3	G4	G5	G6	STN
<b>TIME CONSTANTS</b>											
(Short-circuit and Unsaturated) Direct axis transient time constant (PC.A.5.3.2(a))	S	<input type="checkbox"/>		DPD I							
Direct axis sub-transient time constant (PC.A.5.3.2(a))	S	<input type="checkbox"/>		DPD I							
Quadrature axis sub-transient time constant (PC.A.5.3.2(a))	S	<input type="checkbox"/>		DPD I							
Stator time constant (PC.A.5.3.2(a))	S	<input type="checkbox"/>		DPD I							
<b>MECHANICAL PARAMETERS</b> (PC.A.5.3.2(a))											
The number of turbine generator masses		<input type="checkbox"/>		DPD II							
Diagram showing the Inertia and parameters for each turbine generator mass for the complete drive train	Kgm <sup>2</sup>	<input type="checkbox"/>		DPD II							
Diagram showing Stiffness constants and parameters between each turbine generator mass for the complete drive train	Nm/rad	<input type="checkbox"/>		DPD II							
Number of poles		<input type="checkbox"/>		DPD II							
Relative power applied to different parts of the turbine	%	<input type="checkbox"/>		DPD II							
Torsional mode frequencies	Hz	<input type="checkbox"/>		DPD II							
Modal damping decrement factors for the different mechanical modes		<input type="checkbox"/>		DPD II							
<b>GENERATING UNIT STEP-UP TRANSFORMER</b>											
Rated MVA (PC.A.3.3.1 & PC.A.5.3.2)	MVA	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+ DPD I							
Voltage Ratio (PC.A.5.3.2)	-	<input type="checkbox"/>		DPD I							
Positive sequence reactance: (PC.A.5.3.2)											
Max tap	% on MVA	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+							
Min tap	% on MVA	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+							
Nominal tap	% on MVA	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD+							
Positive sequence resistance: (PC.A.5.3.2)											
Max tap	% on MVA	<input type="checkbox"/>		DPD II							
Min tap	% on MVA	<input type="checkbox"/>		DPD II							
Nominal tap	% on MVA	<input type="checkbox"/>		DPD II							
Zero phase sequence reactance (PC.A.5.3.2)	% on MVA	<input type="checkbox"/>		DPD II							
Tap change range (PC.A.5.3.2)	+% / -%	<input type="checkbox"/>		DPD II							
Tap change step size (PC.A.5.3.2)	%	<input type="checkbox"/>		DPD II							
Tap changer type: on-load or off-circuit (PC.A.5.3.2)	On/Off	<input type="checkbox"/>		DPD II							

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 6 OF 19**

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENERATING UNIT OR STATION DATA						
		CUSC Contract	CUSC App. Form		G1	G2	G3	G4	G5	G6	STN
<b>EXCITATION:</b>											
<u>Note:</u> The data items requested under Option 1 below may continue to be provided by <b>Generators</b> in relation to <b>Generating Units</b> on the <b>System</b> at 9 January 1995 (in this paragraph, the "relevant date") or they may provide the new data items set out under Option 2. <b>Generators</b> must supply the data as set out under Option 2 (and not those under Option 1) for <b>Generating Unit</b> and <b>Synchronous Power Generating Unit</b> excitation control systems commissioned after the relevant date, those <b>Generating Unit</b> or <b>Synchronous Power Generating Unit</b> excitation control systems recommissioned for any reason such as refurbishment after the relevant date and <b>Generating Unit</b> or <b>Synchronous Power Generating Unit</b> excitation control systems where, as a result of testing or other process, the <b>Generator</b> is aware of the data items listed under Option 2 in relation to that <b>Generating Unit</b> or <b>Synchronous Power Generating Unit</b> .											
<b>Option 1</b>											
DC gain of <b>Excitation Loop</b> (PC.A.5.3.2(c))		<input type="checkbox"/>		DPD II							
Max field voltage (PC.A.5.3.2(c))	V	<input type="checkbox"/>		DPD II							
Min field voltage (PC.A.5.3.2(c))	V	<input type="checkbox"/>		DPD II							
Rated field voltage (PC.A.5.3.2(c))	V	<input type="checkbox"/>		DPD II							
Max rate of change of field volts: (PC.A.5.3.2(c))											
Rising	V/Sec	<input type="checkbox"/>		DPD II							
Falling	V/Sec	<input type="checkbox"/>		DPD II							
Details of <b>Excitation Loop</b> (PC.A.5.3.2(c)) Described in block diagram form showing transfer functions of individual elements	Diagram	<input type="checkbox"/>		DPD II	(please attach)						
Dynamic characteristics of over- excitation limiter (PC.A.5.3.2(c))		<input type="checkbox"/>		DPD II							
Dynamic characteristics of under-excitation limiter (PC.A.5.3.2(c))		<input type="checkbox"/>		DPD II							
<b>Option 2</b>											
<b>Exciter</b> category, e.g. <b>Rotating Exciter</b> , or <b>Static Exciter</b> etc (PC.A.5.3.2(c))	Text	<input type="checkbox"/>	■	SPD							
<b>Excitation System Nominal Response</b> (PC.A.5.3.2(c))	Sec <sup>-1</sup>	<input type="checkbox"/>		DPD II							
$V_E$											
<b>Rated Field Voltage</b> (PC.A.5.3.2(c)) $U_{RN}$	V	<input type="checkbox"/>		DPD II							
<b>No-load Field Voltage</b> (PC.A.5.3.2(c)) $U_{f0}$	V	<input type="checkbox"/>		DPD II							
<b>Excitation System On-Load</b> (PC.A.5.3.2(c))		<input type="checkbox"/>									
<b>Positive Ceiling Voltage</b> $U_{pL+}$	V	<input type="checkbox"/>		DPD II							
<b>Excitation System No-Load</b> (PC.A.5.3.2(c))		<input type="checkbox"/>									
<b>Positive Ceiling Voltage</b> $U_{p0+}$	V	<input type="checkbox"/>		DPD II							
<b>Excitation System No-Load</b> (PC.A.5.3.2(c))		<input type="checkbox"/>									
<b>Negative Ceiling Voltage</b> $U_{p0-}$	V	<input type="checkbox"/>		DPD II							
<b>Power System Stabiliser (PSS) fitted</b> (PC.A.3.4.2)	Yes/No	<input type="checkbox"/>	■	SPD							
Stator Current Limit (PC.A.5.3.2(c))	A	<input type="checkbox"/>		DPD II							
Details of <b>Excitation System</b> (PC.A.5.3.2(c)) (including <b>PSS</b> if fitted) described in block diagram form showing transfer functions of individual elements.	Diagram	<input type="checkbox"/>		DPD II							
Details of <b>Over-excitation Limiter</b> (PC.A.5.3.2(c)) described in block diagram form showing transfer functions of individual elements.	Diagram	<input type="checkbox"/>		DPD II							
Details of <b>Under-excitation Limiter</b> (PC.A.5.3.2(c)) described in block diagram form showing	Diagram	<input type="checkbox"/>		DPD II							



**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 7 OF 19**

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENERATING UNIT OR STATION DATA						
		RTL	CUSC Contract		CUSC App. Form	G1	G2	G3	G4	G5	G6
<b>GOVERNOR AND ASSOCIATED PRIME MOVER PARAMETERS</b>											
<p><b>Note:</b> The data items requested under Option 1 below may continue to be provided by <b>Generators</b> in relation to <b>Generating Units</b> on the <b>System</b> at 9 January 1995 (in this paragraph, the "relevant date") or they may provide the new data items set out under Option 2. <b>Generators</b> must supply the data as set out under Option 2 (and not those under Option 1) for <b>Generating Unit</b> and <b>Synchronous Power Generating Unit</b> governor control systems commissioned after the relevant date, those <b>Generating Unit</b> and <b>Synchronous Power Generating Unit</b> governor control systems recommissioned for any reason such as refurbishment after the relevant date and <b>Generating Unit</b> and <b>Synchronous Power Generating Unit</b> governor control systems where, as a result of testing or other process, the <b>Generator</b> is aware of the data items listed under Option 2 in relation to that <b>Generating Unit</b> and <b>Synchronous Power Generating Unit</b>.</p>											
<b>Option 1</b>											
<u>GOVERNOR PARAMETERS (REHEAT UNITS) (PC.A.5.3.2(d) – Option 1(i))</u>											
HP Governor average gain	MW/Hz	<input type="checkbox"/>		DPD II							
Speeder motor setting range	Hz	<input type="checkbox"/>		DPD II							
HP governor valve time constant	S	<input type="checkbox"/>		DPD II							
HP governor valve opening limits		<input type="checkbox"/>		DPD II							
HP governor valve rate limits		<input type="checkbox"/>		DPD II							
Re-heat time constant (stored <b>Active Energy</b> in reheater)	S	<input type="checkbox"/>		DPD II							
IP governor average gain	MW/Hz	<input type="checkbox"/>		DPD II							
IP governor setting range	Hz	<input type="checkbox"/>		DPD II							
IP governor time constant	S	<input type="checkbox"/>		DPD II							
IP governor valve opening limits		<input type="checkbox"/>		DPD II							
IP governor valve rate limits		<input type="checkbox"/>		DPD II							
Details of acceleration sensitive elements HP & IP in governor loop		<input type="checkbox"/>		DPD II	(please attach)						
Governor block diagram showing transfer functions of individual elements		<input type="checkbox"/>		DPD II	(please attach)						
<u>GOVERNOR (Non-reheat steam and Gas Turbines) (PC.A.5.3.2(d) – Option 1(ii))</u>											
Governor average gain	MW/Hz	<input type="checkbox"/>		DPD II							
Speeder motor setting range		<input type="checkbox"/>		DPD II							
Time constant of steam or fuel governor valve	S	<input type="checkbox"/>		DPD II							
Governor valve opening limits		<input type="checkbox"/>		DPD II							
Governor valve rate limits		<input type="checkbox"/>		DPD II							
Time constant of turbine	S	<input type="checkbox"/>		DPD II							
Governor block diagram		<input type="checkbox"/>		DPD II	(please attach)						

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 8 OF 19**


DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENERATING UNIT OR STATION DATA						
		CUSC Contract	CUSC App. Form		G1	G2	G3	G4	G5	G6	STN
<i>(PC.A.5.3.2(d) – Option 1(iii))</i> <b>BOILER &amp; STEAM TURBINE DATA*</b>											
Boiler time constant (Stored <b>Active Energy</b> )	S			DPD II							
HP turbine response ratio: (Proportion of <b>Primary Response</b> arising from HP turbine)	%			DPD II							
HP turbine response ratio: (Proportion of <b>High Frequency Response</b> arising from HP turbine)	%			DPD II							
End of Option 1											
<b>Option 2</b>											
<b>All Generating Units and Synchronous Power Generating Units</b>											
Governor Block Diagram showing transfer function of individual elements including acceleration sensitive elements			<input type="checkbox"/>	DPD II							
Governor Time Constant <i>(PC.A.5.3.2(d) – Option 2(i))</i>	Sec		<input type="checkbox"/>	DPD II							
#Governor Deadband <i>(PC.A.5.3.2(d) – Option 2(i))</i>											
- Maximum Setting	±Hz			DPD II							
- Normal Setting	±Hz			DPD II							
- Minimum Setting	±Hz			DPD II							
Speeder Motor Setting Range <i>(PC.A.5.3.2(d) – Option 2(i))</i>	%		<input type="checkbox"/>	DPD II							
Average Gain <i>(PC.A.5.3.2(d) – Option 2(i))</i>	MW/Hz		<input type="checkbox"/>	DPD II							
<b>Steam Units</b>											
<i>(PC.A.5.3.2(d) – Option 2(ii))</i>											
HP Valve Time Constant	sec		<input type="checkbox"/>	DPD II							
HP Valve Opening Limits	%		<input type="checkbox"/>	DPD II							
HP Valve Opening Rate Limits	%/sec		<input type="checkbox"/>	DPD II							
HP Valve Closing Rate Limits	%/sec		<input type="checkbox"/>	DPD II							
HP Turbine Time Constant <i>(PC.A.5.3.2(d) – Option 2(ii))</i>	sec		<input type="checkbox"/>	DPD II							
IP Valve Time Constant	sec		<input type="checkbox"/>	DPD II							
IP Valve Opening Limits	%		<input type="checkbox"/>	DPD II							
IP Valve Opening Rate Limits	%/sec		<input type="checkbox"/>	DPD II							
IP Valve Closing Rate Limits	%/sec		<input type="checkbox"/>	DPD II							
IP Turbine Time Constant <i>(PC.A.5.3.2(d) – Option 2(ii))</i>	sec		<input type="checkbox"/>	DPD II							
LP Valve Time Constant	sec		<input type="checkbox"/>	DPD II							
LP Valve Opening Limits	%		<input type="checkbox"/>	DPD II							
LP Valve Opening Rate Limits	%/sec		<input type="checkbox"/>	DPD II							
LP Valve Closing Rate Limits	%/sec		<input type="checkbox"/>	DPD II							
LP Turbine Time Constant <i>(PC.A.5.3.2(d) – Option 2(ii))</i>	sec		<input type="checkbox"/>	DPD II							
Reheater Time Constant	sec			DPD II							
Boiler Time Constant	sec			DPD II							
HP Power Fraction	%			DPD II							
IP Power Fraction	%			DPD II							

# Where the generating unit or synchronous power generating unit governor does not have a selectable deadband facility, then the actual value of the deadband need only be provided.

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 9 OF 19**

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENERATING UNIT OR STATION DATA						
		CUSC Contract	CUSC App. Form		G1	G2	G3	G4	G5	G6	STN
<b>Gas Turbine Units</b>											
<i>(PC.A.5.3.2(d) – Option 2(iii))</i>											
Inlet Guide Vane Time Constant	sec	<input type="checkbox"/>		DPD II							
Inlet Guide Vane Opening Limits	%	<input type="checkbox"/>		DPD II							
Inlet Guide Vane Opening Rate Limits	%/sec	<input type="checkbox"/>		DPD II							
Inlet Guide Vane Closing Rate Limits	%/sec	<input type="checkbox"/>		DPD II							
<i>(PC.A.5.3.2(d) – Option 2(iii))</i>											
Fuel Valve Time Constant	sec	<input type="checkbox"/>		DPD II							
Fuel Valve Opening Limits	%	<input type="checkbox"/>		DPD II							
Fuel Valve Opening Rate Limits	%/sec	<input type="checkbox"/>		DPD II							
Fuel Valve Closing Rate Limits	%/sec	<input type="checkbox"/>		DPD II							
<i>(PC.A.5.3.2(d) – Option 2(iii))</i>											
Waste Heat Recovery Boiler Time Constant											
<b>Hydro Generating Units</b>											
<i>(PC.A.5.3.2(d) – Option 2(iv))</i>											
Guide Vane Actuator Time Constant	sec	<input type="checkbox"/>		DPD II							
Guide Vane Opening Limits	%	<input type="checkbox"/>		DPD II							
Guide Vane Opening Rate Limits	%/sec	<input type="checkbox"/>		DPD II							
Guide Vane Closing Rate Limits	%/sec	<input type="checkbox"/>		DPD II							
Water Time Constant	sec	<input type="checkbox"/>		DPD II							
<b>Synchronous Electricity Storage Units and Modules</b>											
<i>(PC.A.5.3.2(d) – Option 2(v))</i>											
Valve Actuator Time Constant	sec	<input type="checkbox"/>		DPD II							
Valve Opening Limits	%	<input type="checkbox"/>		DPD II							
Valve Opening Rate Limits	%/sec	<input type="checkbox"/>		DPD II							
Valve Closing Rate Limits	%/sec	<input type="checkbox"/>		DPD II							
For <b>Synchronous Electricity Storage Modules</b> which are derived from compressed air energy storage systems the above data should be provided. For other <b>Synchronous Electricity Storage Modules</b> data should be supplied as required by <b>The Company</b> in accordance with PC.A.7.											
End of Option 2											
<b>UNIT CONTROL OPTIONS*</b>											
<i>(PC.A.5.3.2(e))</i>											
Maximum droop	%	<input type="checkbox"/>		DPD II							
Normal droop	%	<input type="checkbox"/>		DPD II							
Minimum droop	%	<input type="checkbox"/>		DPD II							
Maximum <b>Governor Deadband</b>				DPD II							
Normal <b>Governor Deadband</b>				DPD II							
Minimum <b>Governor Deadband</b>											
Maximum <b>Frequency Response Deadband</b> <sup>1</sup>	±Hz			DPD II							
Normal <b>Frequency Response Deadband</b> <sup>1</sup>	±Hz			DPD II							
Minimum <b>Frequency Response Deadband</b> <sup>1</sup>	±Hz			DPD II							
Maximum <b>Frequency Response Insensitivity</b> <sup>1</sup>	±Hz			DPDII							
Normal <b>Frequency Response Insensitivity</b> <sup>1</sup>	±Hz			DPDII							
Minimum <b>Frequency Response Insensitivity</b> <sup>1</sup>	±Hz			DPDII							

	±Hz																		
	±Hz																		
	±Hz																		
Frequency settings between which Unit Load Controller droop applies:																			
Maximum	Hz																		
Normal	Hz																		
Minimum	Hz																		
Sustained response normally selected	Yes/No																		
<sup>1</sup> Data required only in respect of <b>Large Power Stations</b> comprising <b>Type C</b> and <b>Type D Power Generating Modules</b> owned and operated by <b>EU Code Generators</b> .																			



**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 10 OF 19**

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE)							
		CUSC Contract	CUSC App. Form		G1	G2	G3	G4	G5	G6	STN	
<b>Power Park Module Rated MVA</b> (PC.A.3.3.1(a))	MVA	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD+</b>								
<b>Power Park Module Rated MW</b> (PC.A.3.3.1(a))	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD+</b>								
*Performance Chart of a <b>Power Park Module</b> at the connection point (PC.A.3.2.2(f)(ii))				<b>SPD</b>	(see <b>OC2</b> for specification)							
* <b>Output Usable</b> (on a monthly basis) (PC.A.3.2.2(b))	MW			<b>SPD</b>	(except in relation to <b>CCGT Modules</b> when required on a unit basis under the <b>Grid Code</b> , this data item may be supplied under Schedule 3)							
Number & Type of <b>Power Park Units</b> within each <b>Power Park Module</b> (PC.A.3.2.2(k))		<input type="checkbox"/>		<b>SPD</b>								
Number & Type of <b>Offshore Power Park Units</b> within each <b>Offshore Power Park String</b> and the number of <b>Offshore Power Park Strings</b> and connection point within each <b>Offshore Power Park Module</b> (PC.A.3.2.2.(k))				<b>SPD</b>								
In the case where an appropriate <b>Manufacturer's Data &amp; Performance Report</b> is registered with <b>The Company</b> then subject to <b>The Company's</b> agreement, the report reference may be given as an alternative to completion of the following sections of this Schedule 1 to the end of page 11 with the exception of the sections marked thus # below.	Reference the <b>Manufacturer's Data &amp; Performance Report</b>			<b>SPD</b>								
<b>Power Park Unit Model</b> (including <b>Non Synchronous Electricity Storage Units</b> ) - A validated mathematical model in accordance with PC.5.4.2 (a)	Transfer function block diagram and algebraic equations, simulation and measured test results	<input type="checkbox"/>		<b>DPD II</b>								





**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 13 OF 19**

DATA DESCRIPTION	UNITS	DATA to RTL		DATA CAT.	POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE)							
		CUSC Contract	CUSC App. Form		G1	G2	G3	G4	G5	G6	STN	
<p>Torque / Speed and blade angle control systems and parameters (PC.A.5.4.2(c))</p> <p>For the <b>Power Park Unit</b>, details of the torque / speed controller and blade angle controller in the case of a wind turbine and power limitation functions (where applicable) described in block diagram form showing transfer functions and parameters of individual elements</p>	Diagram	<input type="checkbox"/>		DPD II								
<p># Voltage/Reactive Power/Power Factor control system parameters (PC.A.5.4.2(d))</p> <p># For the <b>Power Park Unit</b> and <b>Power Park Module</b> details of <b>Voltage/Reactive Power/Power Factor</b> controller (and <b>PSS</b> if fitted) described in block diagram form including parameters showing transfer functions of individual elements.</p>	Diagram	<input type="checkbox"/>		DPD II								
<p># <b>Frequency</b> control system parameters (PC.A.5.4.2(e))</p> <p># For the <b>Power Park Unit</b> and <b>Power Park Module</b> details of the <b>Frequency</b> controller described in block diagram form showing transfer functions and parameters of individual elements.</p>	Diagram	<input type="checkbox"/>		DPD II								
<p>As an alternative to PC.A.5.4.2 (a), (b), (c), (d), (e) and (f), is the submission of a single complete model that consists of the full information required under PC.A.5.4.2 (a), (b), (c), (d) (e) and (f) provided that all the information required under PC.A.5.4.2 (a), (b), (c), (d), (e) and (f) individually is clearly identifiable. (PC.A.5.4.2(g))</p>	Diagram	<input type="checkbox"/>		DPD II								
# Harmonic Assessment Information (PC.A.5.4.2(h)) (as defined in IEC 61400-21 (2001)) for each <b>Power Park Unit</b> :-												
# Flicker coefficient for continuous operation		<input type="checkbox"/>		DPD I								
# Flicker step factor		<input type="checkbox"/>		DPD I								
# Number of switching operations in a 10 minute window		<input type="checkbox"/>		DPD I								
# Number of switching operations in a 2 hour window		<input type="checkbox"/>		DPD I								
# Voltage change factor		<input type="checkbox"/>		DPD I								
# Current Injection at each harmonic for each <b>Power Park Unit</b> and for each <b>Power Park Module</b>	Tabular format	<input type="checkbox"/>		DPD I								
<p>Note:- <b>Generators</b> who own or operate <b>DC Connected Power Park Modules</b> shall supply all data for their <b>DC Connected Power Park Modules</b> as applicable to <b>Power Park Modules</b>.</p>												

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
**PAGE 14 OF 19**

HVDC SYSTEM AND DC CONVERTER STATION TECHNICAL DATA

HVDC SYSTEM OR DC CONVERTER STATION NAME \_\_\_\_\_

DATE: \_\_\_\_\_

Data Description	Units	DATA to		Data Category	DC Converter Station Data
		RTL			
(P.C.A.4)		CUSC Contract	CUSC App. Form		
<b>HVDC SYSTEM AND DC CONVERTER STATION DEMANDS:</b>					
<b>Demand</b> supplied through <b>Station Transformers</b> associated with the <b>DC Converter Station and HVDC System [P.C.A.4.1]</b>	MW MVA	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- <b>Demand</b> with all <b>DC Converters</b> and <b>HVDC Converters</b> within and HVDC System operating at <b>Rated MW</b> import.	MW MVA	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- <b>Demand</b> with all <b>DC Converters</b> and <b>HVDC Converters</b> within an HVDC System operating at <b>Rated MW</b> export.					
Additional <b>Demand</b> associated with the <b>DC Converter Station or HVDC System</b> supplied through the <b>National Electricity Transmission System. [P.C.A.4.1]</b>	MW MVA	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- The maximum <b>Demand</b> that could occur.	MW MVA	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- <b>Demand</b> at specified time of annual peak half hour of <b>The Company Demand</b> at <b>Annual ACS Conditions.</b>	MW MVA	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- <b>Demand</b> at specified time of annual minimum half-hour of <b>The Company Demand.</b>	Text	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD+</b>	
<b>DC CONVERTER STATION AND HVDC SYSTEM DATA</b>	Text	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD+</b>	
Number of poles, i.e. number of <b>DC Converters</b> or <b>HVDC Converters</b> within the <b>HVDC System</b>		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD+</b>	
Pole arrangement (e.g. monopole or bipole)		<input type="checkbox"/>	<input checked="" type="checkbox"/>		
Details of each viable operating configuration	Diagram	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD</b>	
Configuration 1	Diagram	<input type="checkbox"/>	<input type="checkbox"/>		
Configuration 2	Diagram	<input type="checkbox"/>	<input type="checkbox"/>		
Configuration 3	Diagram	<input type="checkbox"/>	<input type="checkbox"/>		

Configuration 4	Diagram	<input type="checkbox"/>			
Configuration 5		<input type="checkbox"/>			
Configuration 6	Diagram	<input type="checkbox"/>			
Remote ac connection arrangement		<input type="checkbox"/>			

**SCHEDULE 1 – POWER PARK MODULE, GENERATING UNIT (OR CCGT MODULE),  
 POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM  
 AND DC CONVERTER TECHNICAL DATA  
 PAGE 15 OF 19**

Data Description	Units	DATA to RTL		Data Category	Operating Configuration					
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6
<b>DC CONVERTER STATION AND HVDC SYSTEM DATA (PC.A.3.3.1d)</b>										
DC Converter or HVDC Converter Type (e.g. current or Voltage source)	Text	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD						
Point of connection to the <b>National Electricity Transmission System</b> (or the <b>Total System</b> if <b>Embedded</b> ) of the <b>DC Converter Station</b> or <b>HVDC System</b> configuration in terms of geographical and electrical location and system voltage	Text	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD						
If the busbars at the <b>Connection Point</b> are normally run in separate sections identify the section to which the <b>DC Converter Station</b> or <b>HVDC System</b> configuration is connected	Section Number	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD						
	MW			SPD +						
<b>Rated MW</b> import per pole [PC.A.3.3.1]	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD +						
<b>Rated MW</b> export per pole [PC.A.3.3.1]		<input type="checkbox"/>	<input checked="" type="checkbox"/>							

Data Description	Units	DATA to RTL		Data Category	Operating Configuration						
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6	
<b>ACTIVE POWER TRANSFER CAPABILITY</b> (P.C.A.3.2.2)											
<b>Registered Capacity</b>	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD</b>							
<b>Registered Import Capacity</b>	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>								
<b>Minimum Generation</b>	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>SPD</b>							
<b>Minimum Import Capacity</b>	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>								
<b>Maximum HVDC Active Power</b>	MW										
<b>Transmission Capacity</b>	MW	<input type="checkbox"/>		<b>SPD</b>							
<b>Minimum Active Power Transmission Capacity</b>	MW	<input type="checkbox"/>		<b>SPD</b>							
Import MW available in excess of <b>Registered Import Capacity</b> and <b>Maximum Active Power Transmission Capacity</b>	MW	<input type="checkbox"/>		<b>SPD</b>							
Time duration for which MW in excess of <b>Registered Import Capacity</b> is available	Min	<input type="checkbox"/>		<b>SPD</b>							
Export MW available in excess of <b>Registered Capacity</b> and <b>Maximum Active Power Transmission Capacity</b> .	MW	<input type="checkbox"/>		<b>SPD</b>							
Time duration for which MW in excess of <b>Registered Capacity</b> is available	Min	<input type="checkbox"/>		<b>SPD</b>							

**SCHEDULE 1 –POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**


Data Description	Units	DATA to RTL		Data Category	Operating Configuration					
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6
<b>DC CONVERTER AND HVDC CONVERTER TRANSFORMER [PC.A.5.4.3.1]</b>										
Rated MVA	MVA	<input type="checkbox"/>		DPD II						
Winding arrangement		<input type="checkbox"/>		DPD II						
Nominal primary voltage	kV	<input type="checkbox"/>		DPD II						
Nominal secondary (converter-side) voltage(s)	kV	<input type="checkbox"/>		DPD II						
Positive sequence reactance										
Maximum tap	% on MVA	<input type="checkbox"/>		DPD II						
Nominal tap	% on MVA	<input type="checkbox"/>		DPD II						
Minimum tap	% on MVA	<input type="checkbox"/>		DPD II						
Positive sequence resistance										
Maximum tap	% on MVA	<input type="checkbox"/>		DPD II						
Nominal tap	% on MVA	<input type="checkbox"/>		DPD II						
Minimum tap	% on MVA	<input type="checkbox"/>		DPD II						
Zero phase sequence reactance	% on MVA	<input type="checkbox"/>		DPD II						
Tap change range	+%/ -%	<input type="checkbox"/>		DPD II						
Number of steps		<input type="checkbox"/>		DPD II						

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), DC CONNECTED POWER PARK MODULE, HVDC SYSTEM, POWER PARK MODULE AND DC CONVERTER TECHNICAL DATA**  
**PAGE 17 OF 19**

Data Description	Units	DATA to RTL		Data Category	Operating configuration					
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6
<p><b>DC NETWORK [PC.A.5.4.3.1 (c)]</b></p> <p>Rated DC voltage per pole  Rated DC current per pole</p> <p>Details of the <b>DC Network</b> described in diagram form including resistance, inductance and capacitance of all DC cables and/or DC lines. Details of any line reactors (including line reactor resistance), line capacitors, DC filters, earthing electrodes and other conductors that form part of the <b>DC Network</b> should be shown.</p>	<p>kV  A</p> <p>Diagram</p>	<p><input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/></p>		<p><b>DPD II</b>  <b>DPD II</b>    <b>DPD II</b></p>						
<p><b>DC CONVERTER STATION AND HVDC SYSTEM AC HARMONIC FILTER AND REACTIVE COMPENSATION EQUIPMENT [PC.A.5.4.3.1 (d)]</b></p> <p>For all switched reactive compensation equipment</p> <p>Total number of AC filter banks  Diagram of filter connections  Type of equipment (e.g. fixed or variable)  Capacitive rating; or  Inductive rating; or  Operating range</p> <p><b>Reactive Power</b> capability as a function of various MW transfer levels</p>	<p>Diagram</p> <p>Text  Diagram  Text  MVA  MVA  MVA  MVA  Table</p>	<p><input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/>  <input type="checkbox"/></p>	<p>■  ■  ■</p>	<p><b>DPD II</b>    <b>DPD II</b>  <b>DPD II</b>  <b>DPD II</b>  <b>DPD II</b>  <b>DPD II</b>    <b>DPD II</b></p>						

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT  
MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE,  
HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
PAGE 18 OF 19

Data Description	Units	DATA to <b>RTL</b>		Data Category	Operating configuration							
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6		





Data Description	Units	DATA to RTL		Data Category	Operating configuration						
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6	
		<input type="checkbox"/>									
		<input type="checkbox"/>									
		<input type="checkbox"/>									
		<input type="checkbox"/>									
		<input type="checkbox"/>									
		<input type="checkbox"/>									

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
PAGE 19 OF 19

Data Description	Units	DATA to RTL		Data Category	Operating configuration						
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6	
<b>LOADING PARAMETERS [PC.A.5.4.3.3]</b>											
MW Export											
Nominal loading rate	MW/s			<b>DPD I</b>							
Maximum (emergency) loading rate	MW/s			<b>DPD I</b>							
MW Import											
Nominal loading rate	MW/s			<b>DPD I</b>							
Maximum (emergency) loading rate	MW/s			<b>DPD I</b>							
Maximum recovery time, to 90% of pre-fault loading, following an AC system fault or severe voltage depression.	s	<input type="checkbox"/>		<b>DPD II</b>							
Maximum recovery time, to 90% of pre-fault loading, following a transient DC Network fault.	s	<input type="checkbox"/>		<b>DPD II</b>							

**NOTE:** Users are referred to Schedules 5 & 14 which set down data required for all Users directly connected to the National Electricity Transmission System, including Power Stations. Generators undertaking OTSDUW Arrangements and are utilising an OTSDUW DC Converter are referred to Schedule 18.

## SCHEDULE 2 - GENERATION PLANNING PARAMETERS

PAGE 1 OF 3

This schedule contains the **Genset Generation Planning Parameters** required by **The Company** to facilitate studies in **Operational Planning** timescales.

For a **Generating Unit** including those within a **Power Generating Module** (other than a **Power Park Unit**) at a **Large Power Station**, the information is to be submitted on a unit basis and for a **CCGT Module** or **Power Park Module** at a **Large Power Station** the information is to be submitted on a module basis, unless otherwise stated.

Where references to **CCGT Modules** or **Power Park Modules** at a **Large Power Station** are made, the columns "G1" etc should be amended to read "M1" etc, as appropriate.

In the case of Restoration 6 Contractors Service Providers, data only needs to be provided by a Restoration Contractor Service Provider where they are such a Restoration Service Provider is not a CUSC Party and the data has not been submitted previously. In this case the data to be submitted would be pursuant to the the terms of the Anchor Restoration Contract or Top Up Restoration Contract if required.

Power Station: \_\_\_\_\_

### Generation Planning Parameters

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENSET OR STATION DATA						
		CUSC Contract	RTL CUSC App. Form		G1	G2	G3	G4	G5	G6	STN
<b>OUTPUT CAPABILITY</b> (PC.A.3.2.2)											
<b>Registered Capacity</b> on a station and unit basis (on a station and module basis in the case of a <b>CCGT Module</b> or <b>Power Park Module</b> at a <b>Large Power Station</b> )	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD							
<b>Maximum Capacity</b> on a <b>Power Generating Module</b> basis and <b>Synchronous Generating Unit</b> basis and <b>Registered Capacity</b> on a <b>Power Station</b> basis)	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD							
<b>Minimum Generation</b> (on a module basis in the case of a <b>CCGT Module</b> or <b>Power Park Module</b> at a <b>Large Power Station</b> )	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD							
<b>Minimum Stable Operating Level</b> (on a module basis in the case of a <b>Power Generating Module</b> at a <b>Large Power Station</b> )	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD							
MW available from <b>Power Generating Modules</b> and <b>Generating Units</b> or <b>Power Park Modules</b> in excess of <b>Registered Capacity</b> or <b>Maximum Capacity</b>	MW	<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD							
<b>REGIME UNAVAILABILITY</b>											
These data blocks are provided to allow fixed periods of unavailability to be registered.											
<b>Expected Running Regime.</b> Is <b>Power Station</b> normally available for full output 24 hours per day, 7 days per week? If No please provide details of unavailability below. (PC.A.3.2.2.)		<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPD							
Earliest <b>Synchronising</b> time: OC2.4.2.1(a)											
Monday	hr/min	<input checked="" type="checkbox"/>		OC2							-
Tuesday – Friday	hr/min	<input checked="" type="checkbox"/>		OC2							-
Saturday – Sunday	hr/min	<input checked="" type="checkbox"/>		OC2							-
Latest <b>De-Synchronising</b> time: OC2.4.2.1(a)											
Monday – Thursday	hr/min	<input checked="" type="checkbox"/>		OC2							-
Friday	hr/min	<input checked="" type="checkbox"/>		OC2							-





## SCHEDULE 2 - GENERATION PLANNING PARAMETERS

PAGE 3 OF 3

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENSET OR STATION DATA							
		RTL CUSC Contract	CUSC App. Form		G1	G2	G3	G4	G5	G6	STN	
<b>REGULATION PARAMETERS</b>												
<i>OC2.4.2.1(a)</i>												
Regulating Range	MW	▪		DPD II								
Load rejection capability while still Synchronised and able to supply Load.	MW	▪		DPD II								
<b>GAS TURBINE LOADING PARAMETERS:</b>												
<i>OC2.4.2.1(a)</i>												
Fast loading	MW/Min	▪		OC2								
Slow loading	MW/Min	▪		OC2								
<b>CCGT MODULE PLANNING MATRIX</b>				OC2	(please attach)							
<b>POWER PARK MODULE PLANNING MATRIX</b>				OC2	(please attach)							
<b>Power Park Module Active Power Output/ Intermittent Power Source Curve (e.g., MW output / Wind speed)</b>				OC2	(please attach)							

**NOTES:**

- (1) To allow for different groups of **Gensets** within a **Power Station** (e.g., **Gensets** with the same operator) each **Genset** may be allocated to one of up to four **Synchronising Groups**. Within each such **Synchronising Group** the single synchronising interval will apply but between **Synchronising Groups** a zero synchronising interval will be assumed.
- (2) The run-up of a **Genset** from synchronising block load to **Registered Capacity** or **Maximum Capacity** is represented as a three stage characteristic in which the run-up rate changes at two intermediate loads, MWL1 and MWL2. The values MWL1 & MWL2 can be different for each **Genset**.

**SCHEDULE 3 - LARGE POWER STATION OUTAGE PROGRAMMES, OUTPUT  
USABLE AND INFLEXIBILITY INFORMATION  
PAGE 1 OF 1**

(Also outline information on contracts involving **External Interconnections**)

For a **Generating Unit** at a **Large Power Station** the information is to be submitted on a unit basis and for a **CCGT Module** or **Power Park Module** at a **Large Power Station** the information is to be submitted on a module basis, unless otherwise stated.

In the case of Restoration Contractors/Service Providers, data only needs to be provided by a Restoration Contractor/Service Provider where such a Restoration Contractor/Service Provider is not a CUSC Party and the data has not been submitted previously. In this case, the data to be submitted would be pursuant to the terms of the Anchor Restoration Contract or Top Up Restoration Contract.

DATA DESCRIPTION	UNITS	TIME COVERED	UPDATE TIME	DATA CAT	DATA to RTL		
<u>OUTPUT PROFILES</u>							
						CUSC Contract	CUSC App. Form
In the case of <b>Large Power Stations</b> whose output may be expected to vary in a random manner (e.g., wind power) or to some other pattern (e.g., Tidal) sufficient information is required to enable an understanding of the possible profile	MW	F. yrs 1 - 7	Week 24	<b>SPD</b>			

Notes: 1. The week numbers quoted in the Update Time column refer to standard weeks in the current year.

## SCHEDULE 4 - LARGE POWER STATION DROOP AND RESPONSE DATA

PAGE 1 OF 1

### GOVERNOR DROOP AND RESPONSE (PC.A.5.5 ■ CUSC Contract)

The Data in this Schedule 4 is to be supplied by **Generators** with respect to all **Large Power Stations, HVDC System Owners** and by **DC Converter Station owners** (where agreed), whether directly connected or **Embedded**

DATA DESCRIPTION	NORMAL VALUE	MW	DATA CAT	DROOP%			RESPONSE CAPABILITY		
				Unit 1	Unit 2	Unit 3	Primary	Secondary	High Frequency
MLP1	Designed Minimum Operating Level or Minimum Regulating Level (for a CCGT Module or Power Park Module, on a modular basis assuming all units are Synchronised)								
MLP2	Minimum Generation or Minimum Stable Operating Level (for a CCGT Module or Power Park Module, or Power Generating Module on a modular basis assuming all units are Synchronised)								
MLP3	70% of Registered Capacity or Maximum Capacity								
MLP4	80% of Registered Capacity or Maximum Capacity								
MLP5	95% of Registered Capacity or Maximum Capacity								
MLP6	Registered Capacity or Maximum Capacity								

**Notes:**

1. The data provided in this Schedule 4 is not intended to constrain any **Ancillary Services Agreement**.
2. **Registered Capacity** or **Maximum Capacity** should be identical to that provided in Schedule 2.
3. The Governor Droop should be provided for each **Generating Unit**(excluding **Power Park Units**), **Power Park Module**, **HVDC Converter** or **DC Converter**. The Response Capability should be provided for each **Genset** or **DC Converter**.
4. **Primary**, **Secondary** and **High Frequency Response** are defined in CC.A.3.2 or ECC.A.3.2 and are based on a frequency ramp of 0.5Hz over 10 seconds. **Primary Response** is the minimum value of response between 10s and 30s after the frequency ramp starts, **Secondary Response** between 30s and 30 minutes, and **High Frequency Response** is the minimum value after 10s on an indefinite basis.
5. For plants which have not yet **Synchronised**, the data values of MLP1 to MLP6 should be as described above. For plants which have already **Synchronised**, the values of MLP1 to MLP6 can take any value between **Designed Operating Minimum Level** or **Minimum Regulating Level** and **Registered Capacity** or **Maximum Capacity**. If MLP1 is not provided at the **Designed Minimum Operating Level**, the value of the **Designed Minimum Operating Level** should be separately stated.
6. For the avoidance of doubt **Transmission DC Converters** and **OTSDUW DC Converters** must be capable of providing a continuous signal indicating the real time frequency measured at the **Transmission Interface Point** to the **Offshore Grid Entry Point** (as detailed in CC.6.3.7(e)(vii) and CC.6.3.7(e)(viii) or ECC.6.3..3.1.1(f) to enable **Offshore Power Generating Modules, Offshore Generating Units, Offshore Power Park Modules** and/or **Offshore DC Converters** to satisfy the frequency response requirements of CC.6.3.7 or ECC.6.3.7.
7. Alternative governor settings shall be supplied by **Generators, HVDC System Owners** and **DC Converter Owners** where operation is required as part of **System Restoration**- -Aas required in CC.6.3.5 or and ECC.6.3.5.2 and ECC.6.3.5.5(vii)

**SCHEDULE 5 - USERS SYSTEM DATA**  
**PAGE 1 OF 11**

The data in this Schedule 5 is required from **Users** who are connected to the **National Electricity Transmission System** via a **Connection Point** (or who are seeking such a connection). **Generators** undertaking **OTSDUW** should use **DRC** Schedule 18 although they should still supply data under Schedule 5 in relation to their **User's System** up to the **Offshore Grid Entry Point**.

**Table 5 (a)**

DATA DESCRIPTION	UNITS	DATA to RTL		DATA CATEGORY
		CUSC Contract	CUSC App. Form	
<p><b>USERS SYSTEM LAYOUT</b> (PC.A.2.2)</p> <p>A <b>Single Line Diagram</b> showing all or part of the <b>User's System</b> is required. This diagram shall include:-</p> <p>(a) all parts of the <b>User's System</b>, whether existing or proposed, operating at <b>Supergrid Voltage</b>, and in Scotland and <b>Offshore</b>, also all parts of the <b>User System</b> operating at 110kV and greater,</p> <p>(b) all parts of the <b>User's System</b> operating at a voltage of 50kV and greater, and in Scotland and <b>Offshore</b> greater than 30kV, or higher which can interconnect <b>Connection Points</b>, or split bus-bars at a single <b>Connection Point</b>,</p> <p>(c) all parts of the <b>User's System</b> between <b>Embedded Medium Power Stations</b> or <b>Large Power Stations</b> or <b>Offshore Transmission Systems</b> connected to the <b>User's Subtransmission System</b> and the relevant <b>Connection Point</b> or <b>Interface Point</b>,</p> <p>(d) all parts of the <b>User's System</b> at a <b>Transmission Site</b>.</p> <p>The <b>Single Line Diagram</b> may also include additional details of the <b>User's Subtransmission System</b>, and the transformers connecting the <b>User's Subtransmission System</b> to a lower voltage. With <b>The Company's</b> agreement, it may also include details of the <b>User's System</b> at a voltage below the voltage of the <b>Subtransmission System</b>.</p> <p>This <b>Single Line Diagram</b> shall depict the arrangement(s) of all of the existing and proposed load current carrying <b>Apparatus</b> relating to both existing and proposed <b>Connection Points</b>, showing electrical circuitry (i.e., overhead lines, underground cables, power transformers and similar equipment), operating voltages. In addition, for equipment operating at a <b>Supergrid Voltage</b>, and in Scotland and <b>Offshore</b> also at 110kV and greater, circuit breakers and phasing arrangements shall be shown.</p>		■	■	<b>SPD</b>

## SCHEDULE 5 - USERS SYSTEM DATA

PAGE 2 OF 11

**Table 5(b)**

DATA DESCRIPTION	UNITS	DATA EXCH		DATA CATEGORY
		CUSC Contract	CUSC App. Form	
<b>REACTIVE COMPENSATION (PC.A.2.4)</b>				
For independently switched reactive compensation equipment not owned by a <b>Relevant Transmission Licensee</b> connected to the <b>User's System</b> at 132kV and above, and also in Scotland and <b>Offshore</b> , connected at 33kV and above, other than power factor correction equipment associated with a customer's <b>Plant</b> or <b>Apparatus</b> :				
Type of equipment (e.g., fixed or variable)	Text	▪	▪	<b>SPD</b>
Capacitive rating; or	MVar	▪	▪	<b>SPD</b>
Inductive rating; or	MVar	▪	▪	<b>SPD</b>
Operating range	MVar	▪	▪	<b>SPD</b>
Details of automatic control logic to enable operating characteristics to be determined	text and/or diagrams	▪	▪	<b>SPD</b>
Point of connection to <b>User's System</b> (electrical location and system voltage)	Text	▪	▪	<b>SPD</b>
<b>SUBSTATION INFRASTRUCTURE (PC.A.2.2.6(b))</b>				
For the infrastructure associated with any <b>User's</b> equipment at a Substation owned by a <b>Relevant Transmission Licensee</b> or operated or managed by <b>The Company</b> :-				
Rated 3-phase rms short-circuit withstand current	kA	▪	▪	<b>SPD</b>
Rated 1-phase rms short-circuit withstand current	kA	▪	▪	<b>SPD</b>
Rated Duration of short-circuit withstand	s	▪	▪	<b>SPD</b>
Rated rms continuous current	A	▪	▪	<b>SPD</b>

**SCHEDULE 5 – USERS SYSTEM DATA**

PAGE 3 OF 11

**Table 5 (c)**

DATA DESCRIPTION		UNITS	DATA EXCH		DATA CATEGORY
			CUSC Contract	CUSC App. Form	
LUMPED SUSCEPTANCES (PC.A.2.3)					
Equivalent Lumped Susceptance required for all parts of the <b>User's Subtransmission System</b> which are not included in the <b>Single Line Diagram</b> .			■	■	
This should not include:			■	■	
(a)	independently switched reactive compensation equipment identified above.		■	■	
(b)	any susceptance of the <b>User's System</b> inherent in the <b>Demand (Reactive Power)</b> data provided in Schedule 1 ( <b>Generator Data</b> ) or Schedule 11 ( <b>Connection Point</b> data).		■	■	
Equivalent lumped shunt susceptance at nominal <b>Frequency</b> .		% on 100 MVA	■	■	<b>SPD</b>

**SCHEDULE 5 – USERS SYSTEM DATA**  
**PAGE 4 OF 11**

**USER'S SYSTEM DATA**

**Circuit Parameters** (PC.A.2.2.4) (■ CUSC Contract & ■ CUSC Application Form)

The data below is all Standard Planning Data. Details are to be given for all circuits shown on the Single Line Diagram  
 Table 5 (d)

Years Valid	Node 1	Node 2	Rated Voltage kV	Operating Voltage kV	Positive Phase Sequence % on 100 MVA			Zero Phase Sequence (self) % on 100 MVA			Positive Phase Sequence (mutual) % on 100 MVA		
					R	X	B	R	X	B	R	X	B

**Notes**

1. Data should be supplied for the current, and each of the seven succeeding Financial Years. This should be done by showing for which years the data is valid in the first column of the Table.

**SCHEDULE 5 – USERS SYSTEM DATA**  
PAGE 5 OF 11

**USERS SYSTEM DATA**

Transformer Data (PC.A.2.2.5) (■ CUSC Contract & ■ CUSC Application Form)

The data below is all **Standard Planning Data**, and details should be shown below of all transformers shown on the **Single Line Diagram**. Details of Winding Arrangement, Tap Changer and earthing details are only required for transformers connecting the **User's** higher voltage system with its **Primary Voltage System**.

**Table 5 (e)**

Years valid	Name of Node of Connection	Transformer	Rating MVA	Voltage Ratio		Positive Phase Sequence Reactance % on Rating			Positive Phase Sequence Resistance % on Rating			Zero Sequence Reactance % on Rating	Winding Arr	Tap Changer			Earthing Details (delete as app)*
				HV	LV	Max Tap	Min Tap	Nom Tap	Max Tap	Min Tap	Nom Tap			Range +% to -%	Step size %	Type (delete)	
																ON/OFF	Direct/Res/Rea
																ON/OFF	Direct/Res/Rea
																ON/OFF	Direct/Res/Rea
																ON/OFF	Direct/Res/Rea
																ON/OFF	Direct/Res/Rea

\*If Resistance or Ractance please give impedance value

**Notes**

1. Data should be supplied for the current, and each of the seven succeeding Financial Years. This should be done by showing for which years the data is valid in the first column of the Table
2. For a transformer with two secondary windings, the positive and zero phase sequence leakage impedances between the HV and LV1, HV and LV2, and LV1 and LV2 windings are required.

**SCHEDULE 5 –USERS SYSTEM DATA**  
**PAGE 6 OF 11**

**USER'S SYSTEM DATA**

Switchgear Data (PC.A.2.2.6(a)) (■ CUSC Contract & CUSC Application Form ■)

The data below is all **Standard Planning Data**, and should be provided for all switchgear (i.e., circuit breakers, load disconnectors and disconnectors) operating at a **Supergrid Voltage**, and also in Scotland and **Offshore**, operating at 132kV. In addition, data should be provided for all circuit breakers irrespective of voltage located at a **Connection Site** which is owned by a **Relevant Transmission Licensee** or operated or managed by **The Company**.

**Table 5(f)**

Years Valid	Connection Point	Switch No	Rated Voltage kV rms	Operating Voltage kV rms	Rated short-circuit breaking current		Rated short-circuit peak making current		Rated rms continuous current (A)	DC time constant at testing of asymmetrical breaking ability (s)
					3 phase kA rms	1 phase ka rms	3 phase kA rms	1 phase ka rms		

**Notes**

1. Rated Voltage should be as defined by IEC 694.
2. Data should be supplied for the current, and each of the seven succeeding Financial Years. This should be done by showing for which years the data is valid in the first column of the Table


**SCHEDULE 5 –USERS SYSTEM DATA**  
**PAGE 7 OF 11**

**Table 5(g)**

DATA DESCRIPTION	UNITS	DATA to RTL		DATA CATEGORY
		CUSC Contract	CUSC App. Form	
<b>PROTECTION SYSTEMS (PC.A.6.3)</b>				
The following information relates only to <b>Protection</b> equipment which can trip or inter-trip or close any <b>Connection Point</b> circuit breaker or any <b>Transmission</b> circuit breaker. The information need only be supplied once, in accordance with the timing requirements set out in PC.A.1.4 (b) and need not be supplied on a routine annual basis thereafter, although <b>The Company</b> should be notified if any of the information changes.				
(a) A full description, including estimated settings, for all relays and <b>Protection</b> systems installed or to be installed on the <b>User's System</b> ;		■		<b>DPD II</b>
(b) A full description of any auto-reclose facilities installed or to be installed on the <b>User's System</b> , including type and time delays;		■		<b>DPD II</b>
(c) A full description, including estimated settings, for all relays and <b>Protection</b> systems installed or to be installed on the <b>Power Generating Module, Power Park Module</b> or <b>Generating Unit's</b> generator transformer, unit transformer, station transformer and their associated connections;		■		<b>DPD II</b>
(d) For <b>Generating Units</b> (other than <b>Power Park Units</b> ) having a circuit breaker at the generator terminal voltage clearance times for electrical faults within the <b>Generating Unit</b> zone must be declared.		■		<b>DPD II</b>
(e) Fault Clearance Times: Most probable fault clearance time for electrical faults on any part of the <b>Users System</b> directly connected to the <b>National Electricity Transmission System</b> .	msSec	■		<b>DPD II</b>
(f) <u>Alternative Protection data as submitted under (a) to (e) above settings in respect of necessary for System Restoration</u>		■		<u><b>DPD II</b></u>

DATA DESCRIPTION	UNITS	DATA to RTL		DATA CATEGORY
		CUSC Contract	CUSC App. Form	
<b>POWER PARK MODULE/UNIT PROTECTION SYSTEMS</b>				
Details of settings for the <b>Power Park Module/Unit</b> protection relays (to include): (PC.A.5.4.2(f))				
(a) Under frequency,		■		<b>DPD II</b>
(b) Over Frequency,		■		<b>DPD II</b>
(c) Under Voltage, Over Voltage,		■		<b>DPD II</b>
(d) Rotor Over current,		■		<b>DPD II</b>
(e) Stator Over current,		■		<b>DPD II</b>

(f)	High Wind Speed Shut Down Level,		▪		<b>DPD II</b>
(g)	Rotor Underspeed,		▪		<b>DPD II</b>
(h)	Rotor Overspeed.		▪		<b>DPD II</b>



## SCHEDULE 5 - USERS SYSTEM DATA

PAGE 8 OF 11

### Information for Transient Overvoltage Assessment (DPD I) (PC.A.6.2 ■ CUSC Contract)

The information listed below may be requested by **The Company** from each **User** with respect to any **Connection Site** between that **User** and the **National Electricity Transmission System**. The impact of any third party **Embedded** within the **Users System** should be reflected.

- (a) Busbar layout plan(s), including dimensions and geometry showing positioning of any current and voltage transformers, through bushings, support insulators, disconnectors, circuit breakers, surge arresters, etc. Electrical parameters of any associated current and voltage transformers, stray capacitances of wall bushings and support insulators, and grading capacitances of circuit breakers;
- (b) Electrical parameters and physical construction details of lines and cables connected at that busbar. Electrical parameters of all plant e.g., transformers (including neutral earthing impedance or zig-zag transformers if any), series reactors and shunt compensation equipment connected at that busbar (or to the tertiary of a transformer) or by lines or cables to that busbar;
- (c) Basic insulation levels (BIL) of all **Apparatus** connected directly, by lines or by cables to the busbar;
- (d) Characteristics of overvoltage **Protection** devices at the busbar and at the termination points of all lines, and all cables connected to the busbar;
- (e) Fault levels at the lower voltage terminals of each transformer connected directly or indirectly to the **National Electricity Transmission System** without intermediate transformation;
- (f) The following data is required on all transformers operating at **Supergrid Voltage** throughout **Great Britain** and, in Scotland and **Offshore**, also at greater than 110kV: three or five limb cores or single phase units to be specified, and operating peak flux density at nominal voltage.
- (g) An indication of which items of equipment may be out of service simultaneously during **Planned Outage** conditions.

### Harmonic Studies (DPD I) (PC.A.6.4 ■ CUSC Contract)

The information given below, both current and forecast, where not already supplied in this Schedule 5 may be requested by **The Company** from each **User** if it is necessary for **The Company** to evaluate the production/magnification of harmonic distortion on the **National Electricity Transmission System** and **User's** systems. The impact of any third party **Embedded** within the **User's System** should be reflected:

- (a) Overhead lines and underground cable circuits of the **User's Subtransmission System** must be differentiated and the following data provided separately for each type:
  - Positive phase sequence resistance
  - Positive phase sequence reactance
  - Positive phase sequence susceptance
- (b) for all transformers connecting the **User's Subtransmission System** to a lower voltage:
  - Rated MVA
  - Voltage Ratio
  - Positive phase sequence resistance
  - Positive phase sequence reactance

**SCHEDULE 5 – USERS SYSTEM DATA**  
**PAGE 9 OF 11**

- (c) at the lower voltage points of those connecting transformers:
- Equivalent positive phase sequence susceptance
  - Connection voltage and MVA<sub>r</sub> rating of any capacitor bank and component design parameters if configured as a filter
  - Equivalent positive phase sequence interconnection impedance with other lower voltage points
  - The minimum and maximum **Demand** (both MW and MVA<sub>r</sub>) that could occur
  - Harmonic current injection sources in Amps at the Connection voltage points
  - Details of traction loads, e.g., connection phase pairs, continuous variation with time, etc.
- (d) an indication of which items of equipment may be out of service simultaneously during **Planned Outage** conditions

Voltage Assessment Studies (DPD I) (PC.A.6.5 ■ CUSC Contract)

The information listed below, where not already supplied in this Schedule 5, may be requested by **The Company** from each **User** with respect to any **Connection Site** if it is necessary for **The Company** to undertake detailed voltage assessment studies (e.g., to examine potential voltage instability, voltage control co-ordination or to calculate voltage step changes). The impact of any third party **Embedded** within the **Users System** should be reflected:

- (a) For all circuits of the **User's Subtransmission System**:
- Positive Phase Sequence Reactance
  - Positive Phase Sequence Resistance
  - Positive Phase Sequence Susceptance
  - MVA<sub>r</sub> rating of any reactive compensation equipment
- (b) for all transformers connecting the **User's Subtransmission System** to a lower voltage:
- Rated MVA
  - Voltage Ratio
  - Positive phase sequence resistance
  - Positive Phase sequence reactance
  - Tap-changer range
  - Number of tap steps
  - Tap-changer type: on-load or off-circuit
  - AVC/tap-changer time delay to first tap movement
  - AVC/tap-changer inter-tap time delay

## SCHEDULE 5 – USERS SYSTEM DATA

PAGE 10 OF 11

- (c) at the lower voltage points of those connecting transformers:-
- Equivalent positive phase sequence susceptance
  - MVA rating of any reactive compensation equipment
  - Equivalent positive phase sequence interconnection impedance with other lower voltage points
  - The maximum **Demand** (both MW and MVA) that could occur
  - Estimate of voltage insensitive (constant power) load content in % of total load at both winter peak and 75% off-peak load conditions

### Short Circuit Analyses:(DPD I) (PC.A.6.6 ■ CUSC Contract)

The information listed below, both current and forecast, and where not already supplied under this Schedule 5, may be requested by **The Company** from each **User** with respect to any **Connection Site** where prospective short-circuit currents on equipment owned by a **Relevant Transmission Licensee** or operated or managed by **The Company** are close to the equipment rating. The impact of any third party **Embedded** within the **User's System** should be reflected:-

- (a) For all circuits of the **User's Subtransmission System**:
- Positive phase sequence resistance
  - Positive phase sequence reactance
  - Positive phase sequence susceptance
  - Zero phase sequence resistance (both self and mutuals)
  - Zero phase sequence reactance (both self and mutuals)
  - Zero phase sequence susceptance (both self and mutuals)
- (b) for all transformers connecting the **User's Subtransmission System** to a lower voltage:
- Rated MVA
  - Voltage Ratio
  - Positive phase sequence resistance (at max, min and nominal tap)
  - Positive phase sequence reactance (at max, min and nominal tap)
  - Zero phase sequence reactance (at nominal tap)
  - Tap changer range
  - Earthing method: direct, resistance or reactance
  - Impedance if not directly earthed
- (c) at the lower voltage points of those connecting transformers:-
- The maximum **Demand** (in MW and MVA) that could occur
  - Short-circuit infeed data in accordance with PC.A.2.5.6(a) unless the **User's** lower voltage network runs in parallel with the **Subtransmission System**, when to prevent double counting in each node infeed data, a  $\pi$  equivalent comprising the data items of PC.A.2.5.6(a) for each node together with the positive phase sequence interconnection impedance between the nodes shall be submitted.

## SCHEDULE 5 – USERS SYSTEM DATA

PAGE 11 OF 11

Dynamic Models:(DPD II) (PC.A.6.7 ■ CUSC Contract)

The information listed below, both current and forecast, and where not already supplied under this Schedule 5, may be requested by **The Company** from each **EU Code User** or in respect of each **EU Grid Supply Point** with respect to any **Connection Site**

- (a) Dynamic model structure and block diagrams including parameters, transfer functions and individual elements (as applicable)
- (b) Power control functions and block diagrams including parameters, transfer functions and individual elements (as applicable)
- (c) Voltage control functions and block diagrams including parameters, transfer functions and individual elements (as applicable)
- (d) Converter control models and block diagrams including parameters, transfer functions and individual elements (as applicable)

**SCHEDULE 6 – USERS OUTAGE INFORMATION**

PAGE 1 OF 32

DATA DESCRIPTION	UNITS	DATA to RTL	TIMESCALE COVERED	UPDATE TIME	DATA CAT.
<p>Details are required from <b>Network Operators</b> of proposed outages in their <b>User Systems</b> and from <b>Generators</b> with respect to their outages, which may affect the performance of the <b>Total System</b> (e.g., at a <b>Connection Point</b> or constraining <b>Embedded Large Power Stations</b> or constraints to the <b>Maximum Import Capacity</b> or <b>Maximum Export Capacity</b> at an <b>Interface Point</b>) (OC2.4.1.3.2(a) &amp; (b)). <u>Outages of Plant and Apparatus of Restoration Contractors and key Plant and Apparatus of a Network Operator's System associated with a Distribution Restoration Zone Plan also need to be co-ordinated with outages on the National Electricity Transmission System. This would include data from Network Operators, Users and Restoration Contractors Service Providers which would impact the ability to operate a Local Joint Restoration Plan or Distribution Restoration Zone Plan.</u></p>		<ul style="list-style-type: none"> <li>■ CUSC Contract</li> </ul>	Years 2-5	Week 8 <b>(Network Operator etc)</b>	<b>OC2</b>
				Week 13 <b>(Generators)</b>	<b>OC2</b> <u>PC.A.5.7.2</u>
<p><b>(The Company</b> advises <b>Network Operators</b> of <b>National Electricity Transmission System</b> outages affecting their <b>Systems</b>)</p>			Years 2-5	Week 28)	
<p><b>Network Operator</b> informs <b>The Company</b> if unhappy with proposed outages)</p>		■	"	Week 30	<b>OC2</b>
<p><b>(The Company</b> draws up revised <b>National Electricity Transmission System</b> (outage plan advises <b>Users</b> of operational effects)</p>			"	Week 34)	
<p><b>Generators</b> and <b>Non-Embedded Customers</b> provide Details of <b>Apparatus</b> owned by them (other than <b>Gensets</b>) at each <b>Grid Supply Point</b> (OC2.4.1.3.3)</p>		■	Year 1	Week 13	<b>OC2</b>
<p><b>(The Company</b> advises <b>Network Operators</b> of outages affecting their <b>Systems</b>) (OC2.4.1.3.3)</p>			Year 1	Week 28)	
<p><b>Network Operator</b> details of relevant outages affecting the <b>Total System</b> (OC2.4.1.3.3)</p>		■	Year 1	Week 32	<b>OC2</b>
<p>Details of:-  <b>Maximum Import Capacity</b> for each <b>Interface Point</b>  <b>Maximum Export Capacity</b> for each <b>Interface Point</b>                      Changes to previously declared values of the <b>Interface Point Target Voltage/Power Factor</b> (OC2.4.1.3.3(c)).</p>	MVA / MW MVA / MW V (unless power factor control		Year 1	Week 32	<b>OC2</b>
<p><b>(The Company</b> informs <b>Users</b> of aspects that may affect their <b>Systems</b>) (OC2.4.1.3.3)</p>			Year 1	Week 34)	
<p><b>Users</b> inform <b>The Company</b> if unhappy with aspects as notified (OC2.4.1.3.3)</p>		■	Year 1	Week 36	<b>OC2</b>
<p><b>(The Company</b> issues final <b>National Electricity Transmission System</b> (outage plan with advice of operational) (OC2.4.1.3.3) (effects on <b>Users System</b>)</p>		■	Year 1	Week 49	<b>OC2</b>
<p><b>Generator, Network Operator</b> and <b>Non-Embedded Customers</b> to inform <b>The Company</b> of changes to outages previously requested</p>			Week 8 ahead to year end	As occurring	<b>OC2</b>
<p>Details of load transfer capability of 12MW or more between <b>Grid Supply Points</b> in England and Wales and 10MW or more between <b>Grid Supply Points</b> in Scotland.</p>			Within Yr 0	As <b>The Company</b> request	<b>OC2</b>

DATA DESCRIPTION	UNITS	DATA to RTL	TIMESCALE COVERED	UPDATE TIME	DATA CAT. OC2
Details of:- <b>Maximum Import Capacity</b> for each <b>Interface Point</b> <b>Maximum Export Capacity</b> for each <b>Interface Point</b> Changes to previously declared values of the <b>Interface Point Target Voltage/Power Factor</b>	MVA / MW MVA / MW V (unless power factor control)		Within Yr 0	As occurring	

**Note:** Users should refer to **OC2** for full details of the procedure summarised above and for the information which **The Company** will provide on the **Programming Phase**.

## SCHEDULE 6 – USERS OUTAGE INFORMATION


PAGE 2 OF 32

The data below is to be provided to **The Company** as required for compliance with the applicable **Retained EU Law** (Commission Regulation (EU) No 543/2013 (OC2.4.2.3)). Data provided under Article Numbers 7.1(a), 7.1(b), 15.1(a), 15.1(b), and 15.1(c) and 15.1(d) is to be provided using **MODIS**.

ECR ARTICLE No.	DATA DESCRIPTION	USERS PROVIDING DATA	FREQUENCY OF SUBMISSION
7.1(a)	Planned unavailability of the <b>Apparatus</b> belonging to a <b>Non-Embedded Customer</b> where OC2.4.7 (a) applies  - Unavailable demand capacity during the event (MW) - Estimated start date and time (dd.mm.yy hh:mm) - Estimated end date and time (dd.mm.yy hh:mm) - Reason for unavailability from the list below: . Maintenance . Failure . Shutdown . Other	<b>Non-Embedded Customer</b>	To be received by <b>The Company</b> as soon as reasonably possible but in any case, to facilitate publication of data no later than 1 hour after a <b>decision has been made by the Non-Embedded Customer</b> regarding the planned unavailability
7.1(b)	Changes in actual availability of the <b>Apparatus</b> belonging to a <b>Non-Embedded Customer</b> where OC2.4.7 (b) applies  - Unavailable demand capacity during the event (MW) - Start date and time (dd.mm.yy hh:mm) - Estimated end date and time (dd.mm.yy hh:mm) - Reason for unavailability from the list below : . Maintenance . Failure . Shutdown . Other	<b>Non-Embedded Customer</b>	To be received by <b>The Company</b> as soon as reasonably possible but in any case, to facilitate publication of data no later than 1 hour after the change in actual availability
8.1	Year Ahead Forecast Margin information as provided in accordance with OC2.4.1.2.2  - <b>Output Usable</b>	<b>Generator</b>	In accordance with OC2.4.1.2.2
14.1(a)	<b>Registered Capacity</b> or <b>Maximum Capacity</b> for <b>Generating Units</b> or <b>Power Generating Modules</b> with greater than 1 MW <b>Registered Capacity</b> or <b>Maximum Capacity</b> provided in accordance with PC.4.3.1 and PC.A.3.4.3 or PC.A.3.1.4  - <b>Registered Capacity</b> or <b>Maximum Capacity</b> (MW) - Production type (from that listed under PC.A.3.4.3)	<b>Generator</b>	Week 24
14.1(b)	<b>Power Station Registered Capacity</b> for units with equal or greater than 100 MW <b>Registered Capacity</b> provided in accordance with PC.4.3.1 and PC.A.3.4.3  - <b>Power Station</b> name - Location of <b>Generating Unit</b> - Production type (from that listed under PC.A.3.4.3) - Voltage connection levels - <b>Registered Capacity</b> or <b>Maximum Capacity</b> (MW)	<b>Generator</b>	Week 24

14.1(c)	<p>Estimated output of <b>Active Power</b> of a <b>BM Unit</b> or <b>Generating Unit</b> for each per <b>Settlement Period</b> of the next <b>Operational Day</b> provided in accordance with BC1.4.2</p> <p>- <b>Physical Notification</b></p>	Generator	In accordance with BC1.4.2
15.1(a)	<p>Planned unavailability of a <b>Generating Unit</b> where OC2.4.7(c) applies</p> <p>- <b>Power Station</b> name  - <b>Generating Unit</b> and/or <b>Power Generating Module</b> name  - Location of <b>Generating Unit</b> and/or <b>Power Generating Module</b>  - <b>Generating Unit Registered Capacity</b> (MW)  - Production type (from that listed under PC.A.3.4.3)  - <b>Output Usable</b> (MW) during the event  - Start date and time (dd.mm.yy hh:mm)  - Estimated end date and time (dd.mm.yy hh:mm)  - Reason for unavailability from the list below:  . Maintenance  . Shutdown  . Other</p>	Generator	To be received by <b>The Company</b> as soon as reasonably possible but in any case, to facilitate publication of data no later than 1 hour after a decision has been made by the <b>Generator</b> regarding the planned unavailability
15.1(b)	<p>Changes in availability of a <b>Generating Unit</b> and/or <b>Power Generating Module</b> where OC2.4.7 (d) applies</p> <p>- <b>Power Station</b> name  - <b>Generating Unit</b> and/or <b>Power Generating Module</b> name  - Location of <b>Generating Unit</b> and/or <b>Power Generating Module</b>  - <b>Generating Unit Registered Capacity</b> and <b>Power Generating Module Maximum Capacity</b> (MW)  - Production type (from that listed under PC.A.3.4.3)  - Maximum Export Limit (MW) during the event  - Start date and time (dd.mm.yy hh:mm)  - Estimated end date and time (dd.mm.yy hh:mm)  - Reason for unavailability from the list below:  . Maintenance  . Shutdown  . Other</p>	Generator	To be received by <b>The Company</b> as soon as reasonably possible but in any case, to facilitate publication of data no later than 1 hour after the change in actual availability
15.1(c)	<p>Planned unavailability of a <b>Power Station</b> where OC2.4.7(e) applies</p> <p>- <b>Power Station</b> name  - Location of <b>Power Station</b>  - <b>Power Station Registered Capacity</b> (MW)  - Production type (from that listed under PC.A.3.4.3)  - <b>Power Station aggregated Output Usable</b> (MW) during the event  - Start date and time (dd.mm.yy hh:mm)  - Estimated end date and time (dd.mm.yy hh:mm)  - Reason for unavailability from the list below:  . Maintenance  . Shutdown  . Other</p>	Generator	To be received by <b>The Company</b> as soon as reasonably possible but in any case, to facilitate publication of data no later than 1 hour after a decision has been made by the <b>Generator</b> regarding the planned unavailability
15.1(d)	<p>Changes in actual availability of a <b>Power Station</b> where OC2.4.7 (f) applies</p> <p>- <b>Power Station</b> name  - Location of <b>Power Station</b>  - <b>Power Station Registered Capacity</b> (MW)  - Production type (from that listed under PC.A.3.4.3)  - <b>Power Station aggregated Maximum Export Limit</b> (MW) during the event  - Start date and time (dd.mm.yy hh:mm)  - Estimated end date and time (dd.mm.yy hh:mm)  - Reason for unavailability from the list below:  . Maintenance  . Shutdown  . Other</p>	Generator	To be received by <b>The Company</b> as soon as reasonably possible but in any case, to facilitate publication of data no later than 1 hour after the change in actual availability

<p><u>15.1(e)</u></p>	<p><u>Outage data from a Network Operator relating to an outage on the Network Operator's System or an outage of a Restoration Contractor's Plant and Apparatus (not already supplied) which would prevent the operation of a Restoration Plan. Any outage data from a Network Operator or Restoration Service Provider (not already supplied) which would prevent the operation of a Restoration Plan. Outages of Plant and Apparatus of Restoration Contractors and key associated with a Distribution Restoration Zone Plan also need to be co-ordinated with outages on the National Electricity Transmission System</u></p>	<p><u>Network Operators and Restoration Service Contractors Providers</u></p>	<p><u>In accordance with the requirements of OC2</u></p>
-----------------------	--	---	--





**SCHEDULE 8 - DATA SUPPLIED BY BM PARTICIPANTS**  
**PAGE 1 OF 1**

CODE	DESCRIPTION
BC1	<b>Physical Notifications</b>
BC1 & BC2	<b>Export and Import Limits</b>
BC1	<b>Bid-Offer Data</b>
BC1	<b>Dynamic Parameters</b> (Day Ahead)
BC2	<b>Dynamic Parameters</b> (For use in <b>Balancing Mechanism</b> )
BC1 & BC2	<b>Other Relevant Data</b>

- No information collated under this Schedule will be transferred to the **Relevant Transmission Licensees**

## SCHEDULE 9 - DATA SUPPLIED BY THE COMPANY TO USERS

PAGE 1 OF 1

(Example of data to be supplied)

CODE	DESCRIPTION
CC or ECC	Operation Diagram
CC or ECC	Site Responsibility Schedules
PC	Day of the peak <b>National Electricity Transmission System Demand</b>  Day of the minimum <b>National Electricity Transmission System Demand</b>
<u>OC1.7</u>	<u>From 31 December 2026 and during normal system operation, The Company shall publish on a daily basis, 60% and 100% of the peak National Demand, under pre System shutdown conditions for the following day, based on the latest forecast that would feed into the System Restoration Regional targets by means of messages inputted by The Company to the Balancing Mechanism Reporting Service (BMRS).</u>  <u>From 31 December 2026 and during System Restoration, The Company shall publish for each System Restoration Region, the Demand that is used to calculate the National Demand on an hourly basis on a reasonable endeavours basis by means of messages inputted by The Company to the Balancing Mechanism Reporting Service (BMRS).</u>
OC2	<b>Surpluses and Output Useable (OU)</b> requirements for each <b>Generator</b> over varying timescales  Equivalent networks to <b>Users</b> for <b>Outage Planning</b>  <b>Negative Reserve Active Power Margins</b> (when necessary)  <b>Operating Reserve</b> information
BC1	<b>Demand Estimates, Indicated Margin and Indicated Imbalance</b> , indicative <b>Synchronising and Desynchronising</b> times of <b>Embedded Power Stations</b> to <b>Network Operators</b> , special actions.
BC2	<b>Bid-Offer Acceptances, Ancillary Services</b> instructions to relevant <b>Users</b> , <b>Emergency Instructions</b>
BC3	Location, amount, and <b>Low Frequency Relay</b> settings of any <b>Low Frequency Relay</b> initiated <b>Demand</b> reduction for <b>Demand</b> which is <b>Embedded</b> .

- No information collated under this Schedule will be transferred to the **Relevant Transmission Licensees**

- In respect of OC1, the data would also be supplied to **Restoration Contractors Service Providers**

### DATA TO BE SUPPLIED BY THE COMPANY TO USERS

#### PURSUANT TO THE TRANSMISSION LICENCE

1. The **Transmission Licence** requires **The Company** to publish annually the **Seven Year Statement** which is designed to provide **Users** and potential **Users** with information to enable them to identify opportunities for continued and further use of the **National Electricity**

### **Transmission System.**

When a **User** is considering a development at a specific site, certain additional information may be required in relation to that site which is of such a level of detail that it is inappropriate to include it in the **Seven Year Statement**. In these circumstances, the **User** may contact **The Company** who will be pleased to arrange a discussion and the provision of such additional information relevant to the site under consideration as the **User** may reasonably require.

2. The **Transmission Licence** also requires **The Company** to offer terms for an agreement for connection to and use of the **National Electricity Transmission System** and further information will be given by **The Company** to the potential **User** in the course of the discussions of the terms of such an agreement.





**SCHEDULE 11 - CONNECTION POINT DATA**

**PAGE 1 OF 5**

The following information is required from each **Network Operator** and from each **Non-Embedded Customer**. The data should be provided in calendar week 24 each year (although **Network Operators** may delay the submission until calendar week 28).

**Table 11(a)**

**Connection Point:**

<b>Connection Point Demand</b> at the time of - (select each one in turn) (Provide data for each Access Period associated with the Connection Point)	a) maximum <b>Demand</b> b) peak <b>National Electricity Transmission System Demand</b> (specified by <b>The Company</b> ) c) minimum <b>National Electricity Transmission System Demand</b> (specified by <b>The Company</b> ) d) maximum <b>Demand</b> during <b>Access Period</b> e) specified by either <b>The Company</b> or a <b>User</b>
Name of <b>Transmission Interface Circuit</b> out of service during <b>Access Period</b> (if reqd).	<b>PC.A.4.1.4.2</b>

DATA DESCRIPTION (CUSC Contract □ & CUSC Application Form ■)	Outturn	Outturn Weather Corrected	F.Yr 1	F.Yr 2	F.Yr 3	F.Yr 4	F.Yr 5	F.Yr 6	F.Yr 7	F.Yr 8	DATA CAT
Date of a), b), c), d) or e) as denoted above.											<b>PC.A.4.3.3</b>
Time of a), b), c), d) or e) as denoted above.											<b>PC.A.4.3.3</b>
<b>Connection Point Demand</b> (MW)											<b>PC.A.4.3.1</b>
<b>Connection Point Demand</b> (MVar)											<b>PC.A.4.3.1</b>
Deduction made at <b>Connection Point</b> for <b>Small Power Stations, Medium Power Stations and Customer Generating Plant</b> (MW)											<b>PC.A.4.3.2(a)</b>
Reference to valid <b>Single Line Diagram</b>											<b>PC.A.4.3.5</b>
Reference to node and branch data.											<b>PC.A.2.2</b>

Note: The following data block can be repeated for each post fault network revision that may impact on the Transmission System.

Reference to post-fault revision of <b>Single Line Diagram</b>											<b>PC.A.4.5</b>
Reference to post-fault revision of the node and branch data associated with the <b>Single Line Diagram</b>											<b>PC.A.4.5</b>
Reference to the description of the actions and timescales involved in effecting the post-fault actions (e.g. auto-switching, manual, teleswitching, overload protection operation etc)											<b>PC.A.4.5</b>

**Access Group:**

Note: The following data block to be repeated for each **Connection Point** with the **Access Group**.

Name of associated <b>Connection Point</b> within the same <b>Access Group</b> :											<b>PC.A.4.3.1</b>
<b>Demand</b> at associated <b>Connection Point</b> (MW)											<b>PC.A.4.3.1</b>
<b>Demand</b> at associated <b>Connection Point</b> (MVar)											<b>PC.A.4.3.1</b>
Deduction made at associated <b>Connection Point</b> for <b>Small Power Stations, Medium Power Stations and Customer Generating Plant</b> (MW)											<b>PC.A.4.3.2(a)</b>

**SCHEDULE 11 - CONNECTION POINT DATA**  
PAGE 2 OF 5

**Table 11(b)**

Embedded Generation Data											
Connection Point:											
DATA DESCRIPTION	O u t t u r n	O u t t u r n	F Y r	F.Yr	F.Yr.	F.Yr.	F.Yr.	F.Yr	F.Yr	F.Yr	DATA CAT
				Weather Corrected	1	2	3	4	5	6	
<b>Small Power Station, Medium Power Station and Customer Generation Summary</b>	For each <b>Connection Point</b> where there are <b>Embedded Small Power Stations, Medium Power Stations</b> or <b>Customer Generating Stations</b> the following information is required:										
No. of <b>Small Power Stations, Medium Power Stations</b> or <b>Customer Power Stations</b>											<b>PC.A.3.1.4(a)</b>
Number of <b>Generating Units</b> within these stations											<b>PC.A.3.1.4(a)</b>
Summated Capacity of all these <b>Generating Units</b>											<b>PC.A.3.1.4(a)</b>
Where the <b>Network Operator's System</b> places a constraint on the capacity of an <b>Embedded Large Power Station</b>											
<b>Station Name</b>											<b>PC.A.3.2.2(c)</b>
<b>Generating Unit</b>											<b>PC.A.3.2.2(c)</b>
<b>System Constrained Capacity</b>											<b>PC.A.3.2.2(c)(i)</b>
<b>Reactive Despatch Network Restriction</b>											<b>PC.A.3.2.2(c)(ii)</b>

Where the <b>Network Operator's System</b> places a constraint on the capacity of an <b>Offshore Transmission System</b> at an <b>Interface Point</b>											
<b>Offshore Transmission System Name</b>											<b>PC.A.3.2.2(c)</b>
<b>Interface Point Name</b>											<b>PC.A.3.2.2(c)</b>
<b>Maximum Export Capacity</b>											<b>PC.A.3.2.2(c)</b>
<b>Maximum Import Capacity</b>											<b>PC.A.3.2.2(c)</b>



**SCHEDULE 11 - CONNECTION POINT DATA**  
**PAGE 4 OF 5**

**NOTES:**

1. 'F.Yr.' means **Financial Year**. F.Yr. 1 refers to the current financial year.
2. All **Demand** data should be net of the output (as reasonably considered appropriate by the **User**) of all **Embedded Small Power Stations, Embedded Medium Power Stations** and **Customer Generating Plant**. Generation and / or Auxiliary demand of **Embedded Large Power Stations** should not be included in the demand data submitted by the **User**. **Users** should refer to the **PC** for a full definition of the **Demand** to be included.
3. Peak **Demand** should relate to each **Connection Point** individually and should give the maximum demand that in the **User's** opinion could reasonably be imposed on the **National Electricity Transmission System**. **Users** may submit the **Demand** data at each node on the **Single Line Diagram** instead of at a **Connection Point** as long as the **User** reasonably believes such data relates to the peak (or minimum) at the **Connection Point**.

In deriving **Demand** any deduction made by the **User** (as detailed in note 2 above) to allow for **Embedded Small Power Stations, Embedded Medium Power Stations** and **Customer Generating Plant** is to be specifically stated as indicated on the Schedule.

4. **The Company** may at its discretion require details of any **Embedded Small Power Stations** or **Embedded Medium Power Stations** whose output can be expected to vary in a random manner (e.g. wind power) or according to some other pattern (e.g. tidal power)
5. Where more than 95% of the total **Demand** at a **Connection Point** is taken by synchronous motors, values of the **Power Factor** at maximum and minimum continuous excitation may be given instead. **Power Factor** data should allow for series reactive losses on the **User's System** but exclude reactive compensation network susceptance specified separately in Schedule 5.
1. Where a **Reactive Despatch Network Restriction** is in place which requires the generator to maintain a target voltage set point this should be stated as an alternative to the size of the **Reactive Despatch Network Restriction**.

**SCHEDULE 11 - CONNECTION POINT DATA**  
PAGE 5 OF 5

**Table 11 (d)**

**Embedded Small Power Stations <1MW**

<b>Network Operator</b>	
-------------------------	--

<b>Fuel Type</b>	<b>Aggregate Registered Capacity Total MW</b>	<b>Number of PGMs</b>	<b>Comments</b>
Biomass			
Fossil brown coal/lignite			
Fossil coal-derived gas			
Fossil gas			
Fossil hard coal			
Fossil oil			
Fossil oil shale			
Fossil peat			
Geothermal			
Hydro pumped storage			
Hydro run-of-river and poundage			
Hydro water reservoir			
Marine			
Nuclear			
Other renewable			
Solar			
Waste			
Wind offshore			
Wind onshore			
<u>Other</u>			

**SCHEDULE 12 - DEMAND CONTROL**  
**PAGE 1 OF 2**

The following information is required from each **Network Operator** and where indicated with an asterisk from **Externally Interconnected System Operators** and/or **Interconnector Users** and a **Pumped Storage Generator** and **Generators** in respect of **Electricity Storage Modules**. Where indicated with a double asterisk, the information is only required from **Suppliers**.

DATA DESCRIPTION	UNITS		UPDATE TIME	
<b><u>Demand Control</u></b>				
<b>Demand</b> met or to be relieved by <b>Demand Control</b> (averaging at the <b>Demand Control Notification Level</b> or more over a half hour) at each <b>Connection Point</b> .				
<b>Demand Control</b> at time of <b>National Electricity Transmission System</b> weekly peak demand				
Amount	MW	)F.yrs 0 to 5	Week 24	<b>OC1</b>
Duration	Min	)		
For each half hour	MW	Wks 2-8 ahead	1000 Mon	<b>OC1</b>
For each half hour	MW	Days 2-12 ahead	1200 Wed	<b>OC1</b>
For each half hour	MW	Previous calendar day	0600 daily	<b>OC1</b>
<b>**Customer Demand Management</b> (at the <b>Customer Demand Management Notification Level</b> or more at the <b>Connection Point</b> )				
For each half hour	MW	Any time in Control Phase		<b>OC1</b>
For each half hour	MW	Remainder of period	When changes occur to previous plan	<b>OC1</b>
For each half hour	MW	Previous calendar day	0600 daily	<b>OC1</b>
<b>**In Scotland, Load Management Blocks</b> For each block of 5MW or more, for each half hour	MW	For the next day	11:00	<b>OC1</b>

**SCHEDULE 12 - DEMAND CONTROL**  
PAGE 2 OF 2

DATA DESCRIPTION	UNITS	TIME COVERED	UPDATE TIME	DATA CAT.
<b>*Demand Control or Pump Tripping Offered as Reserve</b>				
Magnitude of <b>Demand</b> or pumping load or <b>Electricity Storage</b> charging load which is tripped	MW	Year ahead from week 24	Week 24	<b>DPD I</b>
<b>System Frequency</b> at which tripping is initiated	Hz	"	"	"
Time duration of <b>System Frequency</b> below trip setting for tripping to be initiated	S	"	"	"
Time delay from trip initiation to Tripping	S	"	"	"
<b>Electricity Storage Module data</b>				
<b>Maximum Capacity</b>	MW	"	"	"
<b>Maximum Import Power</b>	MW	"	"	"
<b>Registered Import Capability</b>	MW	"	"	"
Charge Time	Min	"	"	"
Discharge time	Min	"	"	"
Operating periods	Min	"	"	"
<b>Emergency Manual Load Disconnection</b>				
Method of achieving load disconnection	Text	Year ahead from week 24	Annual in week 24	OC6
<b>Annual ACS Peak Demand (Active Power) at Connection Point</b> (requested under Schedule 11 - repeated here for reference)	MW	"	"	"
Cumulative percentage of <b>Connection Point Demand (Active Power)</b> which can be disconnected by the following times from an instruction from <b>The Company</b>				
5 mins	%	"	"	"
10 mins	%	"	"	"
15 mins	%	"	"	"
20 mins	%	"	"	"
25 mins	%	"	"	"
30 mins	%	"	"	"

--	--	--	--	--	--

Notes:

1. **Network Operators** may delay the submission until calendar week 28.
2. No information collated under this Schedule will be transferred to the **Relevant Transmission Licensees** (or **Generators** undertaking **OTSDUW**).

**SCHEDULE 12A - AUTOMATIC LOW FREQUENCY DEMAND DISCONNECTION**  
**PAGE 1 OF 1**

Time Covered: Year ahead from week 24  
 Update Time: Annual in week 24

Data Category: OC6

Grid Supply Point	GSP Demand MW	Low Frequency Demand Disconnection Blocks MW									Residual demand MW
		1 48.8Hz	2 48.75Hz	3 48.7Hz	4 48.6Hz	5 48.5Hz	6 48.4Hz	7 48.2Hz	8 48.0Hz	9 47.8Hz	
GSP1											
GSP2											
GSP3											
Total demand disconnected per block MW %											
Total demand disconnection		MW ( % of aggregate demand of MW)									

Note: All demand refers to that at the time of forecast **National Electricity Transmission System** peak demand.

**Network Operators** may delay the submission until calendar week 28

No information collated under this schedule will be transferred to the **Relevant Transmission Licensees** (or **Generators** undertaking **OTSDUW**).

**SCHEDULE 13 - FAULT INFEEED DATA**

PAGE 1 OF 2

The data in this Schedule 13 is all **Standard Planning Data**, and is required from all **Users** other than **Generators** who are connected to the **National Electricity Transmission System** via a **Connection Point** (or who are seeking such a connection). A data submission is to be made each year in Week 24 (although **Network Operators** may delay the submission until Week 28). A separate submission is required for each node included in the **Single Line Diagram** provided in Schedule 5.

DATA DESCRIPTION	UNITS	F.Yr	F.Yr.	DATA to								
		0	1	2	3	4	5	6	7	RTL		
<b>SHORT CIRCUIT INFEEED TO THE NATIONAL ELECTRICITY TRANSMISSION SYSTEM FROM USERS SYSTEM AT A CONNECTION POINT</b>											CUSC Contract	CUSC App. Form
<i>(PC.A.2.5)</i>												
Name of node or Connection Point											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Symmetrical three phase short-circuit current infeed												
- at instant of fault	kA										<input type="checkbox"/>	<input checked="" type="checkbox"/>
- after subtransient fault current contribution has substantially decayed	Ka										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Zero sequence source impedances as seen from the Point of Connection or node on the Single Line Diagram (as appropriate) consistent with the maximum infeed above:												
- Resistance	% on 100										<input type="checkbox"/>	<input checked="" type="checkbox"/>
- Reactance	% on 100										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Positive sequence X/R ratio at instance of fault											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Pre-Fault voltage magnitude at which the maximum fault currents were calculated	p.u.										<input type="checkbox"/>	<input checked="" type="checkbox"/>

**SCHEDULE 13 - FAULT INFEEED DATA**  
**PAGE 2 OF 2**

DATA DESCRIPTION	UNITS	F.Yr 0	F.Yr. 1	F.Yr. 2	F.Yr. 3	F.Yr. 4	F.Yr. 5	F.Yr. 6	F.Yr. 7	DATA to RTL	
<b>SHORT CIRCUIT INFEEED TO THE NATIONAL ELECTRICITY TRANSMISSION SYSTEM FROM USERS SYSTEM AT A CONNECTION POINT</b>										CUSC Contract	CUSC App. Form
Negative sequence impedances of <b>User's System</b> as seen from the <b>Point of Connection</b> or node on the <b>Single Line Diagram</b> (as appropriate). If no data is given, it will be assumed that they are equal to the positive sequence values.											
- Resistance	% on 100									<input type="checkbox"/>	<input checked="" type="checkbox"/>
- Reactance	% on 100									<input type="checkbox"/>	<input checked="" type="checkbox"/>

**SCHEDULE 14 - FAULT INFEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**

The data in this Schedule 14 is all **Standard Planning Data**, and is to be provided by **Generators**, with respect to all directly connected **Power Stations**, all **Embedded Large Power Stations** and all **Embedded Medium Power Stations** connected to the **Subtransmission System**. A data submission is to be made each year in Week 24.

Fault infeeds via **Unit Transformers**

A submission should be made for each **Generating Unit** (including those which are part of a **Synchronous Power Generating Module**) with an associated **Unit Transformer**. Where there is more than one **Unit Transformer** associated with a **Generating Unit**, a value for the total infeed through all **Unit Transformers** should be provided. The infeed through the **Unit Transformer(s)** should include contributions from all motors normally connected to the **Unit Board**, together with any generation (e.g. **Auxiliary Gas Turbines**) which would normally be connected to the **Unit Board**, and should be expressed as a fault current at the **Generating Unit** terminals for a fault at that location.

DATA DESCRIPTION	UNITS	F.Yr.	DATA to									
		0	1	2	3	4	5	6	7	RTL		
(PC.A.2.5)										CUSC Contract	CUSC App. Form	
Name of <b>Power Station</b>											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Number of <b>Unit Transformers</b>											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Symmetrical three phase short-circuit current infeed through the <b>Unit Transformers(s)</b> for a fault at the <b>Generating Unit</b> terminals												
- at instant of fault	kA										<input type="checkbox"/>	<input checked="" type="checkbox"/>
- after subtransient fault current contribution has substantially decayed	kA										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Positive sequence X/R ratio at instance of fault											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Subtransient time constant (if significantly different from 40ms)	ms										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Pre-fault voltage at fault point (if different from 1.0 p.u.)											<input type="checkbox"/>	<input checked="" type="checkbox"/>
The following data items need only be supplied if the <b>Generating Unit</b> Step-up Transformer can supply zero sequence current from the <b>Generating Unit</b> side to the <b>National Electricity Transmission System</b>												
Zero sequence source impedances as seen from the <b>Generating Unit</b> terminals consistent with the maximum infeed above:												
- Resistance	% on 100										<input type="checkbox"/>	<input checked="" type="checkbox"/>
- Reactance	% on 100										<input type="checkbox"/>	<input checked="" type="checkbox"/>

**SCHEDULE 14 - FAULT INFEEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**  
PAGE 2 OF 5

Fault infeeds via Station Transformers

A submission is required for each **Station Transformer** directly connected to the **National Electricity Transmission System**. The submission should represent normal operating conditions when the maximum number of **Gensets** are **Synchronised** to the **System**, and should include the fault current from all motors normally connected to the **Station Board**, together with any Generation (e.g. **Auxiliary Gas Turbines**) which would normally be connected to the **Station Board**. The fault infeed should be expressed as a fault current at the hv terminals of the **Station Transformer** for a fault at that location.

If the submission for normal operating conditions does not represent the worst case, then a separate submission representing the maximum fault infeed that could occur in practice should be made.

DATA DESCRIPTION	UNITS	F.Yr. 0	F.Yr. 1	F.Yr. 2	F.Yr. 3	F.Yr. 4	F.Yr. 5	F.Yr. 6	F.Yr. 7	DATA to RTL	CUSC Contract	CUSC App. Form
<i>(PC.A.2.5)</i>												
Name of <b>Power Station</b>											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Number of <b>Station Transformers</b>											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Symmetrical three phase short-circuit current infeed for a fault at the <b>Connection Point</b>												
- at instant of fault	kA										<input type="checkbox"/>	<input checked="" type="checkbox"/>
- after subtransient fault current contribution has substantially decayed	kA										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Positive sequence X/R ratio At instance of fault											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Subtransient time constant (if significantly different from 40ms)	ms										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Pre-fault voltage (if different from 1.0 p.u.) at fault point (See note 1)											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Zero sequence source Impedances as seen from the <b>Point of Connection</b> Consistent with the maximum Infeed above:												
- Resistance	% on 100										<input type="checkbox"/>	<input checked="" type="checkbox"/>
- Reactance	% on 100										<input type="checkbox"/>	<input checked="" type="checkbox"/>

Note 1. The pre-fault voltage provided above should represent the voltage within the range 0.95 to 1.05 that gives the highest fault current

Note 2. % on 100 is an abbreviation for % on 100 MVA

**SCHEDULE 14 - FAULT INFEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**  
**PAGE 3 OF 5**

**Fault infeeds from Power Park Modules**

A submission is required for the whole **Power Park Module** and for each **Power Park Unit** type or equivalent. The submission shall represent operating conditions that result in the maximum fault infeed. The fault current from all motors normally connected to the **Power Park Unit's** electrical system shall be included. The fault infeed shall be expressed as a fault current at the terminals of the **Power Park Unit**, or the **Common Collection Busbar** if an equivalent **Single Line Diagram** and associated data as described in PC.A.2.2.2 is provided, and the **Grid Entry Point**, or **User System Entry Point if Embedded**, for a fault at the **Grid Entry Point**, or **User System Entry Point if Embedded**.

Should actual data in respect of fault infeeds be unavailable at the time of the application for a **CUSC Contract** or **Embedded Development Agreement**, a limited subset of the data, representing the maximum fault infeed that may result from all of the plant types being considered, shall be submitted. This data will, as a minimum, represent the root mean square of the positive, negative and zero sequence components of the fault current for both single phase and three phase solid faults at the **Grid Entry Point** (or **User System Entry Point if Embedded**) at the time of fault application and 50ms following fault application. Actual data in respect of fault infeeds shall be submitted to **The Company** as soon as it is available, in line with PC.A.1.2

DATA DESCRIPTION	UNITS	F.Yr. 0	F.Yr. 1	F.Yr. 2	F.Yr. 3	F.Yr. 4	F.Yr. 5	F.Yr. 6	F.Yr. 7	DATA to RTL	CUSC Contract	CUSC App. Form
(PC.A.2.5)												
Name of Power Station											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Name of Power Park Module											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Power Park Unit type											<input type="checkbox"/>	<input checked="" type="checkbox"/>
A submission shall be provided for the contribution of the entire <b>Power Park Module</b> and each type of <b>Power Park Unit</b> or equivalent to the positive, negative and zero sequence components of the short circuit current at the <b>Power Park Unit</b> terminals, or <b>Common Collection Busbar</b> , and <b>Grid Entry Point</b> or <b>User System Entry Point if Embedded</b> for												
(i) a solid symmetrical three phase short circuit												
(ii) a solid single phase to earth short circuit											<input type="checkbox"/>	<input checked="" type="checkbox"/>
(iii) a solid phase to phase short circuit											<input type="checkbox"/>	<input checked="" type="checkbox"/>
(iv) a solid two phase to earth short circuit											<input type="checkbox"/>	<input checked="" type="checkbox"/>
at the <b>Grid Entry Point</b> or <b>User System Entry Point if Embedded</b> .											<input type="checkbox"/>	<input checked="" type="checkbox"/>
If protective controls are used and active for the above conditions, a submission shall be provided in the limiting case where the protective control is not active. This case may require application of a non-solid fault, resulting in a retained voltage at the fault point.											<input type="checkbox"/>	<input checked="" type="checkbox"/>

**SCHEDULE 14 - FAULT INFEEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**  
**PAGE 4 OF 5**

DATA DESCRIPTION	UNITS	F.Yr.	DATA to RTL	DATA DESCRIPTION							
		0	1	2	3	4	5	6	7		
										CUSC Contract	CUSC App. Form
- A continuous time trace and table showing the root mean square of the positive, negative and zero sequence components of the fault current from the time of fault inception to 140ms after fault inception at 10ms intervals	Graphical and tabular kA versus s									<input type="checkbox"/>	<input checked="" type="checkbox"/>
- A continuous time trace and table showing the positive, negative and zero sequence components of retained voltage at the terminals or <b>Common Collection Busbar</b> , if appropriate	pu versus s									<input type="checkbox"/>	<input checked="" type="checkbox"/>
- A continuous time trace and table showing the root mean square of the positive, negative and zero sequence components of retained voltage at the fault point, if appropriate	pu versus s									<input type="checkbox"/>	<input checked="" type="checkbox"/>

**SCHEDULE 14 - FAULT INFEEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**  
**PAGE 5 OF 5**

DATA DESCRIPTION	UNITS	F.Yr.	DATA to RTL	DATA DESCRIPTION							
		0	1	2	3	4	5	6	7		
										CUSC Contract	CUSC App. Form
For <b>Power Park Units</b> that utilise a protective control, such as a crowbar circuit,											
- additional rotor resistance applied to the <b>Power Park Unit</b> under a fault situation	% on MVA									<input type="checkbox"/>	<input checked="" type="checkbox"/>
- additional rotor reactance applied to the <b>Power Park Unit</b> under a fault situation.	% on MVA									<input type="checkbox"/>	<input checked="" type="checkbox"/>
Positive sequence X/R ratio of the equivalent at time of fault at the <b>Common Collection Busbar</b>										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Minimum zero sequence impedance of the equivalent at a <b>Common Collection Busbar</b>										<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Active Power</b> generated pre-fault	MW									<input type="checkbox"/>	<input checked="" type="checkbox"/>
Number of <b>Power Park Units</b> in equivalent generator										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Power Factor (lead or lag)										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Pre-fault voltage (if different from 1.0 pu) at fault point (See note 1)	pu									<input type="checkbox"/>	<input checked="" type="checkbox"/>
Items of reactive compensation switched in pre-fault										<input type="checkbox"/>	<input checked="" type="checkbox"/>

Note 1. The pre-fault voltage provided above should represent the voltage within the range 0.95 pu to 1.05 pu that gives the highest fault current

**SCHEDULE 15 – MOTHBALLED POWER GENERATING MODULE, MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE (INCLUDING MOTHBALLED DC CONNECTED POWER PARK MODULES), MOTHBALLED HVDC SYSTEMS, MOTHBALLED HVDC CONVERTERS, MOTHBALLED DC CONVERTERS AT A DC CONVERTER STATION AND ALTERNATIVE FUEL DATA**

PAGE 1 OF 3

**MOTHBALLED POWER GENERATING MODULES, MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE (INCLUDING MOTHBALLED DC CONNECTED POWER PARK MODULES), MOTHBALLED HVDC SYSTEMS, MOTHBALLED HVDC CONVERTERS OR MOTHBALLED DC CONVERTER AT A DC CONVERTER STATION AND ALTERNATIVE FUEL DATA**  
 The following data items must be supplied with respect to each **Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module** (including **Mothballed DC Connected Power Park Modules**), **Mothballed HVDC Systems, Mothballed HVDC Converters** or **Mothballed DC Converters at a DC Converter station**

Power Station \_\_\_\_\_ Generating Unit, Power Park Module or DC Converter  
 Name (e.g. Unit 1) \_\_\_\_\_

DATA DESCRIPTION	UNITS	DATA CAT	GENERATING UNIT DATA						Total MW being returned
			<1 month	1-2 months	2-3 months	3-6 months	6-12 months	>12 months	
MW output that can be returned to service	MW	DPD II							

**Notes**

1. The time periods identified in the above table represent the estimated time it would take to return the **Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module (Mothballed DC Connected Power Park Modules), Mothballed HVDC Systems, Mothballed HVDC Converters** or **Mothballed DC Converter** at a **DC Converter Station** to service once a decision to return has been made.
2. Where a **Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module** (including a **Mothballed DC Connected Power Park Module**), **Mothballed HVDC System, Mothballed HVDC Converter** or **Mothballed DC Converter** at a **DC Converter Station** can be physically returned in stages covering more than one of the time periods identified in the above table then information should be provided for each applicable time period.
3. The estimated notice to physically return MW output to service should be determined in accordance with **Good Industry Practice** assuming normal working arrangements and normal plant procurement lead times.
4. The MW output values in each time period should be incremental MW values, e.g. if 150MW could be returned in 2 – 3 months and an additional 50MW in 3 – 6 months then the values in the columns should be Nil, Nil, 150, 50, Nil, Nil, 200 respectively.
5. Significant factors which may prevent the **Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module (Mothballed DC Connected Power Park Module), Mothballed HVDC System, Mothballed HVDC Converter** or **Mothballed DC Converter** at a **DC Converter Station** achieving the estimated values provided in this table, excluding factors relating to **Transmission Entry Capacity**, should be appended separately.

**SCHEDULE 15 – MOTHBALLED POWER GENERATING MODULES, MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE (INCLUDING DC CONNECTED POWER PARK MODULES), MOTHBALLED HVDC SYSTEMS, MOTHBALLED HVDC CONVERTERS, MOTHBALLED DC CONVERTERS AT A DC CONVERTER STATION AND ALTERNATIVE FUEL DATA**  
**PAGE 2 OF 3**

ALTERNATIVE FUEL INFORMATION

The following data items for alternative fuels need only be supplied with respect to each **Generating Unit** whose primary fuel is gas including those which form part of a **Power Generating Module**.

**Power Station** \_\_\_\_\_ **Generating Unit Name (e.g. Unit 1)**

DATA DESCRIPTION	UNITS	DATA CAT	GENERATING UNIT DATA			
			1	2	3	4
Alternative Fuel Type (*please specify)	Text	DPD II	Oil distillate	Other gas*	Other*	Other*
CHANGEOVER TO ALTERNATIVE FUEL For off-line changeover:						
Time to carry out off-line fuel changeover	Minutes	DPD II				
Maximum output following off-line changeover	MW	DPD II				
For on-line changeover:						
Time to carry out on-line fuel changeover	Minutes	DPD II				
Maximum output during on-line fuel changeover	MW	DPD II				
Maximum output following on-line fuel changeover	MW	DPD II				
Maximum operating time at full load assuing:						
Typical stock levels	Hours	DPD II				
Maximum possible stock levels	Hours	DPD II				
Maximum rate of replacement of depleted stocks of alternative fuels on the basis of Good Industry Practice	MWh (electrical)/day	DPD II				
Is changeover to alternative fuel used in normal operating arrangements?	Text	DPD II				
Number of successful changeovers carried out in the last <b>Financial Year</b> (*delete as appropriate)	Text	DPD II	0 / 1-5 / 6-10 / 11-20 / >20 **	0 / 1-5 / 6-10 / 11-20 / >20 **	0 / 1-5 / 6-10 / 11-20 / >20 **	0 / 1-5 / 6-10 / 11-20 / >20 **

**SCHEDULE 15 – MOTHBALLED POWER GENERATING MODULES, MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE (INCLUDING MOTHBALLED DC CONNECTED POWER PARK MODULES), MOTHBALLED HVDC SYSTEMS, MOTHBALLED HVDC CONVERTERS MOTHBALLED DC CONVERTERS AT A DC CONVERTER STATION AND ALTERNATIVE FUEL DATA**

PAGE 3 OF 3

DATA DESCRIPTION	UNITS	DATA CAT	GENERATING UNIT DATA			
			1	2	3	4
CHANGEOVER BACK TO MAIN FUEL For off-line changeover:  Time to carry out off-line fuel changeover	Minutes					
For on-line changeover  Time to carry out on-line fuel changeover	Minutes					
Maximum output during on-line fuel changeover	MW					

**Notes**

1. Where a **Generating Unit** has the facilities installed to generate using more than one alternative fuel type details of each alternative fuel should be given.
2. Significant factors and their effects which may prevent the use of alternative fuels achieving the estimated values provided in this table (e.g. emissions limits, distilled water stocks etc.) should be appended separately.

~~No information collated under this Schedule will be transferred to the Relevant Transmission Licensees~~

**SCHEDULE 16 – ~~SYSTEM RESTORATION BLACK START~~ INFORMATION**  
**PAGE 1 OF 2**  
**PART I**

**~~SYSTEM RESTORATION~~BLACK START INFORMATION (EXCLUDING PARTIES PARTICIPATING IN DISTRIBUTION RESTORATION ZONES)**

The following data/text items are required from each **Generator** for each **BM Unit** at a **Large Power Station** as detailed in PC.A.5.7. Data is not required for ~~Generating Units that are contracted to provide Black Start Capability, Restoration Contractors Service Providers Plant and Apparatus, or Electricity Storage Modules which have short cycle times.~~ The data should be provided in accordance with PC.A.1.2 and also, where possible, upon request from **The Company** during a **Black Start System Restoration.** ~~For Restoration Contractors who are party to a Distribution Restoration Zone Plan, the data submitted should be supplied as part of Schedule 16 Part II of this Data Registration Code.~~

Formatted: Font: Not Bold

Data Description	Units	Data Category
<i>(PC.A.5.7.1) (■ CUSC Contract)</i>		
Assuming all <b>BM Units</b> were running immediately prior to the <b>Total Shutdown</b> or <b>Partial Shutdown</b> and in the event of loss of all external power supplies, provide the following information:		
a) Expected time for the first and subsequent <b>BM Units</b> to be <b>Synchronised</b> , <del>at time intervals of 12 hours, 24 hours, 36 hours, 48 hours and 72 hours</del> from the restoration of external power supplies, assuming external power supplies are not available <del>for up to at the User's Site 24hrs</del>	Tabular or Graphical	DPD II
b) Describe any likely issues that would have a significant impact on a <b>BM Unit's</b> time to be <b>Synchronised</b> arising as a direct consequence of the inherent design or operational practice of the <b>Power Station</b> and/or <b>BM Unit</b> , e.g. limited barring facilities, time from a <b>Total Shutdown</b> or <b>Partial Shutdown</b> at which batteries would be discharged <del>or the availability of primary fuel supplies such as gas supplies, coal stocks or water levels.</del>	Text	DPD II
<b>Block Loading Capability:</b>		
c) Provide estimated <b>Block Loading Capability</b> from 0MW to <b>Registered Capacity</b> <del>and the time between each incremental step</del> of each <b>BM Unit</b> based on <del>when the unit being 'hot' (run prior to shutdown) and also 'cold' (not run for 48hrs or more prior to the shutdown) was running immediately prior to the Shutdown) and at time intervals of 12 hours, 24 hours, 36 hours, 48 hours and 72 hours after the BM Unit had been Shutdown.</del> The <b>Block Loading Capability</b> should be valid for a frequency deviation of 49.5Hz – 50.5Hz. The data should identify any required 'hold' points.	Tabular or Graphical	DPD II

**SCHEDULE 16 – ~~SYSTEM RESTORATION~~BLACK START INFORMATION**

PAGE 21 OF 2

PART II

<b>BLACK START<del>SYSTEM RESTORATION</del> INFORMATION (EXCLUDING PARTIES PARTICIPATING IN DISTRIBUTION RESTORATION ZONES)</b>		
<p>The following data/text items are required from each <b>HVDC System Owner</b> or <b>DC Converter Station Owner</b> for each <b>HVDC System</b> and <b>DC Converter Station</b> as detailed in PC.A.5.7. Data is not required for <b>Restoration Contractors Service Providers Plant and Apparatus HVDC Systems and DC Converter Stations</b> that are contracted to provide a <b>Black Start Capability</b>. The data should be provided in accordance with PC.A.1.2 and also, where possible, upon request from <b>The Company</b> during a <b>Black Start System Restoration</b>.</p>		
Data Description (PC.A.5.7.1) (■ CUSC Contract)	Units	Data Category
Assuming all <b>BM Units</b> were running immediately prior to the <b>Total Shutdown</b> or <b>Partial Shutdown</b> and in the event of loss of all external power supplies, provide the following information:		
a) Expected time for the first and subsequent <b>BM Units</b> to be <b>Synchronised</b> , <u>at time intervals of 12 hours, 24 hours, 36 hours, 48 hours and 72 hours</u> from the restoration of external power supplies, assuming external power supplies are not available <u>at the User's Site for up to 24hrs</u>	Tabular or Graphical	DPD II
b) Describe any likely issues that would have a significant impact on a <b>BM Units</b> time to be <b>Synchronised</b> arising as a direct consequence of the inherent design or operational practice of the <b>HVDC System</b> or <b>DC Converter Station</b> and/or <b>BM Unit</b> , e.g. time from a <b>Total Shutdown</b> or <b>Partial Shutdown</b> at which batteries would be discharged.	Text	DPD II
<b>Block Loading Capability:</b>		
c) Provide estimated incremental <b>Active Power</b> steps, from no load to <b>Rated MW</b> <u>and the time between each incremental step</u> which an <b>HVDC System</b> or <b>DC Converter Station</b> can instantaneously supply without causing it to trip or go outside the <b>Frequency</b> range of 47.5Hz – 52Hz (or an otherwise agreed <b>Frequency</b> range). The time between each incremental step shall also be provided. In addition data <u>should</u> <u>shall</u> be provided from OMW to <b>Registered Capacity</b> <u>of for</u> each <b>BM Unit</b> <u>which based on the HVDC System or DC Converter Station</u> being (not run for 48hrs or more prior to the shutdown) or run immediately before the <b>Partial Shutdown</b> or <b>Total Shutdown</b> <u>was running immediately prior to the Shutdown</u> and at time intervals of 12 hours, 24 hours, 36 hours, 48 hours and 72 hours after the <b>BM Unit</b> had been <b>Shutdown</b> . The data supplied should be valid for a <b>Frequency</b> deviation of 49.5Hz – 50.5Hz and should identify any required 'hold' points.	Tabular or Graphical	DPD II
<u>Governor Setting Information</u>		
From 2025 onwards, <b>Generators, HVDC System Owners</b> and		<u>DPD II</u>

<u>DC Converter owners, shall supply the governor setting information in accordance with the applicable requirements of CC.6.3.7 (h) or ECC.6.3.7.3.8.</u>		
--	--	--

**SCHEDULE 16 – SYSTEM RESTORATION INFORMATION**  
**PAGE 1 OF 1**  
**PART II**

<b>DISTRIBUTION RESTORATION ZONE INFORMATION (PC.A.5.7.2 – DPD)</b>		
<u>Where a Network Operator has a Distribution Restoration Zone Plan in place, the following data specified shall be submitted by Network Operators and Restoration Contractors, party to a Distribution Restoration Zone Plan. Restoration Contractors shall, where reasonably practicable, submit the relevant information to the Network Operator who shall then supply that information to The Company.</u>		
<u>Data Description</u> <i>(PC.A.5.7.2)</i>	<u>Units</u>	<u>Data Category</u>
<u>The expected time for each Restoration Contractor's Plant to connect to the Network Operator's System following a Total Shutdown or Partial Shutdown. The assessment should include the Restoration Contractor's ability to reconnect or re-synchronise all their Plant, to the Total System at time intervals of 12 hours, 24 hours, 36 hours, 48 hours and 72 hours from the restoration of external power supplies.</u>	<u>Tabular or Graphical</u>	<u>DPD II</u>
<u>Additionally, the data and supporting text should highlight any specific issues (eg those that would affect the time before which the Restoration Contractor's Plant could be energised) that may arise as time progresses from Shutdown without external supplies being restored or the availability of primary fuel supplies.</u>	<u>Tabular or Graphical</u>	<u>DPD II</u>
<b><u>Block Loading Capability</u></b>		
<u>Provide estimated Block Loading Capability from 0MW to Registered Capacity and the time between each incremental step of each Restoration Contractor's Plant and Apparatus based on when the Restoration Contractor's Plant and Apparatus which was running immediately prior to the Shutdown) and at time intervals of 12 hours, 24 hours, 36 hours, 48 hours and 72 hours after the Restoration Contractor's Plant and Apparatus BM Unit had been Shutdown. The Block Loading Capability should be valid for a frequency deviation of 49.5Hz – 50.5Hz. The data should identify any required 'hold' points.</u>	<u>Tabular or Graphical</u>	<u>DPD II</u>
<u>Governor Setting Information</u>		

**Commented [ML1]:** Updated post initial Panel view to:

Provide estimated Block Loading Capability from 0MW to Registered Capacity and the time between each incremental step of each Restoration Contractor's Plant and Apparatus based on when the Restoration Contractors Plant and Apparatus which was running immediately prior to the Shutdown) and at time intervals of 12 hours, 24 hours, 36 hours, 48 hours and 72 hours after the Restoration Contractors Plant and Apparatus BM Unit had been Shutdown. The Block Loading Capability should be valid for a frequency deviation of 49.5Hz – 50.5Hz. The data should identify any required 'hold' points.

From 2025 onwards, **Restoration Contractors, Generators, HVDC System Owners** and **DC Converter** owners, shall supply the governor setting information in accordance with the applicable requirements of CC.6.3.7 (h) or ECC.6.3.7.3.8.

Tabular or Graphical

DPD II

**SCHEDULE 16 – SYSTEM RESTORATION INFORMATION**

**PAGE 1 OF 5**

**PART III**

All **Users** and **Restoration Contractors** are required to confirm annually they comply with the applicable requirements of OC5.7. In the case of **Generators, HVDC System Owners, DC Converter owners, Non-Embedded Customers, and Network Operators** this confirmation shall be provided in their Week 24 submission.

<b>Assurance Activity</b>	<b>Grid Code Reference</b>	<b>Parties Involved</b>	<b>Frequency of Assurance Activity</b>	<b>The Company Witness required</b>	<b>Date of test result submission/visit</b>	<b>Annual Statement of Compliance (Y/N/Not applicable)</b>
<b>System Restoration Power Island review</b>	<a href="#">OC9.4.7.6</a> <a href="#">OC5.7.4.2(iv)</a>	<b>Relevant Transmission Licensees, Network Operators and The Company</b>	Every 3 years	<del>No</del> aApplicable		
<b>System Restoration Power Island availability assessment</b>	<a href="#">OC9.4.7.6-1</a> <a href="#">OC5.7.4.2(iv)</a>	<b>Relevant Transmission Licensees, Network Operators and The Company</b>	Yearly	Not aApplicable		
Remote Synchronisation test - TO/DNO	<a href="#">OC5.7.2.1(g)</a> <a href="#">OC5.7.2.3 (d)</a>	<b>Relevant Transmission Licensees, relevant Network Operators, Restoration Contractors</b> and to submit results for review by <b>The Company</b>	Every 3 years	No		
<b>Low Frequency Demand Disconnection Relay test</b>	<a href="#">CC.A.5.4.3 /</a> <a href="#">ECC.A.5.4.3</a>	<b>Relevant Transmission Licences, relevant Network Operators, and Non-Embedded Customers</b> to submit results for review by <b>The Company</b>	Every 3 years although this may be extended to no more than every five years if considered to be required for operational purposes	No		
<b>Anchor Restoration Contractor test</b>	<a href="#">OC5.7.2.1</a> <a href="#">/OC5.7.2.2</a> <a href="#">/OC5.7.2.3</a>	<b>Relevant Transmission Licensees, Network Operators,</b>	Every 3 years	Yes		

<u>Assurance Activity</u>	<u>Grid Code Reference</u>	<u>Parties Involved</u>	<u>Frequency of Assurance Activity</u>	<u>The Company Witness required</u>	<u>Date of test result submission/visit</u>	<u>Annual Statement of Compliance (Y/N/Not applicable)</u>
		<u>Anchor Restoration Contractors and witnessed by The Company</u>				
<u>Top Up Restoration Contractor Test</u>	<u>OC.5.7.2.4</u>	<u>Relevant Transmission Licensees, Network Operators, Top Up Restoration Contractors and witnessed by The Company</u>	<u>Every 3 years</u>	<u>Yes</u>		
<u>Resilience to Partial Shutdown or Total Shutdown of Restoration Contractor</u>	<u>OC9.4.7.6.2</u> <u>OC5.7.4.2(iii)</u> <u>CC/ECC.7.11</u>	<u>Restoration Contractors and to submit evidence to The Company</u>	<u>Yearly</u>	<u>No</u>		
<u>Quick Resynchronisation Unit Test</u>	<u>OC5.7.2.5</u>	<u>EU Generators in respect of Type C and Type D Power Generating Modules, relevant Network Operators and witnessed by The Company</u>	<u>Yearly</u>	<u>Yes</u>		
<u>Distribution Restoration Zone Control System Test</u>	<u>OC5.7.2.6</u> <u>Electrical Standard - Distribution Restoration Zone Control System High Level Functional Specification</u>	<u>Network Operators, Restoration Contractors and witnessed by The Company</u>	<u>Every 3 years</u>	<u>Yes</u>		
<u>Dead Line Charge Test</u>	<u>OC5.7.2.1(g)(a)</u> <u>OC5.7.2.3(d)(a)</u>	<u>Transmission Licensees, relevant Network Operators Anchor</u>	<u>Every 3 years</u>	<u>Yes</u>		

**Commented [ML2]:** Update Post initial Panel review:  
Propose to remove reference to the Standard in the DRC

<u>Assurance Activity</u>	<u>Grid Code Reference</u>	<u>Parties Involved</u>	<u>Frequency of Assurance Activity</u>	<u>The Company Witness required</u>	<u>Date of test result submission/visit</u>	<u>Annual Statement of Compliance (Y/N/Not applicable)</u>
		<u>Restoration Contractors and – witnessed by The Company</u>				
<u>Remote Synchronisation Test -Restoration Contractor</u>	<u>OC5.7.2.1(q)(b)</u> <u>OC5.7.2.3(d)(b)</u>	<u>Relevant Transmission Licensees, relevant Network Operators, and Restoration Contractors – witnessed by and The Company</u>	<u>Every 3 years</u>	<u>Yes</u>		
<u>Assurance Visits</u>	<u>OC5.7.4</u> <u>OC5.7.5</u>	<u>The Company, Relevant Transmission Licensees, relevant Network Operators to visit Restoration Contractors</u>	<u>Every 3 years</u>	<u>Yes</u>		
<u>Voice Systems Resilience Test or equivalent</u>	<u>OC5.7.4.2(vi)</u>	<u>CUSC Parties, relevant Network Operators, Relevant Transmission Licensees Restoration Contractors and to submit results for review by The Company; The Company to test its own capability</u>	<u>Yearly</u>	<u>No</u>		
<u>Critical Tools and Facilities control systems resilience demonstration – power resilience including power resilience</u>	<u>OC5.7.2.6</u> <u>OC.5.7.4.2(iii)</u> <u>OC5.7.4.2(ix)</u> <u>OC5.7.4.3</u> <u>CC.7.10</u> <u>ECC.7.10</u>	<u>CUSC Parties, relevant Network Operators, Relevant Transmission Licensees,</u>	<u>Yearly</u>	<u>No</u>		

<u>Assurance Activity</u>	<u>Grid Code Reference</u>	<u>Parties Involved</u>	<u>Frequency of Assurance Activity</u>	<u>The Company Witness required</u>	<u>Date of test result submission/visit</u>	<u>Annual Statement of Compliance (Y/N/Not applicable)</u>
demonstration & connectivity and alarm event handling		and <u>Restoration Contractors</u> to submit results for review by and <u>The Company.</u> <u>The Company</u> to test its own capability				
Control systems resilience demonstration – diagram & topology	<u>OC5.7.2.6</u> <u>OC.5.7.4.2(iii)</u> <u>OC5.7.4.2(ix)</u>	<u>CUSC Parties,</u> relevant <u>Network Operators,</u> <u>RRelevant Transmission Licensees,</u> and <u>Restoration Contractors</u> to submit results for review by and <u>The Company.</u> <u>The Company</u> to test its own capability	<u>Yearly</u>	<u>No</u>		
Cyber-Security	<u>CC.7.10.6</u> <u>ECC.7.10.6</u> <u>OC.5.7.4.2(iii)</u> <u>OC5.7.4.2(x)</u>	<u>CUSC Parties,</u> relevant <u>Network Operators,</u> <u>RRelevant Transmission Licensees,</u> and <u>Restoration Contractors</u> and to submit results for review by <u>The Company.</u> <u>The Company</u> to test its own capability	<u>Yearly</u>	<u>No</u>		
Telephony services (Test per month as per CC/ECC.6.5.4.	<u>CC.6.5.1 –</u> <u>CC.6.5.5</u> <u>ECC.6.5.1 –</u>	<u>CUSC Parties,</u> relevant	<u>Yearly</u>	<u>No</u>		

<u>Assurance Activity</u>	<u>Grid Code Reference</u>	<u>Parties Involved</u>	<u>Frequency of Assurance Activity</u>	<u>The Company Witness required</u>	<u>Date of test result submission/visit</u>	<u>Annual Statement of Compliance (Y/N/Not applicable)</u>
	<u>ECC.6.5.5</u> <u>OC.5.7.4.2(vi)</u> <u>OC5.7.4.2(xi)</u> <u>OC5.7.4.2(xii)</u>	<u>Network Operators,</u> <u>Relevant Transmission Licensees and Restoration Contractors</u> <u>to submit results for review by and</u> <u>The Company.</u> <u>The Company to test its own capability</u>				
<u>Resilience to Partial Shutdown or Total Shutdown of CUSC Parties</u>	<u>OC5.7.4</u> <u>OC5.7.5</u>	<u>CUSC Parties</u> <u>to submit evidence for review by and</u> <u>The Company</u>	<u>Yearly</u>	<u>No</u>		
<u>Restoration Procedure review</u>	<u>OC9.4.7.6.2</u> <u>OC5.7.4.2(iv)</u>	<u>The Company,</u> <u>Relevant Transmission Licensees,</u> <u>relevant Network Operators,</u> <u>CUSC Parties</u> <u>and</u> <u>Restoration Contractors</u>	<u>Every 3 years</u>	<u>Not applicable</u>		
<u>LJRP &amp; DRZP reviews</u>	<u>OC9.4.7.6</u> <u>OC5.7.4.2(iv)</u>	<u>The Company,</u> <u>Network Operators,</u> <u>Transmission Licensees</u> <u>and parties who are signatories to a Restoration Plan</u> <u>signatories</u>	<u>Every 3 years</u>	<u>Not applicable</u> <u>Yes</u>		
<u>Awareness training for Restoration Contractor and CUSC Parties</u>	<u>OC9.4.7.6.2</u> <u>OC5.7.4</u>	<u>The Company,</u> <u>relevant Network Operators,</u> <u>Transmission Licensees,</u>	<u>Every 3 years</u>	<u>Not applicable</u> <u>Yes</u>		

<u>Assurance Activity</u>	<u>Grid Code Reference</u>	<u>Parties Involved</u>	<u>Frequency of Assurance Activity</u>	<u>The Company Witness required</u>	<u>Date of test result submission/visit</u>	<u>Annual Statement of Compliance (Y/N/Not applicable)</u>
		<u>CUSC Parties and Restoration Contractors</u>				
<u>Cross industry training</u>	<u>OC9.4.7.6.2</u> <u>OC5.7.4</u>	<u>The Company, provides training to Network Operators, Transmission Licensees, CUSC Parties and Restoration Contractors</u>	<u>Every 3 years</u>	<u>Not applicable</u> <u>Yes</u>		



## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 1 OF 24

The data in this Schedule 18 is required from **Generators** who are undertaking **OTSDUW** and connecting to a **Transmission Interface Point**.

DATA DESCRIPTION	UNITS	DATA to		DATA CAT.	GENERATING UNIT OR STATION DATA						
		RTL CUSC Cont ract	CUSC App. Form		F.Yr0	F.Yr1	F.Yr2	F.Yr3	F.Yr4	F.Yr5	F.Yr 6
<b>INDIVIDUAL OTSDUW DATA</b>											
Interface Point Capacity (PC.A.3.2.2 (a))	MW MVA <sub>r</sub>	<input type="checkbox"/>	<input checked="" type="checkbox"/>								
Performance Chart at the Transmission Interface Point for OTSDUW Plant and Apparatus (PC.A.3.2.2(f)(iv))		<input type="checkbox"/>	<input checked="" type="checkbox"/>								
<b>OTSDUW DEMANDS</b>											
<b>Demand</b> associated with the <b>OTSDUW Plant and Apparatus</b> (excluding <b>OTSDUW DC Converters</b> – see Note 1)) supplied at each <b>Interface Point</b> . The <b>User</b> should also provide the <b>Demand</b> supplied to each <b>Connection Point</b> on the <b>OTSDUW Plant and Apparatus</b> . (PC.A.5.2.5)											
- The maximum <b>Demand</b> that could occur.	MW MVA <sub>r</sub>	<input type="checkbox"/>		<b>DPD I</b>							
- <b>Demand</b> at specified time of annual peak half hour of <b>National Electricity Transmission System Demand</b> at <b>Annual ACS Conditions</b> .	MW MVA <sub>r</sub>	<input type="checkbox"/>		<b>DPD I</b> <b>DPD II</b>							
- <b>Demand</b> at specified time of annual minimum half-hour of <b>National Electricity Transmission System Demand</b> .	MW MVA <sub>r</sub>	<input type="checkbox"/>		<b>DPD II</b> <b>DPD II</b>							
(Note 1 – <b>Demand</b> required from <b>OTSDUW DC Converters</b> should be supplied under page 2 of Schedule 18).											

## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 2 OF 24

### OTSDUW USERS SYSTEM DATA

DATA DESCRIPTION	UNITS	DATA to RTL		DATA CATEGORY
		CUSC Contract	CUSC App. Form	
<b>OFFSHORE TRANSMISSION SYSTEM LAYOUT</b> (PC.A.2.2.1, PC.A.2.2.2 and P.C.A.2.2.3)				
A <b>Single Line Diagram</b> showing connectivity of all of the <b>Offshore Transmission System</b> including all <b>Plant and Apparatus</b> between the <b>Interface Point</b> and all Connection <b>Points</b> is required.		■	■	SPD
This <b>Single Line Diagram</b> shall depict the arrangement(s) of all of the existing and proposed load current carrying <b>Apparatus</b> relating to both existing and proposed <b>Interface Points</b> and <b>Connection Points</b> , showing electrical circuitry (i.e. overhead lines, underground cables (including subsea cables), power transformers and similar equipment), operating voltages, circuit breakers and phasing arrangements		■	■	SPD
<b>Operational Diagrams</b> of all substations within the <b>OTSDUW Plant and Apparatus</b>		■	■	SPD
<b>SUBSTATION INFRASTRUCTURE</b> (PC.A.2.2.6)				
For the infrastructure associated with any <b>OTSDUW Plant and Apparatus</b>				
Rated 3-phase rms short-circuit withstand current	kA	■	■	SPD
Rated 1-phase rms short-circuit withstand current	kA	■	■	SPD
Rated Duration of short-circuit withstand	s	■	■	SPD
Rated rms continuous current	A	■	■	SPD
<b>LUMPED SUSCEPTANCES</b> (PC.A.2.3)				
Equivalent Lumped Susceptance required for all parts of the User's Subtransmission System (including OTSDUW Plant and Apparatus) which are not included in the Single Line Diagram.		■	■	
This should not include:		■	■	
(a) independently switched reactive compensation equipment identified above.		■	■	
(b) any susceptance of the <b>OTSDUW Plant and Apparatus</b> inherent in the <b>Demand (Reactive Power)</b> data provided on Page 1 and 2 of this Schedule 14.		■	■	
Equivalent lumped shunt susceptance at nominal <b>Frequency</b> .	% on 100 MVA	■	■	

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**

PAGE 3 OF 24

**OFFSHORE TRANSMISSION SYSTEM DATA**

Branch Data (PC.A.2.2.4)

Node 1	Node 2	Rated Voltage kV	Operating Voltage kV	Circuit	PPS PARAMETERS			ZPS PARAMETERS			Maximum Continuous Ratings			Length (km)
					R	X	B	R	X	B	R	X	B	

**Notes**

1. For information equivalent STC Reference: STCP12-1m Part 3 – 2.1 Branch Data
2. In the case where an overhead line exists within the OTSDUW Plant and Apparatus the Mutual inductances should also be provided.

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 4 OF 24**

**OFFSHORE TRANSMISSION SYSTEM DATA**

2 Winding Transformer Data (PC.A.2.2.5)

The data below is **Standard Planning Data**, and details should be shown below of all transformers shown on the **Single Line Diagram**

HV Node	HV (kV)	LV Node	LV (kV)	Rating (MVA)	Transformer	Positive Phase Sequence Reactance % on 100MVA			Positive Phase Sequence Resistance % on 100MVA			Tap Changer			Winding Arr	Earthing method (Direct/ Res/ Reac)	Earthing Impedance method
						Max Tap	Min Tap	Nom Tap	Max Tap	Min Tap	Nom Tap	Range +% to -%	Step size %	Type			

Notes

1 For information the corresponding STC Reference is STCP12-1: Part 3 – 2.4 Transformers

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 5 OF 24**







## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 7 OF 24

### OFFSHORE TRANSMISSION SYSTEM DATA

#### REACTIVE COMPENSATION EQUIPMENT (PC.A.2.4(e))

Item	Node	kV	Device No.	Rating (MVar)	P Loss (kW)	Tap range	Connection Arrangement

Notes:

1. For information STC Reference: STCP12-1: Part 3 - 2.5 Reactive Compensation Equipment
2. Data relating to continuously variable reactive compensation equipment (such as statcoms or SVCs) should be entered on the SVC Modelling table.
3. For the avoidance of doubt this includes any AC Reactive Compensation equipment included within the OTSDUW DC Converter other than harmonic filter data which is to be entered in the harmonic filter data table.

PC.A.2.4.1(e)	A mathematical representation in block diagram format to model the control of any dynamic compensation plant. The model should be suitable for RMS dynamic stability type studies in which the time constants used should not be less than 10ms.
---------------	--

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**

**OFFSHORE TRANSMISSION SYSTEM DATA**

REACTIVE COMPENSATION - SVC Modelling Data (PC.A.2.4.1(e)(iii))

HV node	LV Node	Control Node	Nominal Voltage (kV)	Target Voltage (kV)	Max MVAR at HV	Min MVAR at HV	Slope %	Voltage Dependent Q Limit	Normal Running Mode	R1 PPS_R	X1 PPS_X	R0 ZPS_R	Z0 ZPS_X	Trasnf Winding Type	Connection (Direct/ Tertiary)

Notes:

1.For information the equivalent STC Reference is: STCP12-1: Part 3 - 2.7 SVC Modelling Data





## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 10 OF 24

### Information for Transient Overvoltage Assessment (DPD I) (PC.A.6.2 ■ CUSC Contract)

The information listed below may be requested by **The Company** from each **User** undertaking **OTSDUW** with respect to any **Interface Point** or **Connection Point** to enable **The Company** to assess transient overvoltage on the **National Electricity Transmission System**.

- (a) Busbar layout plan(s), including dimensions and geometry showing positioning of any current and voltage transformers, through bushings, support insulators, disconnectors, circuit breakers, surge arresters, etc. Electrical parameters of any associated current and voltage transformers, stray capacitances of wall bushings and support insulators, and grading capacitances of circuit breakers;
- (b) Electrical parameters and physical construction details of lines and cables connected at that busbar. Electrical parameters of all plant e.g., transformers (including neutral earthing impedance or zig-zag transformers if any), series reactors and shunt compensation equipment connected at that busbar (or to the tertiary of a transformer) or by lines or cables to that busbar;
- (c) Basic insulation levels (BIL) of all **Apparatus** connected directly, by lines or by cables to the busbar;
- (d) Characteristics of overvoltage **Protection** devices at the busbar and at the termination points of all lines, and all cables connected to the busbar;
- (e) Fault levels at the lower voltage terminals of each transformer connected to each **Interface Point** or **Connection Point** without intermediate transformation;
- (f) The following data is required on all transformers within the **OTSDUW Plant and Apparatus**.
- (g) An indication of which items of equipment may be out of service simultaneously during **Planned Outage** conditions.

### Harmonic Studies (DPD I) (PC.A.6.4 ■ CUSC Contract)

The information given below, both current and forecast, where not already supplied in this Schedule 14 may be requested by **The Company** from each **User** if it is necessary for **The Company** to evaluate the production/magnification of harmonic distortion on **National Electricity Transmission System**. The impact of any third party **Embedded** within the **User's System** should be reflected:-

- (a) Overhead lines and underground cable circuits (including subsea cables) of the **User's OTSDUW Plant and Apparatus** must be differentiated and the following data provided separately for each type:-
  - Positive phase sequence resistance
  - Positive phase sequence reactance
  - Positive phase sequence susceptance
- (b) for all transformers connecting the **OTSDUW Plant and Apparatus** to a lower voltage:-
  - Rated MVA
  - Voltage Ratio
  - Positive phase sequence resistance
  - Positive phase sequence reactance

## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 11 OF 24

- (c) at the lower voltage points of those connecting transformers:-

Equivalent positive phase sequence susceptance  
Connection voltage and MVA rating of any capacitor bank and component design parameters if configured as a filter

Equivalent positive phase sequence interconnection impedance with other lower voltage points  
The minimum and maximum **Demand** (both MW and MVA) that could occur  
Harmonic current injection sources in Amps at the Connection Points and Interface Points

- (d) an indication of which items of equipment may be out of service simultaneously during **Planned Outage** conditions

### Voltage Assessment Studies (DPD I) (PC.A.6.5 ■ CUSC Contract)

The information listed below, where not already supplied in this Schedule 14, may be requested by **The Company** from each **User** undertaking **OTSDUW** with respect to any **Connection Point** or **Interface Point** if it is necessary for **The Company** to undertake detailed voltage assessment studies (e.g. to examine potential voltage instability, voltage control co-ordination or to calculate voltage step changes on the **National Electricity Transmission System**).

- (a) For all circuits of the **User's OTSDUW Plant and Apparatus**:-

Positive Phase Sequence Reactance  
Positive Phase Sequence Resistance  
Positive Phase Sequence Susceptance  
MVA rating of any reactive compensation equipment

- (b) for all transformers connecting the **User's OTSDUW Plant and Apparatus** to a lower voltage:-

Rated MVA  
Voltage Ratio  
Positive phase sequence resistance  
Positive Phase sequence reactance  
Tap-changer range  
Number of tap steps  
Tap-changer type: on-load or off-circuit  
AVC/tap-changer time delay to first tap movement  
AVC/tap-changer inter-tap time delay

- (c) at the lower voltage points of those connecting transformers

Equivalent positive phase sequence susceptance  
MVA rating of any reactive compensation equipment  
Equivalent positive phase sequence interconnection impedance with other lower voltage points  
The maximum **Demand** (both MW and MVA) that could occur  
Estimate of voltage insensitive (constant power) load content in % of total load at both winter peak and 75% off-peak load conditions

## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 12 OF 24

### Short Circuit Analyses:(DPD I) (PC.A.6.6 ■ CUSC Contract)

The information listed below, both current and forecast, and where not already supplied under this Schedule 14, may be requested by **The Company** from each **User** undertaking **OTSDUW** with respect to any **Connection Point** or **Interface Point** where prospective short-circuit currents on **Transmission** equipment are close to the equipment rating.

(a) For all circuits of the **User's OTSDUW Plant and Apparatus**:-

- Positive phase sequence resistance
- Positive phase sequence reactance
- Positive phase sequence susceptance
- Zero phase sequence resistance (both self and mutuals)
- Zero phase sequence reactance (both self and mutuals)
- Zero phase sequence susceptance (both self and mutuals)

(b) For all transformers connecting the **User's OTSDUW Plant and Apparatus** to a lower voltage:-

- Rated MVA
- Voltage Ratio
- Positive phase sequence resistance (at max, min and nominal tap)
- Positive Phase sequence reactance (at max, min and nominal tap)
- Zero phase sequence reactance (at nominal tap)
- Tap changer range
- Earthing method: direct, resistance or reactance
- Impedance if not directly earthed

(c) At the lower voltage points of those connecting transformers:-

The maximum **Demand** (in MW and MVA) that could occur  
Short-circuit infeed data in accordance with PC.A.2.5.6(a) unless the **User's OTSDUW Plant and Apparatus** runs in parallel with the **Subtransmission System**, when to prevent double counting in each node infeed data, a  $\pi$  equivalent comprising the data items of PC.A.2.5.6(a) for each node together with the positive phase sequence interconnection impedance between the nodes shall be submitted.

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**

Fault infeed data to be submitted by OTSDUW Plant and Apparatus providing a fault infeed (including OTSDUW DC Converters) (PC.A.2.5.5)

A submission is required for **OTSDUW Plant and Apparatus** (including **OTSDUW DC Converters** at each **Transmission Interface Point** and **Connection Point**. The submission shall represent operating conditions that result in the maximum fault infeed. The fault current from all auxiliaries of the **OTSDUW Plant and Apparatus** at the **Transmission Interface Point** and **Connection Point** shall be included. The fault infeed shall be expressed as a fault current at the **Transmission Interface Point** and also at each **Connection Point**.

Should actual data in respect of fault infeeds be unavailable at the time of the application for a **CUSC Contract** or **Embedded Development Agreement**, a limited subset of the data, representing the maximum fault infeed that may result from the **OTSDUW Plant and Apparatus**, shall be submitted. This data will, as a minimum, represent the root mean square of the positive, negative and zero sequence components of the fault current for both single phase and three phase solid faults at each **Connection Point** and **Interface Point** at the time of fault application and 50ms following fault application. Actual data in respect of fault infeeds shall be submitted to **The Company** as soon as it is available, in line with PC.A.1.2.

DATA DESCRIPTION	UNITS	F.Yr.	DATA to RTL								
		0	1	2	3	4	5	6	7	CUSC Contract	CUSC App. Form
(PC.A.2.5)											
Name of OTSDUW Plant and Apparatus											
OTSDUW DC Converter type (i.e. voltage or current source)											
A submission shall be provided for the contribution of each OTSDUW Plant and Apparatus to the positive, negative and zero sequence components of the short circuit current at the <b>Interface Point</b> and each <b>Connection Point</b> for (i) a solid symmetrical three phase short circuit (ii) a solid single phase to earth short circuit (iii) a solid phase to phase short circuit (iv) a solid two phase to earth short circuit  If protective controls are used and active for the above conditions, a submission shall be provided in the limiting case where the protective control is not active. This case may require application of a non-solid fault, resulting in a retained voltage at the fault point.										<input type="checkbox"/> ■ <input type="checkbox"/> ■ <input type="checkbox"/> ■ <input type="checkbox"/> ■ <input type="checkbox"/> ■	

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**

DATA DESCRIPTION	UNITS	F.	DATA to									
		Yr.	RTL									
		0	1	2	3	4	5	6	7	CUSC Contract	CUSC App. Form	
- A continuous time trace and table showing the root mean square of the positive, negative and zero sequence components of the fault current from the time of fault inception to 140ms after fault inception at 10ms intervals	Graphical and tabular  kA versus s										<input type="checkbox"/>	<input checked="" type="checkbox"/>
- A continuous time trace and table showing the positive, negative and zero sequence components of retained voltage at the <b>Interface Point</b> and each <b>Connection Point</b> , if appropriate	p.u. versus s										<input type="checkbox"/>	<input checked="" type="checkbox"/>
- A continuous time trace and table showing the root mean square of the positive, negative and zero sequence components of retained voltage at the fault point, if appropriate	p.u. versus s										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Positive sequence X/R ratio of the equivalent at time of fault at the <b>Interface Point</b> and each <b>Connection Point</b>											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Minimum zero sequence impedance of the equivalent at the <b>Interface Point</b> and each <b>Connection Point</b>											<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Active Power</b> transfer at the Interface Point and each Connection Point pre-fault	MW										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Power Factor (lead or lag)											<input type="checkbox"/>	<input checked="" type="checkbox"/>
Pre-fault voltage (if different from 1.0 p.u.) at fault point (See note 1)	p.u.										<input type="checkbox"/>	<input checked="" type="checkbox"/>
Items of reactive compensation switched in pre-fault											<input type="checkbox"/>	<input checked="" type="checkbox"/>

Note 1. The pre-fault voltage provided above should represent the voltage within the range 0.95 to 1.05 that gives the highest fault current

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 15 OF 24**

Thermal Ratings Data (PC.A.2.2.4)

	<b>CIRCUIT RATING SCHEDULE</b>			
<b>Voltage</b> 132kV	<b>Offshore TO Name</b>		<b>Issue Date</b>	

**CIRCUIT Name from Site A – Site B**

OVERALL CCT RATINGS		Winter				Spring/Autumn				Summer			
		%Nom	Limit	Amps	MVA	%Nom	Limit	Amps	MVA	%Nom	Limit	Amps	MVA
Pre-Fault Continuous		84%	Line	485	111	84%	Line	450	103	84%	Line	390	89
Post-Fault Continuous		100%	Line	580	132	100%	Line	540	123	100%	Line	465	106
Prefault load exceeds line prefault continuous rating	6hr	95%	Line	580	132	95%	Line	540	123	95%	Line	465	106
	20m		Line	580	132		Line	540	123		Line	465	106
	10m	mva	Line	580	132	mva	Line	540	123	mva	Line	465	106
	5m	125	Line	580	132	116	Line	540	123	100	Line	465	106
Short Term Overloads	3m		Line	580	132		Line	540	123		Line	465	106
	6hr	90%	Line	580	132	90%	Line	540	123	90%	Line	465	106
	20m		Line	580	132		Line	540	123		Line	465	106
	10m	mva	Line	580	132	mva	Line	540	123	mva	Line	465	106
Limiting Item and permitted overload values for different times and pre-fault loads	5m	118	Line	580	132	110	Line	540	123	95	Line	465	106
	3m		Line	580	132		Line	540	123		Line	465	106
	6hr	84%	Line	580	132	84%	Line	540	123	84%	Line	465	106
	20m		Line	590	135		Line	545	125		Line	470	108
	10m	mva	Line	630	144	mva	Line	580	133	mva	Line	495	113
	5m	110	Line	710	163	103	Line	655	149	89	Line	555	126
	3m		Line	810	185		Line	740	170		Line	625	143
	6hr	75%	Line	580	132	75%	Line	540	123	75%	Line	465	106
	20m		Line	595	136		Line	555	126		Line	475	109
	10m	mva	Line	650	149	mva	Line	600	137	mva	Line	510	116
	5m	99	Line	760	173	92	Line	695	159	79	Line	585	134
	3m		Line	885	203		Line	810	185		Line	685	156
	6hr	60%	Line	580	132	60%	Line	540	123	60%	Line	465	106
	20m		Line	605	138		Line	560	128		Line	480	110
	10m	mva	Line	675	155	mva	Line	620	142	mva	Line	530	121
	5m	79	Line	820	187	73	Line	750	172	63	Line	635	145
	3m		Line	985	226		Line	900	206		Line	755	173
	6hr	30%	Line	580	132	30%	Line	540	123	30%	Line	465	106
	20m		Line	615	141		Line	570	130		Line	490	112
	10m	mva	Line	710	163	mva	Line	655	150	mva	Line	555	127
	5m	39	Line	895	205	36	Line	820	187	31	Line	690	158
	3m		Line	1110	255		Line	1010	230		Line	845	193

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**

PAGE 16 OF 24

6hr													
20m													
10m													
5m													
3m													
6hr													
20m													
10m													
5m													
3m													
Notes or Restrictions Detailed													

- Notes: 1. For information the equivalent STC Reference: STCP12-1: Part 3 - 2.6 Thermal Ratings  
 2. The values shown in the above table is example data.

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 17 OF 24**

**Protection Policy** (PC.A.6.3)

To include details of the protection policy

**Protection Schedules**(PC.A.6.3)

Data schedules for the protection systems associated with each primary plant item including:

Protection, Intertrip Signalling & operating times  
Intertripping and protection unstabilisation initiation  
Synchronising facilities  
Delayed Auto Reclose sequence schedules

**Automatic Switching Scheme Schedules** (PC.A.2.2.7)

A diagram of the scheme and an explanation of how the system will operate and what plant will be affected by the scheme's operation.

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 18 OF 24**

**GENERATOR INTERTRIP SCHEMES** (PC.A.2.2.7(b))

Substation: \_\_\_\_\_

Details of Generator Intertrip Schemes:

A diagram of the scheme and an explanation of how the system will operate and what plant will be effected by the schemes operation.

**DEMAND INTERTRIP SCHEMES** (PC.A.2.2.7(b))

Substation: \_\_\_\_\_

Details of Demand Intertrip Schemes:

A diagram of the scheme and an explanation of how the system will operate and what plant will be effected by the schemes operation

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 19 OF 24**

*Specific Operating Requirements (CC.5.2.1 or ECC.5.2.1)*

SUBSTATION OPERATIONAL GUIDE

**Substation:** \_\_\_\_\_

**Location Details:**

Postal Address:	Telephone Nos.	Map Ref.
<b>Transmission Interface</b>		
<b>Generator Interface</b>		

- 1. Substation Type:**
  
  
  
  
  
  
  
  
  
  
- 2. Voltage Control:** *(short description of voltage control system. To include mention of modes i.e. Voltage, manual etc. Plus control step increments i.e. 0.5% or 0.33kV)*
  
  
  
  
  
  
  
  
  
  
- 3. Energisation Switching Information:** *(The standard energisation switching process from dead.)*
  
  
  
  
  
  
  
  
  
  
- 4. Intertrip Systems:**
  
  
  
  
  
  
  
  
  
  
- 5. Reactive Plant Outage:** *(A short explanation of any system re-configurations required to facilitate the outage of any reactive plant which form part of the OTSDUW Plant and Apparatus equipment. Also any generation restrictions required).*
  
  
  
  
  
  
  
  
  
  
- 6. Harmonic Filter Outage:** *(An explanation as to any OTSDUW Plant and Apparatus reconfigurations required to facilitate the outage and maintain the system within specified Harmonic limits, also any generation restrictions required).*

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 20 OF 24**

**OTSDUW DC CONVERTER TECHNICAL DATA**

**OTSDUW DC CONVERTER NAME**

DATE: \_\_\_\_\_


Data Description	Units	DATA to RTL		Data Category	DC Converter Station Data
(PC.A.4 and PC.A.5.2.5)		CUSC Contract	CUSC App. Form		
<b>OTSDUW DC CONVERTER (CONVERTER DEMANDS):</b>					
<b>Demand</b> supplied through <b>Station Transformers</b> associated with the <b>OTSDUW DC Converter</b> at each <b>Interface Point</b> and each <b>Offshore Connection Point Grid Entry Point [PC.A.4.1]</b>					
- <b>Demand</b> with all <b>OTSDUW DC Converters</b> operating at <b>Interface Point Capacity</b> .	MW MVA <sub>r</sub>	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- <b>Demand</b> with all <b>OTSDUW DC Converters</b> operating at maximum <b>Interface Point</b> flow from the <b>Interface Point</b> to each <b>Offshore Grid Entry Point</b> .	MW MVA <sub>r</sub>	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- The maximum <b>Demand</b> that could occur.	MW MVA <sub>r</sub>	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- <b>Demand</b> at specified time of annual peak half hour of <b>The Company Demand</b> at <b>Annual ACS Conditions</b> .	MW MVA <sub>r</sub>	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b> <b>DPD II</b>	
- <b>Demand</b> at specified time of annual minimum half-hour of <b>The Company Demand</b> .	MW MVA <sub>r</sub>	<input type="checkbox"/>	<input type="checkbox"/>	<b>DPD II</b>	
<b>OTSDUW DC CONVERTER DATA</b>	Text	<input type="checkbox"/>	■	<b>SPD+</b>	
Number of poles, i.e. number of <b>OTSDUW DC Converters</b>	Text	<input type="checkbox"/>	■	<b>SPD+</b>	
Pole arrangement (e.g. monopole or bipole)	Diagram	<input type="checkbox"/>			
Return path arrangement					
Details of each viable operating configuration			■		
Configuration 1	Diagram	<input type="checkbox"/>	■	<b>SPD+</b>	
Configuration 2	Diagram	<input type="checkbox"/>	■		
Configuration 3	Diagram	<input type="checkbox"/>	■		
Configuration 4	Diagram	<input type="checkbox"/>	■		
Configuration 5	Diagram	<input type="checkbox"/>	■		
Configuration 6	Diagram	<input type="checkbox"/>	■		




**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 22 OF 24**

Data Description	Units	DATA to RTL		Data Category	Operating configuration						
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6	
<b>OTSDUW DC CONVERTER NETWORK DATA</b> (PC.A.5.4.3.1 (c))  Rated DC voltage per pole Rated DC current per pole  Details of the <b>OTSDUW DC Network</b> described in diagram form including resistance, inductance and capacitance of all DC cables and/or DC lines. Details of any line reactors (including line reactor resistance), line capacitors, DC filters, earthing electrodes and other conductors that form part of the <b>OTSDUW DC Network</b> should be shown.	kV A  Diagram	<input type="checkbox"/> <input type="checkbox"/>  <input type="checkbox"/>		<b>DPD II</b> <b>DPD II</b>  <b>DPD II</b>							

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 23 OF 24**



Data Description	Units	DATA to		Data Category	Operating configuration						
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6	



<b>OTSDUW DC CONVERTER CONTROL SYSTEMS</b> (PC.A.5.4.3.2)							
Static $V_{DC} - P_{DC}$ (DC voltage – DC power) or Static $V_{DC} - I_{DC}$ (DC voltage – DC current) characteristic (as appropriate) when operating as –Rectifier –Inverter	Diagram	□					
	Diagram	□					
	Diagram	□					
Details of rectifier mode control system, in block diagram form together with parameters showing transfer functions of individual elements.	Diagram	□					
Details of inverter mode control system, in block diagram form showing transfer functions of individual elements including parameters (as applicable).	Diagram	□					
Details of <b>OTSDUW DC Converter</b> transformer tap changer control system in block diagram form showing transfer functions of individual elements including parameters.	Diagram	□					
Details of AC filter control systems in block diagram form showing transfer functions of individual elements including parameters	Diagram	□					
Details of any frequency and/or load control systems in block diagram form showing transfer functions of individual elements including parameters.	Diagram	□					
Details of any large or small signal modulating controls, such as power oscillation damping controls or sub-synchronous oscillation damping controls, that have not been submitted as part of the above control system data.	Diagram	□					
Transfer block diagram representation of the reactive power control at converter ends for a voltage source converter.	Diagram	□					
For <b>Generators</b> in respect of <b>OTSDUW</b> who are also <b>EU Code Users</b> details of <b>OTSDUW DC  Converter</b> unit models and/or control systems in block diagram form showing transfer functions of individual elements including parameters.	Diagram	□					
For <b>Generators</b> in respect of <b>OTSDUW</b> who are also <b>EU Code Users</b> details of AC component models and/or control systems in block diagram form showing transfer functions of individual elements including parameters.	Diagram	□					
For <b>Generators</b> in respect of <b>OTSDUW</b> who are also <b>EU Code Users</b> details of DC Grid models and/or control systems in block diagram form showing transfer functions of individual elements including parameters.	Diagram	□					
For <b>Generators</b> in respect of <b>OTSDUW</b> who are also <b>EU Code Users</b> details of Voltage and power controller and/or control systems in block diagram form showing transfer functions of individual elements including parameters.	Diagram	□					
For <b>Generators</b> in respect of <b>OTSDUW</b> who are also <b>EU Code Users</b> details of Special control features if applicable (e.g. power oscillation damping (POD) function, subsynchronous	Diagram	□					

Data Description	Units	DATA to		Data Category	Operating configuration					
		CUSC Contract	RTL CUSC App. Form		1	2	3	4	5	6
<p>torsional interaction (SSTI) control and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</p> <p>For <b>Generators</b> in respect of <b>OTSDUW</b> who are also <b>EU Code Users</b> details of Multi terminal control, if applicable and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</p> <p>For <b>Generators</b> in respect of <b>OTSDUW</b> who are also <b>EU Code Users</b> details of <b>OTSDUW DC Converter</b> protection models as agreed between <b>The Company</b> and the <b>Generator</b> (in respect of <b>OTSDW</b>) and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</p>	Diagram			<b>DPD II</b>						
	Diagram			<b>DPD II</b>						

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 24 OF 24**

Data Description	Units	DATA to		Data Category	Operating configuration					
		CUSC Contract	CUSC App. Form		1	2	3	4	5	6
<b>LOADING PARAMETERS (PC.A.5.4.3.3)</b>										
MW Export from the <b>Offshore Grid Entry Point to the Transmission Interface Point</b>	MW/s	<input type="checkbox"/>		<b>DPD I</b>						
Nominal loading rate	MW/s	<input type="checkbox"/>			<b>DPD I</b>					
Maximum (emergency) loading rate										
Maximum recovery time, to 90% of pre-fault loading, following an AC system fault or severe voltage depression.	s	<input type="checkbox"/>		<b>DPD II</b>						
Maximum recovery time, to 90% of pre-fault loading, following a transient DC Network fault.	s	<input type="checkbox"/>		<b>DPD II</b>						

## SCHEDULE 19 – USER DATA FILE STRUCTURE

PAGE 1 OF 2

The structure of the **User Data File Structure** is given below.

i.d.	Folder name	Description of contents
<b>Part A: Commercial &amp; Legal</b>		
<b>A2</b>	Commissioning	Commissioning & Test Programmes
<b>A3</b>	Statements	Statements of Readiness
<b>A9</b>	AS Monitoring	Ancillary Services Monitoring
<b>A10</b>	Self-Certification	User Self Certification of Compliance
<b>A11</b>	Compliance statements	Compliance Statement
<b>Part 1: Safety &amp; System Operation</b>		
<b>1.1</b>	Interface Agreements	Interface Agreements
<b>1.2</b>	Safety Rules	Safety Rules
<b>1.3</b>	Switching Procedures	Local Switching Procedures
<b>1.4</b>	Earthing	Earthing
<b>1.5</b>	SRS	Site Responsibility Schedules
<b>1.6</b>	Diagrams	Operational and Gas Zone Diagrams
<b>1.7</b>	Drawings	Site Common Drawings
<b>1.8</b>	Telephony	Control Telephony
<b>1.9</b>	Safety Procedures	Local Safety Procedures
<b>1.10</b>	Co-ordinators	Safety Co-ordinators
<b>1.11</b>	RISSP	Record of Inter System Safety Precautions
<b>1.12</b>	Tel Numbers	Telephone Numbers for Joint System Incidents
<b>1.13</b>	Contact Details	Contact Details (fax, tel, email)
<b>1.14</b>	Restoration Plan	Local Joint Restoration Plan (incl. <u>System Restoration</u> if applicable)
<b>1.15</b>	Maintenance	Maintenance Standards
<b>Part 2: Connection Technical Data</b>		
<b>2.1</b>	DRC Schedule 5	DRC Schedule 5 – Users System Data
<b>2.2</b>	Protection Report	Protection Settings Reports
<b>2.3</b>	Special Automatic Facilities	Special Automatic Facilities e.g. intertrip
<b>2.4</b>	Operational Metering	Operational Metering
<b>2.5</b>	Tariff Metering	Tariff Metering
<b>2.6</b>	Operational Comms	Operational Communications
<b>2.7</b>	Monitoring	Performance Monitoring
<b>2.8</b>	Power Quality	Power Quality Test Results (if required)

## SCHEDULE 19 – USER DATA FILE STRUCTURE

PAGE 2 OF 2

<b>Part 3: Generator Technical Data</b>		
3.1	DRC Schedule 1	DRC Schedule 1 - Generating Unit, Power Generating Module, HVDC System and DC Converter Technical Data
3.2	DRC Schedule 2	DRC Schedule 2 - Generation Planning Data
3.3	DRC Schedule 4	DRC Schedule 4 – Frequency Droop & Response
3.4	DRC Schedule 14	DRC Schedule 14 – Fault Infeed Data – Generators
3.5	Special Generator Protection	Special Generator Protection e.g. Pole slipping; islanding
3.6	Compliance Tests	Compliance Tests & Evidence
3.7	Compliance Studies	Compliance Simulation Studies
3.8	Site Specific	Bilateral Connections Agreement Technical Data & Compliance
3.9	DRC Schedule 20	DRC Schedule 20 - Grid Forming Plant Data
<b>Part 4: General DRC Schedules</b>		
4.1	DRC Schedule 3	DRC Schedule 3 – Large Power Station Outage Information
4.2	DRC Schedule 6	DRC Schedule 6 – Users Outage Information
4.3	DRC Schedule 7	DRC Schedule 7 – Load Characteristics
4.4	DRC Schedule 8	DRC Schedule 8 – BM Unit Data (if applicable)
4.5	DRC Schedule 10	DRC Schedule 10 –Demand Profiles
4.6	DRC Schedule 11	DRC Schedule 11 – Connection Point Data
<b>Part 5: OTSDUW Data and Information</b> (if applicable and prior to <b>OTSUA Transfer Time</b> )		
		Diagrams Circuits Plant and Apparatus Circuit Parameters Protection Operation and Autoswitching Automatic Control Systems
		Mathematical model of dynamic compensation plant

**SCHEDULE 20 – GRID FORMING PLANT CAPABILITY DATA**

The following data need only be supplied by **Users** (be they a **GB Code User** or **EU Code User**) or **Non-CUSC Parties** who wish to offer a **Grid Forming Capability** as provided for ECC.6.3.19.3. Where such a **Grid Forming Capability** is provided then the following data items and models are to be supplied in respect of each **Grid Forming Plant**.

DATA DESCRIPTION		GRID FORMING PLANT DATA		
		1	2	3
Submission of <b>Network Frequency Perturbation Plot</b> and <b>Nichols Chart</b> for each <b>GBGF-I</b> (PC.A.5.8.1)	Graphs			
High level equivalent architecture diagram of Grid Forming Plant (PC.A.5.8.1)	Diagram			
<b>GBGF-I Grid Forming Plant Block Diagram</b> (Laplace Operator) in the general form shown in Figure PC.A.5.8.1 or as agreed with <b>The Company</b> .  When submitting either Figure PC.A.5.8.1 (a) or Figure PC.A.5.8.1 (b), each <b>User</b> or <b>Non-CUSC Party</b> can use their own design, that may be very different to Figures PC.A.5.8.1 (a) or PC.A.5.8.1 (b), but should contain all relevant functions that can include simulation models and other equivalent data and documentation	Block Diagram (Laplace Operator)  Documentation			
Each <b>User</b> or <b>Non-CUSC Party</b> shall provide a model of their <b>Grid Forming Plant</b> which provides a true and accurate reflection of its <b>Grid Forming Capability</b> .	Model and documentation – format to be agreed with <b>The Company</b>			

In order to participate in the **Grid Forming Capability** market, **User's** and **Non-CUSC Parties** are required to provide data of their **GBGF-I** in accordance with Figures PC.A.5.8.1(a) and PC.A.5.8.1(b) **Users** and **Non-CUSC Parties** in respect of **Grid Forming Plants** should indicate if the data is submitted on a unit or aggregated basis. Table 1 below defines the notation used in Figure PC.5.8.1

Parameter	Symbol	Units
-----------	--------	-------

The primary reactance of the <b>Grid Forming Unit</b> , in pu.	X <sub>in</sub> or X <sub>ts</sub>	pu on MVA Rating of <b>Grid Forming Unit</b>
The additional reactance, in pu, between the terminals of the <b>Grid Forming Unit</b> and the <b>Grid Entry Point</b> or <b>User System Entry Point</b> (if <b>Embedded</b> ).	X <sub>tr</sub>	pu on MVA Rating of <b>Grid Forming Unit</b>
The rated angle between the <b>Internal Voltage Source</b> and the input terminals of the <b>Grid Forming Unit</b> .		radians
The rated angle between the <b>Internal Voltage Source</b> and <b>Grid Entry Point</b> or <b>User System Entry Point</b> (if <b>Embedded</b> ).		radians
The rated voltage and phase of the <b>Internal Voltage Source</b> of the <b>Grid Forming Unit</b> .		Voltage - pu Phase - radians
The rated electrical angle between current and voltage at the input to the Grid transformer.		radians

Table 1

In order to participate in a **Grid Forming Capability** market, **User's** and **Non-CUSC Parties** are also required to provide the data of their **GBGF-I** in accordance with the Table below to **The Company**. The details and arrangements for **Users** and **Non-CUSC Parties** participating in this market shall be published on **The Company's Website**.

Quantity	Units	Range (where Applicable)	User Defined Parameter
Type of Grid form <b>Plant</b> (eg <b>Generating Unit, Electricity Storage Module, Dynamic Reactive Compensation Equipment</b> )	N/A		
Maximum Continuous Rating at <b>Registered Capacity</b> or <b>Maximum Capacity</b>	MVA		
Primary reactance X <sub>in</sub> or X <sub>ts</sub> (see Table 1)	pu on MVA		
Additional reactance X <sub>tr</sub> (See Table 1)	pu on MVA		
<b>Maximum Capacity</b>	MW		

<b>Active ROCOF Response Power</b> (MW) supplied or absorbed at 1Hz/s <b>System Frequency</b> change (which is the maximum frequency change for linear operation of the <b>Grid Forming Plant</b> )	MW		
<b>Phase Jump Angle Withstand</b>	degrees		60 degrees specified
<b>Phase Jump Angle limit</b>	degrees		5 degrees recommended
<b>Phase Jump Power</b> (MW) at the rated angle	MW		
<b>Defined Active Damping Power</b> for a <b>Grid Oscillation Value</b> of 0.05 Hz peak to peak at 1 Hz	MW		
The cumulative energy delivered for a 1Hz/s <b>System Frequency</b> fall from 52 Hz to 47 Hz This is the total <b>Active Power</b> transient output of the <b>Grid Forming Plant</b>	MWs or MJ		
<b>Inertia Constant (H)</b> using equation 1 or declared in accordance with the simulation results of ECP.A.3.9.4	MWs/MVA		
<b>Inertia Constant (He)</b> using equation 2 or declared in accordance with the simulation results of ECP.A.3.9.4	MWs/MVA		
Continuous Overload Capability	% on MVA		
Short Term duration Overload capability			
Duration of Short Term Overload Capability	s		
<b>Peak Current Rating</b>	pu		
Nominal <b>Grid Entry Point</b> or <b>User System Entry Point</b> voltage	kV		
<b>Grid Entry Point</b> or <b>User System Entry Point</b>	- Location		
Continuous or defined time duration MVA Rating	MVA		
Continuous or defined time duration MW Rating	MW		

For a <b>GBGF-I</b> the inverters maximum <b>Internal Voltage Source (IVS)</b> for the worst case condition – for example operation at maximum exporting <b>Reactive Power</b> at the maximum AC <b>System</b> voltage	pu		
Maximum Three Phase Short Circuit Infeed at <b>Grid Entry Point</b> or <b>User System Entry Point</b>	kA		
Maximum Single Phase Short Circuit Infeed at <b>Grid Entry Point</b> or <b>User System Entry Point</b>	kA		
Will the <b>Grid Forming Plant</b> contribute to any other form of commercial service – for example Dynamic Containment, Firm Frequency Response,	Details to be provided		
<b>Equivalent Damping Factor.</b>	$\zeta$		0.2 to 5.0 allowed

Table 2

$H = \text{Installed MWs} / \text{Rated installed MVA}$

(equation 1)

$H_e = (\text{Active ROCOF Response Power at } 1 \text{ Hz} / \text{s} \times \text{System Frequency}) / (\text{Installed MVA} \times 2)$

(equation 2)

<END OF DATA REGISTRATION CODE>