

Date: Monday 11 Apr 2022

BSUoS Charge Estimate: £8.28/MWh






Total Outturn: £9.57m

Daily Balancing Costs

nationalgridESO

BM Cost (Indicative)

AS Cost (Estimate)



Commentary

The market was short over the early hours to the early morning, and from the late afternoon to evening period. 300MW of STOR was run over the late afternoon to evening. Trades and BM Action supported overnight Voltage Control in the South East of England, Midlands, and the East of England. BM Action required overnight for System Inertia. BM Action managed thermal export constraints in Scotland from 10am onwards into the night. BM Action alleviated thermal export constraints in the East of England from the late afternoon onwards.