


Date: Wednesday 06 Apr 2022

BSUoS Charge Estimate: £8.76/MWh
Total Outturn: £10.44m





BM Cost (Indicative)

AS Cost (Estimate)



Daily Balancing Costs

nationalgridESO



Commentary

A short market overnight to the early morning, and from late afternoon onwards into the night. Interconnector Trades were required for Downward Regulation overnight.

Trades supported overnight Voltage Control in the Midlands, South East of England, and Wales area. BM Action and Trades required for System Inertia overnight and during the mid afternoon. BM Action alleviated thermal export constraints in Scotland and the North of England over the morning to the early afternoon. BM Action managed thermal export constraints in the East of England over the afternoon.