



Date: Monday 22 Aug 2022




BSUoS Charge Estimate: £5.86/MWh
Total Outturn: £6.22m

Daily Balancing Costs

BM Cost (Indicative)
AS Cost (Estimate)



- Energy Imbalance
- Positive Reserve (Op Res + STOR)
- Negative Reserve (Footroom)
- Frequency Control (Response + Fast Reserve)
- Other Reserve (Ancillary Costs Only)
- Constraints (BM & Trades only)
- Other (Reactive + Black Start + BM & AS General)



Commentary

The market was short in excess of 400MW in the afternoon. Multiple trades on the interconnectors were required between midnight and the evening for positive margin. For most of the day BM actions were undertaken to ease constraint in the south of England. From the evening, additional BM actions were required to solve power flow restrictions in Scotland.