

Date: Saturday 06 Aug 2022






BSUoS Charge Estimate: £9.68/MWh
Total Outturn: £8.28m

Daily Balancing Costs

nationalgridESO

BM Cost (Indicative)

AS Cost (Estimate)



Commentary

There were periods of short market in excess of 300MW between the early morning and the evening, and in excess of 600MW in the late evening. Multiple trades on the interconnectors were undertaken in the afternoon for downward regulation and in the evening for positive margin. From the afternoon wind generation in Scotland was bought off in the BM to ease the power flow restrictions due to high wind levels. Additionally, offers were accepted in the BM to manage the voltage levels in England.