

Date:

Friday 11 Nov 2022

BSUoS Charge Estimate: £20.59/MWh






Total Outturn: £24.96m

Daily Balancing Costs

nationalgridESO

BM Cost (Indicative)

AS Cost (Estimate)



Commentary

The market was mostly long throughout the day and then short from 7pm. Interconnector Trades were required for Margin during the morning and the afternoon period.

BM Actions managed thermal export constraints in Scotland and the North of England during the day, and also in the East of England and in the North West of England. Trades alleviated thermal import constraints in the South Coast and South East of England throughout the day. Overnight Voltage Control supported by Trades and BM Action. BM Action required in the morning for System Inertia.