






Date: **Thursday 24 Dec 2020**

BSUoS Charge Estimate: £3.18/MWh
Total Outturn: £4.16m

Daily Balancing Costs

- BM Cost (Indicative)
- AS Cost (Estimate)



Western Link status: Available

Commentary

The market was mostly short apart from a long position between 1:30 and 6:30am when trades were made for downward regulation. Small BMUs were used in the afternoon and evening.

Thermal constraints were active in Scotland between 6:00 and 8:00am. Trades and BM Actions were needed for RoCoF. An optional contract enactment, trades and BM actions were required for voltage control.