



Date: **Sunday 31 Jan 2021**




BSUoS Charge Estimate: £1.61/MWh
Total Outturn: £2.08m

Daily Balancing Costs

- BM Cost (Indicative)
- AS Cost (Estimate)



- Energy Imbalance
- Positive Reserve (Op Res + STOR)
- Negative Reserve (Footroom)
- Frequency Control (Response + Fast Reserve)
- Other Reserve (Ancillary Costs Only)
- Constraints (BM & Trades only)
- Other (Reactive + Black Start + BM & AS General)



Commentary

Throughout the 24 hours, the market was prevalently long. Overnight, a mix of BM actions and multiple trades on the interconnectors were undertaken to mitigate the RoCoF risk; additionally voltage levels in England were managed with offers accepted in the BM

Western Link status: Available