



Date: Thursday 11 Mar 2021




BSUoS Charge Estimate: £9.76/MWh
Total Outturn: £13.41m

Daily Balancing Costs

- BM Cost (Indicative)
- AS Cost (Estimate)



- Energy Imbalance
- Positive Reserve (Op Res + STOR)
- Negative Reserve (Footroom)
- Frequency Control (Response + Fast Reserve)
- Other Reserve (Ancillary Costs Only)
- Constraints (BM & Trades only)
- Other (Reactive + Black Start + BM & AS General)



Western Link status: Unavailable

Commentary

The market varied through the day. Trades were made for downwards regulation in the early morning. Demand out turned significantly lower than forecast overnight.

Constraints were active in Scotland and northern England for most of the day. Trades and BM Actions were used for RoCoF. An optional contract enactment, trades and BM actions were needed for voltage management.