


Date: **Tuesday 26 Oct 2021**

BSUoS Charge Estimate: £11.18/MWh


Total Outturn: £14.35m

BM Cost (Indicative)

AS Cost (Estimate)



Daily Balancing Costs



Energy Imbalance

Positive Reserve (Op Res + STOR)




Negative Reserve (Footroom)

Frequency Control (Response + Fast Reserve)

Other Reserve (Ancillary Costs Only)

Constraints (BM & Trades only)

Other (Reactive + Black Start + BM & AS General)



Commentary

The market alternated until approximately 4:00pm and remained long for the rest of the day.Trades were made for margin and downwards regulation during the morning.

Thermal constraints were active in Scotland for much of the day. Trades were made for RoCoF. An optional contract enactment, trades and BM actions were required for voltage management.