



Date: **Saturday 11 Sep 2021**

BSUoS Charge Estimate: £3.60/MWh
Total Outturn: £3.18m




Daily Balancing Costs

BM Cost (Indicative)

AS Cost (Estimate)



- Energy Imbalance
- Positive Reserve (Op Res + STOR)
- Negative Reserve (Footroom)
- Frequency Control (Response + Fast Reserve)
- Other Reserve (Ancillary Costs Only)
- Constraints (BM & Trades only)
- Other (Reactive + Black Start + BM & AS General)



Commentary

A short market for the very early morning and mostly long afterwards.

Thermal constraints were active in Scotland and the south of England during the afternoon. They remained active in Scotland into the evening. Trades and BM Actions were made for RoCoF. A contract enactment, trades and BM actions were required for voltage management.