

Date:


Friday 17 Sep 2021

BSUoS Charge Estimate: £2.71/MWh

Total Outturn: £2.51m


BM Cost (Indicative)

AS Cost (Estimate)






## Daily Balancing Costs

nationalgridESO



- Energy Imbalance
- Positive Reserve (Op Res + STOR)
- Negative Reserve (Footroom)
- Frequency Control (Response + Fast Reserve)
- Other Reserve (Ancillary Costs Only)
- Constraints (BM & Trades only)
- Other (Reactive + Black Start + BM & AS General)



### Commentary

A mostly long market until the late evening. Interconnector Trades required for Downward Regulation between 1am and 5am. 219MW of STOR was run around 10pm in the late evening. Interconnector Trades overnight for RoCoF. BM Action alleviated thermal export constraints in Scotland overnight to midday.