

Stage 02: Workgroup Consultation

Connection and Use of System Code
(CUSC)

CMP213 Project TransmiT TNUoS Developments

This proposal seeks to modify the CUSC so that the TNUoS charging methodology recognises that the impact on incremental transmission network cost varies for generators with different characteristics as well as location; that HVDC circuits that parallel the main transmission network are represented within the charging methodology; and to extend the charging methodology to include island transmission connections comprised of sub-sea cable technology.

This document contains the discussion of the Workgroup which formed in July 2012. Any interested party is able to make a response in line with the guidance set out in Section 10 of this document.

Published on: 07 December 2012
Length of Consultation: 25 Working Days
Responses by: 15 January 2013



High Impact:
Generators



Medium Impact:
None



Low Impact:
All other CUSC parties liable for TNUoS charges

What stage is this document at?

01	Initial Written Assessment
02	Workgroup Consultation
03	Workgroup Report
04	Code Administrator Consultation
05	Draft CUSC Modification Report
06	Final CUSC Modification Report

Contents

1	Summary	3
2	Why Change?	16
3	Solution – The Original Proposal	19
4	Summary of Workgroup Discussions on Sharing	27
5	Summary of Workgroup Discussions on HVDC	104
6	Summary of Workgroup Discussions on Islands	115
7	Impacts	132
8	Proposed Implementation.....	134
9	The Case for Change.....	139
10	How to Respond.....	140
	Annex 1 – Workgroup Terms of Reference	143
	Annex 2 – CMP213 Proposal Form.....	148
	Annex 3 – Workgroup Attendance Register	156
	Annex 4 – Project TransmiT Background.....	157
	Annex 5 – Detail of Original Proposal	165
	Annex 6 – ALF vs. Annual Incremental Cost Analysis	175
	Annex 7 – ALF and Changes to Plant Running Profiles.....	180
	Annex 8 – Comparison of Tariff Volatility.....	185
	Annex 9 – Annual Load Factor Under the Original	195



Any Questions?

Contact:

Jackeline Crespo-Sandoval

Code Administrator



jackeline.crespo-sandoval@nationalgrid.com



01926 653019

Proposer:

Ivo Spreeuwenberg

Company

National Grid

About this document

This document is a Workgroup consultation which seeks the views of CUSC and interested parties in relation to the issues raised herein. Parties are requested to respond by email to cusc.team@nationalgrid.com using the Workgroup Consultation Responses Proforma which can be found on the following link:

<http://www.nationalgrid.com/uk/Electricity/Codes/systemcode/amendments/current/amendmentproposals/>

Document Control

Version	Date	Author	Change Reference
1.0	07 December 2012	National Grid	Final Version

1 Summary

- 1.1 This document summarises the deliberations of the Workgroup and describes the CMP213 Modification Proposal, raised by National Grid Electricity Transmission (NGET) in fulfilment of the Project TransmiT Significant Code Review (SCR) Direction¹ issued by Ofgem (the Authority). It has been prepared in accordance with the terms of the Connection and Use of System Code (CUSC). An electronic copy can be found on the National Grid website, along with the CUSC Modification Proposal Form.

Background

- 1.2 Project TransmiT was the Authority's independent and open review of transmission charging and associated connection arrangements. The stated aim of Project TransmiT was to ensure that arrangements are in place to facilitate the timely move to a low carbon energy sector whilst continuing to provide safe, secure, high quality network services at value for money to existing and future consumers.
- 1.3 The charging element of the Project TransmiT process has involved reports from various academic experts and an industry SCR Technical Working Group followed by economic analysis undertaken on several different approaches to the calculation of Transmission Network Use of System (TNUoS) tariffs. This process led the Authority to rule out a socialised approach to charging and set out that incremental improvements to the existing Investment Cost Related Pricing (ICRP) approach were likely to represent the best way forward.
- 1.4 On the 25th of May 2012, the Authority directed NGET² to raise a modification proposal to the CUSC to ensure that the TNUoS methodology:
- i) Better reflects the costs imposed by different types of generators on the electricity transmission network (a.k.a. network **sharing**);
 - ii) Takes account of the development of **High Voltage Direct Current (HVDC) circuits** that will run parallel to the AC transmission network; and
 - iii) Takes account of potential **island connections** comprised of sub-sea cable technology, such as those currently being considered in Scotland.
- 1.5 CMP213 CUSC Modification Proposal was submitted to the CUSC Modifications Panel (the Panel) for their consideration on 29th June 2012. A copy of the CUSC Modification Proposal can be found in Annex 2.
- 1.6 The Panel determined that the CUSC Modification Proposal should be considered by a Workgroup and that they should report back to the CUSC Modifications Panel following a period for the Workgroup Consultation. Details of the CUSC Modification Proposal can be found in Section 2.

Workgroup Process and Consultation

- 1.7 The CMP213 Workgroup held their first meeting on the 10th of July 2012 and agreed the Terms of Reference on 24th of July 2012. A copy of the Terms of Reference is provided in Annex 1. Over the subsequent 16 meetings leading up to this consultation the Workgroup has considered the issues outlined in the CUSC Modification Proposal and worked through the Terms of Reference. The Workgroup have also considered potential options and alternatives to the Original proposal (i.e. the proposal submitted by NGET to the Panel on the 25th March 2012).

¹ <http://www.ofgem.gov.uk/Pages/MoreInformation.aspx?docid=234&refer=Networks/Trans/PT>

² <http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/Final%20direction%2025%20May%202012.pdf>

- 1.2 Following on from this consultation the Workgroup will: consider the views expressed in response; confirm the exact form of the CMP213 Original proposal; formally agree any Workgroup Alternative CUSC Modification(s) (WACM); carry-out a market analysis and environmental assessment; and assess the Original and any WACM(s) against the Applicable CUSC Objectives before submitting the Final Workgroup Modification Report to the CUSC Panel. The Workgroup will also provide the Panel with legal text to support the Original and any proposed Alternatives (subject to agreement with the Authority).
- 1.8 Finally, the CUSC Panel will consider if the Workgroup Terms of Reference have been met, and then agree that a consultation by the Code Administrator be undertaken on the CMP213 Original proposal, any WACM(s) and the associated legal text. The Panel will then vote and send the Final Modification Report (FMR) to the Authority for consideration and, if appropriate, approval.
- 1.9 The implementation date is decided by the Authority as part of any Direction (to NGET as code administrator) to implement a change to the CUSC. The Workgroup have considered a number of options in this respect and are seeking feedback through this consultation (see Section 8). The Workgroup have also considered the possible need for transitional arrangements to support timely introduction.
- 1.10 The Workgroup is seeking the views of CUSC Parties and other interested parties in relation to the scope of the group's deliberations and consideration of potential options and alternatives to date as set out in this Workgroup consultation, by 15th January 2013. Please see Section 10 for how to respond.

Rationale for CMP213

- 1.3 The underlying principle behind TNUoS charges is that efficient economic signals are provided to Users when services are priced to reflect the incremental costs of providing them. Therefore, charges should reflect the impact that Users of the transmission system at different locations would have on the Transmission Owner's costs, if they were to increase or decrease their use of the respective systems. The ongoing application of this rationale was supported by the conclusion of the TransmiT SCR process.
- 1.4 As a greater proportion of variable, renewable generation connects to the transmission network, the output of many conventional generators has also become more variable in nature. As generators of different technology types change the way in which they use the transmission network, the nature of transmission network investment planning has also altered to ensure efficient investment is undertaken. This is exemplified in the recent changes to the National Electricity Transmission System Security and Quality of Supply Standards – NETS SQSS (GSR-009³) and the increasing amount of transmission investment justified on the basis of avoided future constraint costs (i.e. outside of the deterministic NETS SQSS standards) using cost benefit analysis methods.
- 1.5 These changes in transmission network investment planning, implying increased sharing of transmission capacity by generators with different characteristics, have yet to be reflected into the Investment Cost Related Pricing (ICRP) methodology used to calculate TNUoS tariffs. This change in approach for investment in network capacity driven by generators does not affect network investment for demand.

³ <http://www.ofgem.gov.uk/Pages/MoreInformation.aspx?docid=26&refer=Networks/Trans/ElecTransPolicy/SQSS>

- 1.6 Linked to the aforementioned changes is the proposed use of transmission network technologies not currently in widespread application across the system. In order to improve predictability of future TNUoS tariffs and ensure the methodology used to calculate tariffs incorporates these HVDC and sub-sea technologies in a cost reflective manner, updates are required.
- 1.7 In line with the Direction from the Authority, and as set out in paragraph 1.4, the CMP213 modification proposal is comprised of three aspects addressing the issues outlined above. These aspects are designed to enhance the cost reflectivity of the charging methodology, keep it in line with developments in the transmission system and hence promote effective competition in the electricity market.

High Level Summary of the Original and Workgroup Discussions

- 1.8 The three aspects of the Original proposal are summarised in Table 1.

Summary of Original Proposal	
1. Sharing – Improving the incremental cost signal	
i) Alignment with changes to the NETS SQSS	When calculating background power flows: <ul style="list-style-type: none"> - split Transport model into 2 backgrounds; Peak Security and Year Round; - scale generation to meet demand using NETS SQSS approach for each.
ii) Differentiation between generators based on characteristics as well as location	When calculating incremental costs: <ul style="list-style-type: none"> - circuits allocated to one background or the other based on highest flows (commensurate with planning); - two wider locational tariff elements representing the 2 Transport model backgrounds; - intermittent generation not exposed to the Peak Security element; - Year Round element scaled by a sharing factor (based on generator specific load factor).
2. HVDC Circuits – Including these circuit types into the methodology	
i) Incremental power flow calculation	When calculating background power flows: <ul style="list-style-type: none"> - model HVDC circuit as pseudo-AC circuit; - calculate HVDC circuit flow by apportioning flows with parallel AC circuits, using relative circuit ratings; - average flows across all major system boundaries crossed by the HVDC circuit; - set impedance of the HVDC circuit to achieve this flow.
ii) Expansion Factor (unit cost) calculation	When calculating expansion factors: <ul style="list-style-type: none"> - include both converter station costs and cable costs; - create a unique value for each HVDC circuit.
3. Island Connections – Including these sub-sea connections into the methodology	
i) Local / Wider definition	When classifying island nodes as part of the MITS: <ul style="list-style-type: none"> - utilise the existing definition; - take account of reduced security, where relevant.
ii) Expansion Factor (unit cost) calculation	When calculating expansion factors: <ul style="list-style-type: none"> - create a specific expansion factor for each AC technology; - for HVDC connections maintain consistency with HVDC approach set out above.

Table 1 – Summary of Original Proposal

- 1.9 Each aspect of the modification proposal is set out in more detail, below.

(i) Sharing

- 1.10 The sharing aspect of the Original proposal seeks to enhance the cost reflectivity of the incremental cost signal for generation tariffs by incorporating recent changes to the NETS SQSS in the model used to calculate that signal. These changes would see the wider locational element of TNUoS tariffs calculated on 2 separate backgrounds, Peak Security and Year Round. The scaling of generation to meet demand in these two backgrounds is representative of that used when planning the network.
- 1.11 Incremental costs on a particular circuit would be allocated to one background or the other, depending on which one is deemed to trigger the need for incremental capacity. It is proposed that this trigger is the background leading to the highest power flows on the circuit in question, consistent with the network planning approach.
- 1.12 When calculating charges for a specific generator the wider locational TNUoS tariff is split into two elements arising from the Peak Security and Year Round backgrounds in the charging model.
- 1.13 As investment in transmission capacity is currently not planned for intermittent generation under peak electricity demand conditions, intermittent plant would not be exposed to the Peak Security element of the tariff. However, exposure would be linked to the treatment of this type of generation in the NETS SQSS at times of peak electricity demand. (i.e. currently none, but this could change in future).
- 1.14 In order to enhance the existing distance related signal and differentiate between the incremental impact of generation with different characteristics in a simple and transparent manner the Year Round element of the tariff would be multiplied by a sharing factor based on the annual load factor of a generator. This approach recognises the myriad of generation characteristics that have an effect on incremental costs (e.g. fuel price, efficiency, availability, CO₂, subsidies, bid price, offer price, etc.), but opts for a simple proxy in the form of annual load factor which is a representative manifestation of all these characteristics.
- 1.15 The resulting tariff for conventional and intermittent generation would be of the form illustrated in Figure 1.




Figure 1 – TNUoS tariffs under the Original proposal

- 1.16 The Workgroup discussed and debated the Original proposal for Sharing in detail and have begun to develop several options and alternatives based on the considerations set out in the terms of the Authority's SCR Direction and the specific requests from the CUSC Panel.
- 1.17 The main aspects of these discussions and developments are set out in Table 2, below.

1. Sharing – Main Areas of Workgroup Discussion

i) How charging structures should be applied in areas dominated by one type of generation	<ul style="list-style-type: none"> - The Original proposal would apply the sharing factor equally to the Year Round element for all wider locational tariffs. - Discussion centred on analysis undertaken by the group in areas with little diversity of generation plant types. - Potential options and alternatives arising from this analysis would recognise that the relationship between impact on incremental costs and a generator's annual load factor deteriorates in areas with insufficient non-low carbon thermal generation (due to its bid price characteristics). - Potential options and alternatives were also discussed for negative charging zones and the possible application of the principles set out in the Original (or a variation thereof) to local circuits and island connections in general.
ii) How the sharing factor (based on annual load factor) should be calculated	<ul style="list-style-type: none"> - The Original proposal would calculate the sharing factor based on 5 years historic load factor (using metered output), removing the highest and lowest and averaging the remaining three values. - Discussion centred on what the sharing factor should represent in order to be cost reflective. Some believed that it should reflect network planning assumptions, whilst others believed that it should reflect system usage. - Potential options and alternatives were discussed based on calculating the sharing factor ex-ante or ex-post, whether it should be based on historic or forecast information and whether it should be plant specific or generic.
iii) Whether intermittent technology types should be exposed to the peak element of the tariff	<ul style="list-style-type: none"> - The Original proposal would calculate a two part wider locational tariff including Peak Security and Year Round elements, with intermittent generation not being exposed to the Peak Security element to be consistent with the NETS SQSS. - Discussion centred on what the level of exposure of intermittent plant should be to this tariff element if it was not based on its assumed contribution to the need for network capacity in the planning standards. - Potential options and alternatives were discussed based on some exposure, but the majority of the Workgroup concluded that exposure should be linked to the NETS SQSS assumptions.

Table 2 – Main Areas of Workgroup Discussion for Sharing

1.18 Despite its relative outward simplicity, the Original proposal and its use of a sharing factor based on annual load factors is based on underlying concepts that can be difficult to conceptualise for non-transmission experts. As such the Workgroup spent a considerable amount of time discussing, debating and challenging the Original proposal in this area.

1.19 This debate was predominately focussed on where the boundary between shared and non-shared circuits occurred on the transmission network (deemed to be at MITS nodes, i.e. across the wider network, in the Year Round element of the Original) and on how the sharing factor could be calculated.

1.20 The aforementioned debate resulted in a number of strands of analysis, particularly into the issue of the boundary between shared and non-shared circuits. Both the NGET Electricity Scenario Illustrator model and a separate generic market model were used to investigate the robustness of the relationship between annual load factor and annual incremental costs in areas with little or no diversity of generation plant type.

- 1.21 Views in the Workgroup were split between those who believed that the balance between cost reflectivity and simplicity of the tariff calculation was optimum in the Original proposal (i.e. using the MITS definition as the boundary) and those who believed that the deterioration in the relationship between annual load factor and annual incremental costs in areas with little diversity was such that a potential alternative approach was required.
- 1.22 Three broad methods were developed by the Workgroup to address the issue of generation plant diversity (and the underlying issue of bid price diversity) as potential options and alternatives. These are summarised in Table 3, below.

Area	Original	Method 1	Method 2	Method 3
	All wider Year Round (YR) shared	YR zonal shared / not shared split	YR zonal shared / not shared split	Single background with zonal sharing factor
Dual background	Yes	Yes	Yes	No
Wider locational tariff components	2	3	3	1
MITS sharing	All YR incremental costs	YR split into shared / not shared	YR split into shared / not shared	All incremental costs with zonal sharing factors
Application of generator specific sharing factor	Yes	Yes; to shared element	Yes; to shared element	No
Diversity calculation	None	Based on deterministic relationship between low carbon / carbon ratio	Based on minimum of low carbon / carbon generation in an area	Based on minimum of low carbon / carbon generation in an area
Method for split of Incremental Costs	None	Zonal boundary length using boundaries of influence	Zonal boundary length using boundaries of influence	Zonal boundary length using boundaries of influence

Table 3 – Potential options and alternatives to address diversity

1.23 The main distinguishing factors between the methods developed include whether or not a 2 background approach is utilised as the starting point of the calculation and how “zonal boundary lengths” (set out in paragraphs 4.123 to 4.134) could be split into shared and non-shared elements based on a pre-determined diversity calculation. This approach would then either lead to a 2 part (Peak Security + Year Round) or 3 part (Peak Security + Year Round_{SHARED} + Year Round_{NON-SHARED}) wider locational element of the TNUoS tariff for generators. Finally, the methods distinguish further whether a generator specific sharing factor would apply to the shared elements or whether a zonal average sharing factor would be applied.

1.24 The Workgroup also spent some time investigating the potential application and implications for negative charging zones. Some in the group believed that methods developed for diversity would also apply to these areas of the network in some manner.

- 1.25 Additional analysis was also undertaken by external experts investigating the potential for counter correlation between different renewable generation types on the Scottish islands. This analysis was brought to the Workgroup at a stage in the process where a limited amount of debate and development could occur on the results presented to the group prior to the publication of this consultation, so this is considered to be an area of work in progress by the group.
- 1.26 Nevertheless, the results presented appeared to demonstrate that where wind, wave and tidal generators are co-located on a Scottish island the combined output of these generators would rarely reach the full installed capacity of that generation. Some in the Workgroup believed that the analysis demonstrated that there is likely to be an economic case for building local circuits that are sized under the combined rated capacity of generators using the circuits and that this case holds for intermittent, renewable generators sharing access to a local circuit.
- 1.27 Views of the Workgroup were split as to whether the aforementioned results were evidence of sharing occurring on local circuits or whether these results pointed to the ability of generators to request a TEC lower than their installed capacity. Detailed consideration of the factors affecting Transmission Owner investment decisions and the differences between the planning and charging of local circuits was undertaken with no clear conclusions.
- 1.28 Several methods were considered by the Workgroup for reflecting generation sharing on local transmission circuits, where it was demonstrated that sharing would occur due to explicit counter correlation of the generators in question:
- i) Add a sharing component to the local circuit TNUoS charge by applying the sharing factor (based on Annual Load Factor) to any calculated tariff;
 - ii) Add a sharing component to the local circuit TNUoS tariff that is calculated on a specific amount of calculated sharing;
 - iii) Establish a new designation of “shared local” and apply a sharing factor to the local circuit TNUoS tariff; and
 - iv) Establish a new designation of “island local” and apply a sharing factor to the local circuit TNUoS tariff.
- 1.29 When considering how the proposed sharing factor (based on annual load factor) should be calculated the views of the Workgroup were split between those who believed that this factor should be based on an average of five years of historic metered data (with the highest and lowest factors removed) or a more generic factor as reasonably reflective of transmission network planning assumptions and as a simple, predictable and transparent approach and those who believed that the potential for enhanced cost reflectivity from a more dynamic, potentially forecast factor, would outweigh the benefits of simplicity, predictability and transparency.
- 1.30 The potential issues with the various approaches set out above were explored in detail and the Workgroup developed several methods as potential alternatives for dealing with the calculation of the sharing factor (or annual load factor – ALF), as set out in Table 4, below.

Method	ALF	Description	Updated when?
i	TEC (MW)	ALF=100%; same result as approach used in existing charging methodology.	TEC register
ii	NETS SQSS generic	Generation plant based load factors from GSR-009	NETS SQSS updates
iii	Other generic	Generic historical average per generation plant type	At each Transmission Price Control Review
iv	User forecast	Ex-ante annual forecast, provided by the User, with ex-post reconciliation	Annually
v	Hybrid	Original proposal with option for User to provide own forecast (as per (iv))	Annually

Table 4 – Potential options and alternatives for calculating the sharing factor

- 1.31 When considering if intermittent generation plant types (e.g. wind generation) should be exposed to the Peak Security element of the proposed two part tariff in the Original, some in the Workgroup believed that there should be some exposure to this tariff element. The majority of the Workgroup agreed that, as intermittent generation are currently not considered when planning the need for transmission network capacity for Peak Security, there is little justification for exposure to this tariff element.
- 1.32 Nevertheless, the Workgroup believed that any wording in the methodology for this aspect should link the exposure of intermittent plant to the Peak Security element of the tariff to the NETS SQSS planning assumptions so that they remain consistent.
- 1.33 A range of other potential options and alternatives were considered by the Workgroup through their discussions. These included anticipatory application of the sharing options and the application of a sharing factor to the residual element of the tariff, to name a few. A full account of the Workgroup deliberations on the sharing aspect of the modification proposal is set out in Section 4 of this consultation.

(ii) HVDC

- 1.34 The HVDC aspect of the Original proposal seeks to ensure that HVDC circuits paralleling the AC network are included in the charging calculation in a cost reflective manner. As this technology is not currently in use on the wider network and represents an active, rather than passive (as in AC), network element, the Original proposal deals with both the incremental power flow calculation and expansion factor calculation for these HVDC circuits.
- 1.35 The incremental cost signal in TNUoS is calculated using a load flow model of the network. The Original proposal would model an HVDC circuit by adjusting its impedance in the load flow in order to achieve a pre-determined power flow through it in the base case.
- 1.36 In order to calculate the predetermined power flow, the ratings of all transmission circuits that cross each main system boundary paralleled by the HVDC circuit individually are summed, excluding the HVDC circuit itself. Subsequently, the power flow across each transmission boundary without

any flow on the HVDC circuit would be used to produce a ratio of power flow to boundary total circuit rating. These ratios can be used to calculate an average for all transmission boundaries that the HVDC circuit crosses.

- 1.37 As set out above, this average power flow to total circuit rating figure is used to set the impedance of the HVDC circuit to produce the power flow that gives this ratio to the HVDC circuit rating. This calculation has a direct impact on the incremental cost signal.
- 1.38 In addition, the Original proposal would calculate a unique expansion factor for each HVDC circuit on the system. In calculating this expansion factor both the converter station and cable costs would be included in the unit costs, consistent with the existing offshore arrangements.
- 1.39 The Workgroup discussed and debated the Original proposal for HVDC circuits in detail and have developed some options and alternatives based on the considerations set out in the terms of the Authority's SCR Direction and the specific requests from the CUSC Panel.
- 1.40 The main aspects of these discussions and developments are set out in Table 5, below.

2. HVDC Circuits – Main Areas of Workgroup Discussion	
i) Incremental power flow calculation	<ul style="list-style-type: none"> - The Original would calculate circuit impedance based on setting the power flow through the circuit in the base case as a ratio of relative circuit ratings, averaged across all major system boundaries crossed by the HVDC circuit. - There was minimal discussion on this issue within the Workgroup as the majority of members supported this approach. - Some Workgroup members believed a potential alternative would be for the power flow setting to take place as a ratio of relative circuit ratings on the single most constrained boundary crossed by the HVDC circuit.
ii) Expansion Factor (unit cost) calculation	<ul style="list-style-type: none"> - The Original would calculate unique expansion factors for each individual HVDC circuit including both converter and cable costs. - Discussion centred on what aspects of the AC/DC converter costs should be included in the unit cost calculation. - Potential options and alternatives were discussed based on treatment of HVDC as AC onshore technology unit costs, removal of all converter costs and removal of a portion of converter costs.

Table 5 – Main Areas of Workgroup Discussion for HVDC

- 1.41 Relative to the other aspects of the Original proposal the Workgroup discussion on HVDC circuits was relatively straightforward.
- 1.42 The Workgroup agreed that the modelling of an HVDC circuit as a pseudo-AC circuit, representing it as a circuit with impedance in the load flow used to calculate incremental cost signals, was appropriate. The Workgroup also agreed with the approach of using a ratio of relative circuit ratings across major system boundaries in order to calculate that impedance.
- 1.43 Some members of the Workgroup believed that, rather than taking an average of all the major system boundaries that the HVDC circuit crosses, the ratio of relative circuit ratings should be used on the single most constrained major system boundary on the basis that they believed the definition of the number of boundaries to be an arbitrary one. The group noted that this would increase the effect of the HVDC circuit on the incremental cost signal.

1.44 The Workgroup spent some time debating and developing potential options and alternatives to the calculation of expansion factors for HVDC circuits. The following methods were developed by the Workgroup to address this issue:

- 1) Removal of all converter costs from the expansion factor calculation on the basis that including them was seen by some Workgroup members as targeting an excessive amount of cost at those who benefit from the HVDC circuit and that this may also prevent a number of low carbon generators from connecting and contributing to UK sustainability targets.
- 2) Removal of some converter costs from the expansion factor calculation on the basis that:
 - a) a significant proportion of the converter costs (~50%) could be deemed as akin to other AC substation elements not currently included in the incremental cost signal;
 - b) a proportion of the converter costs (~10%) could be discounted on the basis that the converters bring benefits akin to Quadrature boosters that re-direct power flows on the network and thus allow for maximum utilisation of existing capacity.
- 3) Treatment of HVDC unit costs as existing AC network unit costs on the basis that some Workgroup members believed that the similarities in cost and incremental capacity provided by these two different elements of network technology were sufficient that they should not be differentiated in the methodology.

1.45 Some further work is being undertaken to assess the benefits to the System Operator of Voltage Source Converter technologies relative to Current Source Converter and whether it would be appropriate for this to be taken into account in TNUoS tariffs.

1.46 Other potential options and alternatives were considered by the Workgroup through their discussions. These included a review of the overhead factor used in the annuity calculation for the capital costs of various technologies and the global security factor. A full account of the Workgroup deliberations on the HVDC circuit aspect of the modification proposal is set out in Section 5 of this consultation.

(iii) Island connections

1.47 The Scottish Island connections aspect of the Original proposal seeks to put in place a methodology for calculating cost reflective TNUoS charges for transmission spurs connecting generation and demand between the Scottish mainland and the Scottish islands of Western Isles, Orkney and Shetland. The sub-sea network technologies proposed for these connections are not currently included in the expansion factors set out in the methodology.

1.48 The Original proposal would calculate new expansion factors for each type of transmission network technology proposed. Where such circuits are comprised of HVDC technology, the methodology would be consistent with that for HVDC circuits paralleling the AC network as set out above.

1.49 The Original proposal would not alter the definition of a MITS node (i.e. connected via more than 4 transmission circuits or 2 transmission circuits + a Grid Supply Point). The consequence is that, with the connections currently proposed, some circuits connecting islands to the mainland would be classed as 'local' and others would be classed as 'wider'.

1.50 In addition, the Original proposal would address circumstances where reinforcement creates a MITS node such that the island connection would

become part of the wider tariff, but where a significant proportion of the circuit has no redundancy. Rather than apply the current GB average cost of security, the Original proposal applies the actual level of security to the tariff calculation.

1.51 Any potential for the application of the sharing aspect of the modification proposal is set out in the sharing section of the consultation. However, as the sharing aspect of the Original proposal assumes that sharing occurs implicitly across the wider transmission network, generators connected to nodes on islands classed as part of the Main Interconnected Transmission System (MITS) for TNUoS charging purposes would pay a two part tariff, including the sharing factor (based on the generator's annual load factor), associated with this aspect of the Original proposal.

1.52 The Workgroup discussed and debated the Original proposal for Scottish Island connections in detail and have begun to develop several options and alternatives based on the considerations set out in the terms of the Authority's SCR Direction and the specific requests from the CUSC Panel.

1.53 The main aspects of these discussions and developments are set out in Table 6, below.

3. Islands – Main Areas of Workgroup Discussion	
i) Local / Wider definition	<ul style="list-style-type: none"> - The Original proposal would utilise the existing definition of MITS (i.e. local and wider) with some island connections likely forming part of the wider tariff under this approach. - In this situation, the Original would apply a two part wider locational tariff to island generators (i.e. Peak Security and Year Round) and the sharing factor would be applied to the Year Round element. - Discussion centred on whether Scottish island connection nodes should be classed as MITS, given their characteristics, and whether, if they were classed as MITS, it was right that the sharing factor was automatically applied. (the sharing aspect of the debate is covered under the sharing section, above) - Potential options and alternatives were discussed based on using the unique characteristics of sub-sea island connections to define them as non-MITS (i.e. local) and on an anticipatory application of the MITS definition. - There was agreement amongst Workgroup members that the global security factor should not be applied to portions of island connections that have no redundancy (where island nodes are classed as MITS).
ii) Expansion Factor (unit cost) calculation	<ul style="list-style-type: none"> - The Original proposal would calculate specific expansion factors for each AC technology and for each individual HVDC circuit. - Discussion centred on whether generic or specific expansion factors would be most appropriate. - Potential options and alternatives were debated based on using fully generic, partially generic and specific expansion factors.

Table 6 – Main Areas of Workgroup Discussion for Islands

1.54 Whilst debating the scenario where an island connection node becomes part of the Main Interconnected Transmission System (MITS) for charging purposes, the group considered whether the application of a two part tariff and associated sharing factor would be robust.

1.55 The Workgroup agreed that, where an island connection node is classed as MITS, there would be no justification for not applying a two part wider tariff to island generators. However, the view of the Workgroup on the application of the sharing factor proposed under the Original was split between those that did not believe this posed a problem and others who believed that some form

of alternative addressing diversity of generation plant type would be required in order to maintain an acceptable balance between the cost reflectivity and simplicity of the tariff calculation.

1.56 Some Workgroup members also believed that the potential options and alternatives still under development utilising counter-correlation of generation, set out under the sharing aspect of the proposal, could be applied to address this situation.

1.57 The Workgroup also considered what would be required in order to incorporate island connections into the methodology under potential alternatives where all island connections were classed as wider, all island connections were classed as local and where the existing definitions were maintained. The majority of the Workgroup were in favour of maintaining the existing definitions.

1.58 When considering how expansion factors should be calculated for island connections the group debated a range of methods between fully generic and project specific. The Workgroup also developed several methods as potential alternatives for dealing with the calculation of expansion factors.

1.59 These methods and the relevant pros and cons of each from the perspective of some Workgroup members are set out in Table 7, below (note that these have not necessarily been assessed against the relevant CUSC objectives).

Expansion Factor Methods	Pros	Cons
Original proposal – Project specific (actual cost of the transmission project is used as basis for EF)	<ul style="list-style-type: none"> Fully cost reflective Stable once set Could only benefit from potential drop in price of transmission asset when EF updated for new projects 	<ul style="list-style-type: none"> No opportunity to average costs across all Users as in the wider transmission network All costs included in the locational signal Cannot know TNUoS until very close to the time of build
i) Fully generic – e.g. based on and linked to onshore 132kV underground cable or other	<ul style="list-style-type: none"> Tariffs predictable ahead of transmission project-specific costs. 	<ul style="list-style-type: none"> Does not reflect unit costs of transmission assets used Less cost reflective than specific (i.e. Original) Could be based on generic HVDC costs.
ii) Generic across relevant technologies – e.g. one for island AC and one generic for DC	<ul style="list-style-type: none"> More cost reflective than generic (i) Tariffs more predictable than Original ahead of transmission project specific costs 	<ul style="list-style-type: none"> Less cost reflective than specific (i.e. Original) Equivalent to treatment in onshore wider and local if also differentiates across voltage types
iii) Island or Island Group specific , but not transmission project specific – e.g. actual cost of cables to the Islands aggregated or averaged over all projects and islands in the 'group' or certain cost elements specifically removed.	<ul style="list-style-type: none"> More cost reflective than generic (i) and (ii) Would allow island-specific factors to be incorporated for potential alternatives For second and subsequent transmission cables – more chance of predicting TNUoS 	<ul style="list-style-type: none"> Less cost reflective than specific (i.e. Original) Limited opportunity to average-out a very high single transmission asset cost Generators on first cable cannot know TNUoS until very close to the time of transmission build Some Islands or projects could subsidise others

Table 7 – Potential options and alternatives for calculating island expansion factors

- 1.60 The Workgroup also discussed the potential for an anticipatory application of the MITS definition to island connection nodes where the System Operator believed that these nodes could become part of the MITS at some point in the future. Some members of the Workgroup did not believe that there was a suitably robust reason for why this approach would be appropriate. Others considered that this approach may have benefits and could be justified.
- 1.61 A full account of the Workgroup deliberations on the island connections aspect of the modification proposal is set out in Section 6 of this consultation.

2 Why Change?

- 2.1 This CMP213 Modification Proposal was submitted in order to fulfil the requirements of the Direction issued to NGET by the Authority, arising from the Project TransmiT (TNUoS) SCR process. In line with that Direction, there are three main aspects making up this proposal:
- i) Better reflection of the incremental costs imposed by different types of generators on the electricity transmission network within the Investment Cost Related Pricing (ICRP) TNUoS tariff calculation (i.e. network sharing);
 - ii) Introduction of an approach for including High Voltage Direct Current (HVDC) transmission circuits that parallel the AC transmission network into the TNUoS charging methodology; and
 - iii) Introduction of an approach for including island connections comprised of sub-sea cable technology such as those proposed for the Western Isles, Orkney and Shetland into the TNUoS charging methodology.
- 1.62 In accordance with the Project TransmiT SCR Direction, CMP 213 is designed to help ensure that appropriate arrangements are in place to facilitate the timely move to a low carbon energy sector whilst continuing to provide safe, secure, high quality network services at value for money to existing and future consumers.
- 2.2 In accordance with the relevant CUSC objectives, CMP213 seeks to enhance the cost reflectivity of the TNUoS charging methodology, to keep it in line with developments in the transmission system and hence promote effective competition in the electricity market. These aspects are aligned with the relevant CUSC objectives for Section 14 (i.e. the Use of System Charging Methodology).
- 2.3 In their Direction to NGET the Authority also required that the CUSC Modification Proposal developed pursuant to the Direction should maximise value for money to existing and future consumers, be supported by a robust evidence base and in so doing give due consideration to the interests of existing and future consumers in the achievement of sustainable development.
- 2.4 The transmission network sharing aspect of the proposal incorporates developments in planning the transmission network – namely changes to the National Electricity Transmission System Security and Quality of Supply Standards (NETS SQSS), which specify technological differences in background conditions for transmission network planning studies; as well as the increasing use of Cost Benefit Analysis to supplement the more deterministic NETS SQSS.
- 2.5 These aforementioned changes to the planning of electricity transmission network investments are largely driven by increasing volumes of variable (largely low carbon) electricity generation sources in order to meet legally binding government renewable and green house gas emission targets. As these variable sources are supported by conventional, thermal generation in meeting electricity demand at times when variable sources are unavailable, the total installed capacity of generation over and above peak electricity demand increases, leading to the need for developments in the methodologies for planning the transmission network.
- 2.6 Time bound government renewable and green house gas emissions targets have also led to the rapid development of variable sources of generation, often at the extremities of the transmission network where renewable resources are in greater supply. This has led to the need for new and the

innovative use of existing transmission technology in order to develop the network in the most cost effective manner. The HVDC circuit and Scottish island connection aspects of the proposal seek to expand the existing TNUoS charging methodology so that it is fit for purpose for these new developments in the transmission system.

- 2.7 The reasoning behind each of the three aspects of the CMP213 Modification Proposal is set out in more detail below.

i) Network Capacity Sharing

2.8 In addition to recovering allowed revenue, Transmission Network Use of System (TNUoS) charges reflect the cost of installing, operating and maintaining the transmission system for the Transmission Owner (TO) activity functions of each GB Transmission Licensee. These activities are undertaken to the standards prescribed by the Transmission Licences (specifically the NETS SQSS), to provide the capability to allow the flow of bulk transfers of power between connection sites for conditions expected to arise over a year of operation and to provide transmission system security.

2.9 The underlying principle behind TNUoS charges is that efficient economic signals are provided to Users when services are priced to reflect the incremental costs of providing them. Therefore, charges should reflect the impact that Users of the transmission system at different locations would have on the Transmission Owner's costs, if they were to increase or decrease their use of the respective transmission systems.

2.10 This rationale is currently accounted for using the Investment Cost Related Pricing (ICRP) methodology which considers the incremental effect of generation and demand via a DC⁴ load flow (DCLF) based "Transport" model. The derivation of the incremental investment costs at different points on the transmission system is currently determined against the requirements of that system at the time of peak demand with all generation scaled uniformly to meet that demand.

2.11 As a greater proportion of variable, renewable generation connects to the transmission network, the output of many conventional generators has also become more variable in nature. As generators of different technology types change the way in which they use the transmission network, the nature of transmission capacity investment planning has also altered to ensure efficient investment is undertaken. This is exemplified in the recent changes to the NETS SQSS (GSR-009⁵) and the increasing amount of transmission investment justified on the basis of avoided future constraint costs (i.e. outside of the deterministic NETS SQSS standards) using cost benefit analysis methods. However, the associated commercial arrangements have yet to fully evolve to reflect these underlying physical changes to the transmission system.

2.12 The industry began a process of reviewing the commercial framework to reflect the aforementioned changes through the Transmission Access Review (TAR) process from 2007 to 2010. Through this process, the possibility of explicitly recognising the differential impact on transmission network costs by generators with different characteristics in terms of (i) charging and (ii) access arrangements was considered. However, this process culminated in the Secretary of State rejecting this explicit recognition in favour of a form of Connect and Manage. As a result, this CMP213 Modification Proposal does not propose to alter the form of transmission

⁴ Note that in this context DC does not refer to direct current as used in HVDC, but rather is industry parlance for the simplified methodology used for calculating the load flow.

⁵ <http://www.ofgem.gov.uk/Pages/MoreInformation.aspx?docid=26&refer=Networks/Trans/ElecTransPolicy/SQSS>

access rights afforded to generators (in the form of Transmission Entry Capacity - TEC) through the UK Government's decision. Rather, it seeks to improve the cost reflectivity of TNUoS tariffs for generators by implicitly recognising that this sharing takes place and is taken into account in an equally implicit manner in the transmission network investment planning process.

- 2.13 This CMP213 proposal seeks to recognise the implicit sharing of the wider transmission network (local circuits are generally not planned on the basis of being shared and are therefore not deemed to be shared in the Original) by altering the way in which the wider TNUoS tariff is calculated within the Transport and Tariff model as it is believed that this would improve its cost reflectivity.

ii) Inclusion of parallel HVDC circuits

- 2.14 When calculating the wider TNUoS tariff utilising the ICRP Transport and Tariff model, various AC transmission technologies are modelled in the load flow element. This is done in order to reflect the various unit costs of these transmission technologies into the calculation of the locational signal. Whilst overhead lines and cables of different voltage levels are included, no High Voltage Direct Current (HVDC) technology, outside of the offshore charging methodology, is currently taken account of in the load flow model (Offshore assets are not included in the load flow due to their radial nature). With the first of two planned HVDC circuits committed⁶, the need to be able to suitably represent these links in the TNUoS charging methodology is imminent.

- 2.15 Power flows on the existing AC transmission network are dictated by the relative impedance of the individual network components (such as overhead lines and cables). These power flows are replicated in the load flow aspect of the TNUoS tariff calculation. However, in the case of HVDC transmission circuits that parallel the AC transmission network, the power flow is controllable and not dictated solely by the impedance characteristic and therefore to include HVDC in the load flow aspect assumptions need to be made on how much power will flow on the HVDC transmission circuits relative to the rest of the AC transmission network

iii) Inclusion of sub-sea island connections

- 2.16 An approach for calculating cost reflective TNUoS charges for transmission spurs connecting generation and demand and comprised of transmission network technology not included in the expansion factors set out in clause 14.15.47 and 14.15.49 of the CUSC (i.e. sub-sea cables); such as those which may be established between the Scottish mainland and the Scottish islands of the Western Isles, Orkney and Shetland; is not currently included in the TNUoS charging methodology.

- 2.17 In addition as the Scottish islands are, for the most part, not currently connected to the electricity transmission network and the transmission network technology, in the form of sub-sea cables, is not in wide spread use across the existing transmission network there is a significant amount of uncertainty faced by developers of generation projects on these islands. Inclusion of transmission network circuits with the characteristics of the proposed Scottish island links into the TNUoS charging methodology would remove some of this uncertainty in the charging signal.

⁶ One on the west coast between Hunterson and Deeside, the other planned on the east coast between Peterhead and Teesside.

3 Solution – The Original Proposal

- 3.1 The Workgroup began its work with reviewing the Original proposal from NGET as the Proposer. It has been the Workgroup’s job to debate, probe and, if appropriate, develop alternatives to the Original proposal.
- 3.2 This section provides a summary of the solutions arising out of the Original CMP213 proposal. The detailed discussion on the merits, or otherwise, of the Original proposal, potential options for developments of the Original proposal, and any options for potential alternative(s) are set out in Section 4.
- 3.3 The solutions outlined below are split between the three main aspects of the Original proposal, the background behind each, which is explained in the preceding section:
- i) Better reflection of the incremental costs imposed by different types of generators on the electricity transmission network within the Investment Cost Related Pricing (ICRP) TNUoS charge calculation (i.e. network sharing);
 - ii) Introduction of an approach for including HVDC circuits that parallel the AC network into the TNUoS charging methodology; and
 - iii) Introduction of an approach for including island connections comprised of sub-sea cable technology into the TNUoS charging methodology.
- 3.4 The following section explains how the Proposer believes the Original proposal addresses the issues outlined in the preceding section and, as such, do not constitute the views of the Workgroup as a whole which are set out in Section 4.

i) Network Capacity Sharing

- 3.5 This aspect of the Original proposal seeks to recognise the implicit sharing of the wider transmission network (local circuits are generally not planned on the basis of being shared and are therefore not deemed to be shared so were not part of the Original proposal) by altering the way in which the wider tariff is calculated within the Transport and Tariff model and also how it is applied, thus improving its cost reflectivity.
- 3.6 A high-level summary of the Sharing aspect of the Original proposal is set out in Table 8, below.

<i>i. Sharing – Improving the incremental cost signal</i>	
i) Alignment with changes to the NETS SQSS	<p>When calculating background power flows:</p> <ul style="list-style-type: none"> - split Transport model into 2 backgrounds; Peak Security and Year Round; - scale generation to meet demand using NETS SQSS approach for each.
ii) Differentiation between generators based on characteristics as well as location	<p>When calculating incremental costs:</p> <ul style="list-style-type: none"> - circuits allocated to one background or the other based on highest flows (commensurate with planning); - two wider locational tariff elements representing the 2 Transport model backgrounds; - intermittent generation not exposed to the Peak Security element; - Year Round element scaled by a sharing factor (based on generator specific load factor).

Table 8 – Summary of Sharing aspect of Original proposal

- 3.7 A more detailed explanation of the network capacity sharing aspect of the Original proposal is included in Annex 5 – Detail of Original Proposal.

Transport Model

- 3.8 The Original proposal seeks to replace the existing peak background in the Transport model with two separate background conditions, representing Peak Security and Year Round conditions respectively. Whilst the existing DCLF in the Transport model sets up the peak demand background by scaling down the contracted TEC of all generators in Great Britain equally to meet total demand, the Original proposal would set up two peak demand conditions and scale generation differently under each to reflect the values used in the NETS SQSS. Some of these values would be fixed year on year and some would vary depending on the demand level in the year under consideration.
- 3.9 The values that would have arisen from 2011/12 data are shown in Table 9, below:

Generator Type	TEC	Current Methodology	Peak Security Background	Year Round Background
Intermittent	5,460	65.5%	0%	70%
Nuclear & CCS	10,753	65.5%	72.5%	85%
Interconnectors	3,268	65.5%	0%	100%
Hydro	635	65.5%	72.5%	66%
Pumped Storage	2,744	65.5%	72.5%	50%
Peaking	5,025	65.5%	72.5%	0%
Other (Conventional)	61,185	65.5%	72.5%	66%

Values in grey vary depending on the total demand level, whilst values in black are fixed scaling factors corresponding to those used in the NETS SQSS.

Table 9 – NETS SQSS Treatment by Plant Type

- 3.10 In order to ascertain whether the incremental investment driver on a given transmission circuit is related to Peak Security or Year Round conditions, the power flows on each circuit are compared and a proportion of the circuit is allocated to a given investment driver (i.e. Peak Security or Year Round). It is proposed that the allocation is done on the basis of whole circuits being either Peak Security or Year Round driven, with the background leading to the highest flows on a given circuit dictating its investment driver and allocation. For example, if the flows on a particular transmission circuit are calculated to be 2000MW in the Peak Security background condition and 1500MW in the Year Round background condition then that particular circuit is deemed, according to the Original proposal, to be 'Peak Security'.
- 3.11 Once the allocation process (between Peak Security and Year Round) is complete an incremental MW would be applied at each node in the DCLF model, as occurs in the existing TNUoS charging methodology, in order to establish the effect of that additional MW on the transmission network as a whole. Under this Original proposal, the incremental MW process would occur at each node in turn for both the Peak Security and Year Round conditions, as shown in Figure 2, below:




Figure 2 – Calculation of Nodal Incremental MWkm

3.12 Ultimately, this process results in the incremental impact (i.e. MWkm) for each transmission circuit under both Peak Security and Year Round conditions. These total MWkm would subsequently be allocated to either the Peak Security or Year Round elements, based on the aforementioned allocation of a given circuit to an investment driver.

3.13 As the total system MWkm of the Peak Security and Year Round backgrounds is almost the same as the total MWkm under the existing charging methodology the Proposer believed that this demonstrated that the inclusion and calculation of incremental impacts on a dual background approach, consistent with the NETS SQSS, was robust and consistent with the ICRP approach. Nevertheless, the Proposer also believed that a further step is required in order to make an improvement to the cost reflectivity of this approach when calculating the TNUoS charge due to the fact that a dual background approach in isolation does not sufficiently address the varying impact of generation plant with different characteristics on incremental costs (i.e. not every incremental MW leads to an incremental MW of transmission network cost). This further step is explained below.

3.14 As the majority of transmission investment is no longer planned on a deterministic basis for peak demand conditions and is increasingly planned using cost benefit analysis techniques for conditions expected to occur across all times of the year, the Original proposal recognises that the impact of an incremental MW on the need for transmission network capacity varies depending on the type and characteristics of generation, as well as its size and location in relation to the exiting GB transmission network.

3.15 Due to the nodal granularity of incremental costs in the Transport model, this recognition of generators characteristics occurs in the Tariff model, where nodal costs are used to create zonal weighted averages, in order to align with the zonal granularity of wider TNUoS tariffs. This is explained in more detail, below.

Tariff Model

3.16 The Tariff model utilises the nodal incremental MWkm and the unit cost of these MWkms (i.e. the expansion constant and expansion factors) in order to calculate the locational signal, which forms part of the wider TNUoS tariff.

3.17 This is achieved by first averaging the nodal incremental impact across a TNUoS zone using the existing zoning criteria and a demand weighted average of all nodes. The resulting nodal incremental MWkm are multiplied

by the expansion constant (£/MWkm) and the global locational security factor (currently 1.8) to achieve the zonal wider locational tariff. This is carried out for both the Peak Security and Year Round backgrounds, leading to two separate elements of the wider locational tariff.




Figure 3 – The Zonal Wider Locational Tariff

- 3.18 The result of this process is a two part locational element of the wider tariff: (Peak Security £/kW) and (Year Round £/kW).
- 3.19 For the Peak Security element of the tariff, it is proposed to maintain the existing uniform treatment of generation, with the exception that the tariff of intermittent plant would currently be scaled to 0% in recognition of the assumptions made, by the TOs, when planning transmission network capacity. (i.e. according to the NETS SQSS, to which TOs are obliged to plan and operate their networks through their Transmission Licence, no transmission network capacity is built for intermittent generation on the MITS in order to secure demand – at peak demand conditions). This scaling factor would be linked to the NETS SQSS, such that if this factor changed in future, the TNUoS charging methodology would also change.
- 3.20 This Original proposal would scale the Year Round element of the tariff of each generator depending on its impact on the transmission network, using a sharing factor as detailed below.
- 3.21 Explicit commercial arrangements are not in place that provide Transmission Licensees with information to assess the impact on the need for transmission network investment arising from an individual generator when planning investment using non-deterministic, i.e. cost benefit analysis, methods. Therefore implicit assumptions over input prices (fuel, CO₂, subsidy, etc.) and generator characteristics (efficiency, availability, etc.) relative to the remainder of the market are made by them. The Proposer believes that these detailed implicit assumptions alone are not sufficiently robust in order to calculate TNUoS tariffs. This belief is corroborated by the extensive industry debate undertaken during the Transmission Access Review process where various options were considered.
- 3.22 In order to remain cost reflective, any proposed sharing factor needs to be reflective of the implicit assumptions made when planning transmission network capacity as it is these assumptions that ultimately lead to the costs that the tariff is attempting to reflect. This Original proposal puts forward a form of generator specific sharing factor (based on annual load factor averaged over 5 years historic output) as representative of the assumptions

made, by the TOs, when planning transmission investment for the addition or removal of generation in a given part of the transmission network.

- 3.23 The use of a generator’s annual load factor, as a readily quantifiable manifestation of all the aforementioned detailed characteristics of a generator, was deemed a suitable proxy by the Proposer for use in improving the cost reflectivity of the existing ICRP approach to calculating TNUoS tariffs (i.e. to allow for differentiation between the incremental impact of one generator compared to another). Whilst load factor is recognised to be a simplification, and charging on more detailed aspects of a generator’s characteristics may result in a TNUoS tariff that is more cost reflective, the Proposer believed the proposed CMP213 Original approach represented an appropriate balance between simplicity and cost reflectivity of the TNUoS tariff calculation.
- 3.24 The detail of the aforementioned TNUoS tariff calculation process is explained further within Annex 5 – Detail of Original Proposal.
- 3.25 Once this is completed and the proportion of revenue collected from the locational element is known, the Tariff model also calculates the non-locational, residual element to ensure that the total allowed revenue is recovered in the proportion of 27% from generators and 73% from demand Users of the transmission network. Together the locational and residual elements of the tariff form the wider TNUoS tariff in the existing charging methodology.
- 3.26 Under the Original proposal the structure of the wider TNUoS tariff would change to mirror the change to two backgrounds in the Transport model, and a two part tariff such that the locational element is split into a Peak Security element and a Year Round element as set out above. As a result the TNUoS charge for an individual generator arising from the wider element of the annual TNUoS charge would be calculated as follows:

$$\text{[(Peak Security £/kW) + (Year Round £/kW x Sharing Factor) + (Residual £/kW)]} \\ \text{x TEC kW = £ wider TNUoS charge}$$

- 3.27 For the avoidance of doubt the charging methodology for calculating demand TNUoS charges would be based on the existing approach. Whilst demand tariffs would also be calculated on both a Peak Security and Year Round background, the resultant tariffs are combined and multiplied by the same charging base as under the existing TNUoS charging methodology (due to the fact that investment in network capacity for demand is not affected by the characteristics of that demand, as is the case with generation), thus leading to only minor differences in tariffs as a result of a small number of transmission circuits that change flow direction between the two backgrounds. In other words CMP213 (either the Original or any WACM(s)) will have only a minor impact on demand TNUoS tariffs.
- 3.28 The Proposer believed that a change in the calculation of generation TNUoS tariffs and only minor changes to demand TNUoS tariffs is consistent with the drivers for change outlined in Section 2 “Why Change?”, which point to changes in the characteristics of generators and their resultant use of the transmission network due to government environmental legislation amongst other drivers. As electricity demand is currently, despite progress in this area, still largely price inelastic, the characteristics of demand has not altered such that its impact on the incremental cost of transmission has changed.

ii) Inclusion of parallel HVDC circuits

3.29 The Original proposal puts forward solutions for the two main issues needing to be addressed in order to facilitate HVDC transmission circuits that parallel the AC network into the TNUoS charging model:

- i) As set out above the charging calculation uses a load flow to calculate incremental costs. Power flows on the existing AC network are dictated by the relative impedance of the individual network components (such as overhead lines and cables). These power flows are replicated in the load flow aspect of the tariff calculation. However, in the case of HVDC transmission circuits that parallel the AC transmission network, the power flow is controllable and not dictated solely by the impedance characteristic. Therefore, to include HVDC in the load flow aspect, assumptions need to be made on how much power will flow on the HVDC transmission circuits relative to the rest of the AC transmission network; and
- ii) The calculation of the expansion factor (i.e. relative unit cost) for HVDC transmission circuits.

3.30 A high-level summary of the HVDC aspect of the Original proposal is set out in Table 10, below.

ii. HVDC Circuits – Including these circuit types into the methodology	
i) Incremental power flow calculation	When calculating background power flows: <ul style="list-style-type: none"> - model HVDC circuit as pseudo-AC circuit; - calculate HVDC circuit flow by apportioning flows with parallel AC circuits, using relative circuit ratings; - average flows across all major system boundaries crossed by the HVDC circuit; - set impedance of the HVDC circuit to achieve this flow.
ii) Expansion Factor (unit cost) calculation	When calculating expansion factors: <ul style="list-style-type: none"> - include both converter station costs and cable costs; - create a unique value for each HVDC circuit.

Table 10 – Summary of HVDC aspect of Original proposal

i) Power Flow

3.31 It is proposed that the treatment of power flow on an HVDC circuit in the Transport Model be based on a simplifying assumption. This treatment can be made due to the controllable nature of these links relative to power flows on the parallel AC network, which are dictated solely by the impedance of a transmission circuit and that of the remaining network.

3.32 As a result, the Original proposal would model an HVDC circuit as an AC circuit for the purposes of calculating the incremental power flow element of the locational signal. This approach requires the calculation of impedance for the equivalent AC transmission circuit (i.e. the circuit characteristic that dictates power flow) and is considered a reasonable simplification.

3.33 This Original proposal would calculate the impedance by adjusting the impedance of the HVDC transmission circuit in the load flow in order to achieve a pre-determined power flow through it in the base case. This power flow is determined as a proportion of the average circuit ratings of all the circuits comprising the main transmission boundaries that the HVDC circuit crosses (i.e. the main transmission routes that the circuit would parallel and therefore provide additional capacity across).

- 3.34 To achieve this, the ratings of all transmission circuits that cross each transmission boundary individually are summed, excluding the HVDC circuit itself. Subsequently, the power flow across each transmission boundary without any flow on the HVDC circuit would be used to produce a ratio of power flow to transmission boundary total circuit rating (accounting for the direction of the boundary flow in the base case).
- 3.35 These ratios can be used to calculate an average for all transmission boundaries that the HVDC transmission circuit crosses. This average power flow to total circuit rating figure is used to set the impedance of the AC equivalent HVDC circuit to produce the power flow that gives this ratio to the HVDC circuit rating.

ii) Expansion Factor

- 3.36 The TNUoS charging methodology incorporates the unit cost of various transmission technologies by calculating the cost of a given technology relative to the cost of 400kV overhead line. This allows for the calculation of a multiplier, known as an expansion factor, which is used in the Transport model to calculate the locational signal within TNUoS charges. As HVDC transmission technology does not currently exist in the Transport model, a method of incorporating its unit cost is also required.
- 3.37 When using HVDC cables, as opposed to overhead lines, the unit cost of these are generally less than an AC equivalent. However, in order to utilise this technology relatively expensive power electronic switching devices and associated power quality equipment (e.g. reactive compensation devices), that convert the AC power signal to DC and back again, are required to interface with the existing transmission network. These devices are collectively known as HVDC converter stations. It is for this reason that HVDC circuits are generally only utilised for power transmission over long distances. As such, the Proposer believes that HVDC converter stations should form an integral element of the locational signal for these transmission circuit types so that generators are better able to internalise the transmission network cost impacts of plant location and closer decisions.
- 3.38 As the Original proposal considers HVDC converter stations as an integral element of the distance related locational signal of the HVDC transmission circuit, it is proposed to include the cost of these converter stations as well as the associated cables or overhead lines making up the circuit into the expansion factor calculation for each HVDC transmission circuit. This approach is also consistent with that used in the calculation of TNUoS tariffs for offshore transmission networks. Whilst the charging calculation for offshore networks is different to that of onshore transmission infrastructure, these two approaches are currently, and should remain, consistent.
- 3.39 With the cost of converter stations included, each representing a large fixed cost on either end of the transmission circuit, it is necessary to calculate a unique expansion factor for each HVDC circuit on the transmission network in order to maintain cost reflectivity for circuits of varying length. The Proposer therefore believes that a specific expansion factor should be determined for each HVDC circuit.

iii) Inclusion of sub-sea island connections

- 3.40 In order to calculate cost reflective charges for this type of transmission circuit the Original proposal primarily addresses how the expansion factor should be calculated for underground and sub-sea cable technologies not included in the charging methodology.

3.41 As outlined above, the charging methodology incorporates the unit cost of various transmission technologies by calculating the cost of a given technology relative to the cost of 400kV overhead line. This allows for the calculation of a multiplier, known as an expansion factor, which is used in the Transport model to calculate the locational signal within the TNUoS tariff. As the AC and HVDC, sub-sea and underground technologies proposed for Scottish island connections do not currently exist in the Transport model, a method of incorporating their unit cost is required.

3.42 A high-level summary of the HVDC aspect of the Original proposal is set out in Table 11, below.

iii. Island Connections – Including these circuit types into the methodology	
i) Local / Wider definition	<p>When classifying island nodes as part of the MITS:</p> <ul style="list-style-type: none"> - utilise the existing definition; - take account of reduced security, where relevant.
ii) Expansion Factor (unit cost) calculation	<p>When calculating expansion factors:</p> <ul style="list-style-type: none"> - create a specific expansion factor for each AC technology; - for HVDC connections maintain consistency with HVDC approach set out above.

Table 11 – Summary of Islands aspect of Original proposal

1.63 For transmission spurs, such as those connecting Scottish islands, the Original proposes to calculate new expansion factors for each type of circuit technology proposed. Where such circuits are comprised of HVDC technology, the methodology would be consistent with that outlined for HVDC above. As such, this approach would also be consistent with that used in the calculation of TNUoS tariffs for offshore transmission networks

3.43 In addition, there are some cases where reinforcement to the Scottish islands would create MITS nodes on the islands, but where the level of security provided by the island link remains much lower than the existing wider system average. Where a significant proportion of the spur has no redundancy, but is still deemed to be part of the wider transmission network for charging purposes, the security factor for that portion would essentially be 1⁷ rather than the (current) GB average of 1.8.

⁷ Achieved by the length of that portion of the circuit in the Transport model being adjusted to compensate by multiplying its actual length by 1/(Locational Security Factor)

4 Summary of Workgroup Discussions on Sharing

Introduction

- 4.1 NGET, as the Proposer of CMP213, presented and circulated a more detailed description of the Original proposals. Following discussion some areas of the Original proposal were clarified and further details of the Proposer's reasoning were included. This more detailed outline of the proposed solution is included as Annex 5 – Detail of Original Proposal.
- 4.2 The network capacity sharing aspect of the CMP213 modification proposal seeks to improve the cost reflectivity of the Transmission Network Use of System (TNUoS) tariffs by recognising transmission network capacity sharing by generators in the Investment Cost Related Pricing (ICRP) TNUoS calculation.
- 4.3 As this aspect of the CUSC Modification Proposal CMP213 Modification Proposal represents a significant change to the existing ICRP calculation, is quite detailed in nature and despite its outward simplicity is based on underlying concepts that can be difficult to conceptualise for non-transmission experts, the Workgroup spent a considerable amount of time discussing, debating and challenging the Original proposal in order to fully understand it.
- 4.4 The current charging methodology for calculating TNUoS tariffs at a given point on the transmission network injects an additional 1 MW at that point, removes it from the notional centre of the transmission network (known as the 'reference node') and uses the resulting increase in network power flows on a MW per MW basis to calculate the locational signal.
- 4.5 In using this approach, the existing charging methodology inherently assumes that 1 MW of generation capacity would require 1 MW of transmission network capacity. Historically, with relatively low generation plant margins above peak demand levels (in the order of 20% to 25%), this has been a reasonably cost reflective assumption.
- 4.6 As generators of different technology types connect to, and change the way in which they use the transmission network, the nature of transmission capacity investment planning has also altered to ensure efficient transmission network investment is undertaken. This is exemplified in the recent changes to the NETS SQSS (GSR-009⁸) and the increasing amount of transmission investment justified on the basis of avoided future constraint costs (i.e. a cost benefit analysis, CBA approach; outside of the deterministic NETS SQSS standards).
- 4.7 As a result, transmission planners are increasingly making implicit assumptions about the extent to which generators with differing characteristics share capacity on the transmission network, such that 1 MW of generation capacity will not necessarily require 1 MW of transmission network capacity. The assumptions not only include the characteristics of individual generators but the combined characteristics of a group of generation behind a transmission boundary. Transmission planners historically have achieved this by only considering a limited stack of generation (based on merit order) but this is less robust in areas where intermittent generation is present.
- 4.8 Under the Original proposal the Transport model would continue to be used to calculate the long run incremental cost at a given connection point on the

⁸ <http://www.ofgem.gov.uk/Pages/MoreInformation.aspx?docid=26&refer=Networks/Trans/ElecTransPolicy/SQSS>

transmission network. Within the Transport model a dual background approach would be applied, using both a Peak Security and Year Round background, consistent with recent changes to the NETS SQSS under GSR-009 and the Authority's Direction arising out of the TNUoS Project TransmiT Significant Code Review.

- 4.9 It is proposed that locational incremental requirements on a transmission circuit route are allocated to one background or the other; i.e. Peak Security or Year Round; based on whichever drives the maximum flows on that circuit. The Proposer believes that this approach is consistent with the driving factor behind transmission investments.
- 4.10 Under this approach transmission capacity required for Peak Security reasons would be planned and charged in accordance with a generator's Transmission Entry Capacity (TEC), whilst capacity required for Year Round purposes would be charged in accordance with both a generator's TEC and a generator specific sharing factor, based on their historic average annual load factor, which the Proposer believes to be reflective of the efficient transmission network capacity for that particular generator.
- 4.11 Many in the Workgroup believed that the use of a generators' annual load factor for TNUoS calculation purposes was either overly simplistic and not sufficiently cost reflective or that the use of a form of generator annual load factor may be justified as one element of the TNUoS calculation but that it either should not be specific or should not be based on historic information.
- 4.12 A generator specific, rather than generic, annual load factor is deemed necessary by the Proposer to adequately reflect an individual generator's contribution to the need for transmission network capacity investment to the level of granularity required for cost reflective charges (that are non-discriminatory in nature).
- 4.13 In reality when the transmission planner undertakes a CBA there is limited information available and it is therefore necessary to make a number of assumptions about the characteristics of individual generators in the associated market dispatch model. Some examples of these assumptions, as set out above, include the plant's capacity, efficiency, fuel prices, CO₂ prices, unavailability due to maintenance and faults, bid prices, offer prices, available subsidies, etc.. The Proposer explained that each of these assumed characteristics, as inputs to the market model, would manifest in a generator's annual load factor, which is an output of the market model.

Transmission Planning Using CBA

- 4.14 As the use of market models that dispatch and re-dispatch generation to meet demand and reconcile transmission network constraints are a key aspect of the transmission planning process and as such were also used by the Proposer to demonstrate how the many detailed implicit assumptions on generation characteristics manifest themselves in a generator's annual load factor and how this related to incremental costs, the Workgroup believed it was important to understand how these models worked in principle.
- 4.15 The market model used in the CBA process will use the aforementioned generation characteristic assumptions, along with assumptions about demand levels over the course of a year of operation to calculate an optimum economic despatch of generation to meet demand in each period. Subsequently, this market model will consider the transmission network power flows arising from this optimum economic despatch (OED) against the network capability and re-dispatch generation using the most economic bids and offers available where necessary to ensure power flows remain within

the capability of the transmission network. This process ensures that the total network operational costs are minimised.

- 4.16 This re-dispatch is sometimes referred to as the security constrained optimum economic despatch (SCOED). The difference between the SCOED and the OED for each period summed across a year of operation is known as the annual constraint cost.
- 4.17 The above process of market modelling was also used extensively by the Workgroup to explore and develop the Original proposal in order to address the concerns set out in paragraph 4.11, as set out below.
- 4.18 Individual transmission network reinforcement options are tested in the market dispatch model described above to assess the extent to which they reduce annual constraint costs over a number of future years. A decision to invest in transmission network capacity would occur when the annuitised cost of that investment is less than the forecast reduction in annual constraint costs (and some other benefits such as reduced losses) over a sufficient number of future years. As a result one would expect that transmission network constraint costs (the short run marginal cost – SRMC) and transmission network reinforcement costs (the long run marginal cost – LRMC) would converge over the long term in a given part of the network, all else being equal (i.e. ignoring short term effects such as consenting delays, connect and manage and the ‘lumpiness’ of transmission equipment investment).
- 4.19 It is this CBA method of transmission network planning and the relationship between the SRMC and LRMC of transmission that allows for an investigation of the impact that an additional 1 Megawatt (MW) of generation plant has on constraint costs in order to quantify its incremental network requirements on a network where transmission network capacity is shared. In the Original proposal transmission network capacity is deemed to be shared across the wider transmission network for those incremental network costs driven by the Year Round background in the Transport model.
- 4.20 In search of a method for taking into account the many characteristics of a specific generator in relation to its incremental transmission network requirements, the Proposer undertook a significant amount of market modelling (as described above) using the NGET’s Electricity Scenario Illustrator (ELSI) Model model and a range of assumptions about background conditions based on reasonable forecasts of these conditions also used by NGET when planning transmission capacity. It was not the intention to use this type of modelling to generate produce actual TNUoS tariffs. Rather it was undertaken in an attempt to discover if a simple proxy for a generator’s incremental impact on transmission network costs existed that could be incorporated into the existing ICRP approach. This would avoid the need for complex commercial arrangements to solicit more detailed information from generators, which was shown to be extremely difficult through the TAR industry process.
- 4.21 Within this modelling, undertaken using ELSI, the Proposer concluded that a generator’s annual load factor generally has a linear relationship with its impact on incremental constraint costs although the relationship may vary across different plant types and location due to the fact that the annual load factor is a manifestation of the relative economics of that generator; including its availability, fuel cost, efficiency, CO₂ prices and subsidies such as ROCs.,
- 4.22 Whilst the relationship between annual load factor and incremental cost was not a perfect one and varied for different areas of the transmission system, the Proposer believed that it was much better than the relationship between Transmission Entry Capacity (TEC) and incremental cost, as illustrated in

4.23 Figure 4, below

4.24 The blue diamond points on this plot represent the annual incremental cost impact of a generation plant type against its annual load factor as calculated by the ELSI model. The dotted green line represents the theoretically perfect relationship between annual load factor and annual incremental costs; whereas the red dashed line represents the theoretically perfect relationship between a generator's capacity (i.e. TEC) and annual incremental costs. A similar illustration was shared with the Project TransmiT SCR Technical Working Group in 2011.




Figure 4 – Market Model Outputs vs. Theoretical Perfect Relationships

4.25 The results of the annual load factor vs. incremental cost analysis, in the form of graphs showing the zonal relationships between an incremental 1 MW of various generation plant types (with various load factors arising out of the market model) and the annual incremental constraint cost implications associated with that generator, were shared with the Workgroup at their second meeting in July 2012. A version of these graphs is reproduced within Annex 6 – ALF vs. Annual Incremental Cost Analysis. Similar graphs were also previously shared with the Project TransmiT SCR Technical Working Group in 2011.

4.26 In addition to the above, a simple user interface was created by NGET for the ELSI model in order to allow CMP213 Workgroup members to undertake similar analysis utilising their own assumptions and test the nature and limitations of this relationship for themselves. An example of the types of graphs shared with the Workgroup and included in Annex 6, are shown below in Figure 5.




Figure 5 – Example ELSI analysis

4.27 Based on the analysis undertaken, and despite deterioration of the relationship in some areas of the transmission network as shown in Annex 6,

and in later years (i.e. beyond 2017/18), the use of generator specific sharing factors based on annual load factor was thought to be a reasonable, simple proxy by the Proposer, in lieu of requesting and utilising all the aforementioned detailed characteristics, which provides a suitable balance between the cost reflectivity and simplicity of the TNUoS tariff calculation.

Workgroup Deliberations

4.28 The Workgroup was required to consider the issues raised under this aspect of the CMP213 Modification Proposal and were asked to report on the following specific issues in line with / in addition to those set out in the Authority's SCR Direction by the CUSC Panel:

- (a) whether intermittent generation should contribute to the peak element of the tariff;
- (b) whether load factor is an appropriate measure of the level of sharing;
- (c) whether the proposed method for calculating load factor is an appropriate measure of forward looking charges (subject to item b);
- (d) whether to use maximum line flow when attributing circuit MWkm to the Peak Security and Year Round elements or an alternative approach;
- (e) whether shortening circuit MWkm may be an alternative to the use of load factor in reflecting sharing; and
- (f) comparison of the modelled charging outputs to real network investment costs.

4.29 In the second meeting the Workgroup considered both the terms of the SCR Direction and the specific request from the CUSC Panel and compiled a single list of options and potential alternatives to be investigated from the outset. These are explored further below.

Initial Scoping of the Original

4.30 The Workgroup agreed the areas to be considered for the sharing aspect of the Original proposal could be summarised as:

Considerations from the Direction	Potentials changes to Original
a) How charging structures should be applied geographically; in particular where zones are dominated by one type of generation	i) Account for diversity in a plant type specific manner for each zone
	ii) Account for diversity in a zonal average manner for each zone
	iii) Different treatment for positive and negative charging zones
b) Alternative approaches to ALF for reflecting User characteristics into charging	i) TEC only
	ii) SQSS based generic factor
	iii) Other Generic load factor
	iv) NGET and/or User forecast
	v) Hybrid approach
	vi) Alternatives measures (metered, FPNs)
	vii) Ex-ante or ex-post
c) Whether intermittent technology types should be exposed to the peak element of the tariffs	i) Exposed to some extent
	ii) Indexed linked to something

Table 12 – Considerations from the Direction for Sharing

CMP213 Amendment
Proposal

07 December 2012

Version 1.0

Page 31 of 199

4.31 In developing the Original and potential alternatives of the various themes highlighted in this section further analysis was undertaken by other Workgroup members on market models and concepts were also considered on a more theoretical basis to ensure that results arising from the analysis could be corroborated with what would be expected to happen in theory. This approach also helped all members of the Workgroup to better understand the concepts behind the Original proposal and potential alternatives by breaking it down into its component parts.

Areas for development of Original Proposal and Potential Alternatives

4.32 The Workgroup also discussed further areas where the Original proposal could be developed not highlighted by the Authority’s Direction or where potential alternatives could be developed and discussed each of these in turn.

Potential Alternatives
i. Sharing applies to local
ii. Method of allocation of MWkm to YR and PS backgrounds
iii. Don’t have a dual-background (YR only)
iv. Use of a full market model to calculate charges (more than 2 backgrounds)
v. Background scaling different to GSR-009
vi. Anticipatory application of sharing (or wider)
vii. Explicit sharing
viii. Incorporating circuit loading (e.g. LRIC) into methodology
ix. Application of load factor (or variant) to residual as well as year round
x. A method to recover more revenue through the locational element of tariffs
xi. Alternative zoning methodology

Table 13 – Potential Alternatives for Sharing

Discussion on the Original Proposal and Potential Options and Alternatives

4.33 This section covers the Workgroup discussions on each of the individual issues above. It does so by setting out details of the Workgroup views expressed during the explanation and development of the proposal before taking each of three main considerations from the SCR Direction (set out in Table 12, above) in turn, with each of the potential changes to the Original Proposal covered under these main considerations. Finally, the potential alternatives set out in Table 13 are also considered in turn.

4.34 As set out above, the use of generator’s annual load factor as a surrogate for the incremental cost of transmission network investment (driven by constraint cost) is at the heart of the Original proposal. The Proposer believes a generator’s annual load factor, as a manifestation of many underlying variables, was a simplification of the relationship between generation plant type and incremental transmission cost but that it was better than the use of generation (TEC) capacity alone and represented the right balance between simplicity and cost reflectivity in the TNUoS tariff calculation.

4.35 A number of concerns were raised by some Workgroup members that, although the initial view of the Proposer was that the use of a generator’s annual load factor alone provided the right balance between simplicity and cost reflectivity, in many circumstances this was believed not to be the case

by these members. These members believed that a number of key issues needed to be explored further.

- 4.36 These members pointed out that in those TNUoS charging zones where there was little or no diversity of generation plant type, the relationship between a generator's annual load factor and incremental constraint costs shown by the Proposer appears to deteriorate, with some generation plants types driving higher constraint cost. This was linked to concerns that the absolute value of avoided constraint costs vary depending on the generation (TEC) capacity and type of plant in a TNUoS charging zone. Some believed that zones dominated by low carbon generation plant had constraint costs that are high relative to zones dominated by conventional thermal plant.
- 4.37 It was also believed by some that the difference between bid and offer prices is the driver of constraint costs in areas of the transmission network behind constrained transmission boundaries, which are typically also positive TNUoS zones, whereas differential offer price is the main driver in unconstrained areas of the transmission network and that avoided constraint costs are not significant in these areas, which are also typically negative TNUoS zones.
- 4.38 Linked to the above concerns, some Workgroup members were concerned that the Original proposal does not consider the different characteristics of different transmission network boundaries and simply assumes the generator's annual load factor effect on all transmission network boundaries is identical. The Proposer clarified that the Original proposal currently only differentiates based on the distance related aspect of the signal (which changes by boundary) and the generator specific sharing factor, but not based on the relative capacity of generation plant types in a TNUoS charging zone.
- 4.39 Others in the Workgroup believed that, as the investment in the transmission network is forward looking and investments are made by TOs to avoid incurring future potential significant constraint costs it may thus be prudent to include "future" generation plant in a potential alternative that takes capacity of generation by plant type into account when sharing of transmission network capacity is identified. It was not clear to the group, at this stage, how future generation plant would be identified and how this could be incorporated into the TNUoS charging methodology.
- 4.40 Some members in the Workgroup were also of the view that the methodology used to incorporate recent changes to the NETS SQSS by splitting the tariff into Peak Security and Year Round elements is overly complex and were unsure if the resulting separate incremental cost signals are meaningful (or mathematically robust) given that they are based on different load flows. The Proposer believed that the detail of the TNUoS tariff calculation in the Original, included in this consultation as Annex 5 – Detail of Original Proposal, was mathematically robust and reflective of the way in which the transmission network is planned.
- 4.41 A review of the generation annual load factor versus incremental constraint cost graphs presented to the group by the Proposer and some initial exploratory analysis by another Workgroup member in a separate market model to that used by the Proposer confirmed that a number of the aforementioned concerns were potential issues with the Original proposal in the view of some Workgroup members and subsequently formed the basis of further analysis.
- 4.42 As set out above, the graphs produced by the Proposer in support of the Original plot the annual load factor of a generator of a certain plant type against the impact of an incremental 1 MW of that generation plant type on

the annual constraint costs, as it is these total annual constraint costs against which transmission network capacity is planned. However, when modelling the various demand levels across a year of operation, a market model will use multiple snapshots of demand and dispatch/re-dispatch generation against each snapshot. The results of each snapshot are added together to obtain the annual impact.

- 4.43 The graph in Figure 6, below, shows some indicative findings from the generic market model used by Workgroup members referred to above (i.e. not the ELSI model) for constraint cost in a northern SYS zone in a future year. The chart shows the relationship between the output of an incremental 10MW of capacity of a given generation plant type (CCGT and Onshore Wind) and the additional constraint costs arising as a result of that incremental output for each demand snapshot, representing a finite period in a year of operation. From this graph the Workgroup noted that, across a single transmission boundary, multiple generator annual load factor relationships occur at the various demand levels (and associated generation dispatches) that each snapshot represents.
- 4.44 Some in the Workgroup believed that the graph in Figure 6 confirmed that a generator's annual load factor was a key factor, if not the only factor, in the impact on incremental constraint costs.
- 4.45 The Workgroup discussed the fact that the aforementioned relationship is driven by factors including the severity of the constraint (i.e. the volume of energy that cannot be transported on the transmission system) and the type of generation plant used to relieve the constraint (i.e. the price at which that volume of energy is replaced), amongst other factors. Some Workgroup members requested clarification on the input assumptions used within the generic market model, used to produce the results in Figure 6 through Figure 8.




Figure 6 – Graph of Incremental Constraint Cost vs. Generator Output (for a given snapshot across a year of operation in a positive TNUoS zone)

- 4.46 Some Workgroup members believed that the Proposer's analysis in support of the Original proposal only considered the simple condition of a relatively unconstrained transmission boundary that had ample quantity of thermal generation units present to relieve the constraint. However, the Proposer clarified that the analysis undertaken was done using National Grid's Gone Green background of generation and demand and with transmission network boundary capacities as close to the optimum level of capacity (where the SRMC and LRMC of transmission converge and consistent with the ICRP approach to taking account of network expansion) as possible for the simplified zonal representation of the transmission network used within these types of market model.

4.47 In addition the Proposer agreed, as set out above, that the relationship between a generator’s annual load factor and its impact on incremental constraint costs deteriorates somewhat over time as the proportion of generation plant with high bid prices increases in areas of the transmission network. This effect was also evident from the Proposer’s own analysis using the ELSI model and the graphs created using the Gone Green 2020 background shared with the Workgroup.

4.48 Further exploratory analysis was undertaken by Workgroup members in the generic model which looked at the total annual incremental constraint cost across several transmission boundaries (i.e. the entire network), similar to that undertaken by the Proposer. This analysis was undertaken on a generic future generation and demand background with existing transmission network boundary capabilities. This showed that in general the more constrained the boundary (SYS Zone 2 and Zone 6 – in Scotland) and the more negative the bid price of a generation plant type, the greater the incremental constraint cost. The results are illustrated below in Figure 7, below.




Figure 7 – Total Annual Incremental Constraint Cost against Annual Load Factor

4.49 For southern zones (SYS Zone 13 and Zone 15) where there are in general fewer network constraints the generation annual load factor relationship was considered by some to be relatively weak and the magnitude of the “saving” (i.e. reduction in incremental constraint costs as a result of offsetting constrained volumes from the north) small compared to the increase in incremental constraint costs evident in northern SYS zones. This effect was deemed by some to be driven by the differential offer price of units used to relieve constraints.

4.50 Others in the Workgroup believed that the slope of the generator’s annual load factor versus incremental constraint cost relationship would be dictated by the optimum transmission network boundary capability upon which the Original proposal is based and the distance from the TNUoS charging zone under consideration to the centre of demand on the transmission system (i.e. the number of transmission boundaries that the incremental power flow is likely to cross). Some also considered that the reduction in incremental impact in southern charging zones is consistent with the TNUoS price signal which is lower in the south relative to the north of Great Britain.

4.51 In zones where TNUoS generation charges are negative different relationships between the output of an incremental 10MW of generation

capacity and incremental constraint costs per demand snapshot were again seen, as illustrated in Figure 8, below. The Workgroup noted that, for the majority of snapshots in this analysis the incremental 10 MW of generation was not being dispatched to meet demand and therefore had little or no effect on the incremental constraint cost. Only snapshots at times of high northern constraint cost delivered significant negative values of incremental constraint cost impact. Some in the Workgroup believed that this effect was indicative of a better relationship between generation annual load factor and incremental transmission network costs than that between generation capacity (i.e. output over three peak periods for generators in negative TNUoS charging zones) and incremental transmission network costs.

- 4.52 The Workgroup was interested in the fact that some snapshots of generation dispatch (i.e. optimum economic dispatch) and re-dispatch (i.e. security constrained optimum economic dispatch) delivered values even at a zero generator annual load factor. The group considered that this was likely to be driven by the increased availability of low price offers for generation plant such as the biomass unit illustrated in Figure 8, below. Some Workgroup members were unsure of the input assumptions used, which led to a biomass generator with a 25% annual load factor (i.e. 75% of points at zero output). These members pointed to the ELSI analysis where the annual load factor of biomass generators is much higher.




Figure 8 – Incremental Constraint Cost vs. Generator Output (for a given snapshot across a year of operation in a negative TNUoS zone)

- 4.53 It became clear to some Workgroup members during this development phase that sharing of transmission capacity in an area of the transmission system may be best achieved when the coincidence of running between generation (simultaneous running) is lowest. Thermal generation (such as coal and gas) is usually driven by market conditions, has full control of its input fuel and as such in general follows the demand curve. Low carbon generation (principally hydro, wind, wave and tidal) with their lower variable costs and variable input fuel sources are less correlated to demand and in typically operate in a must-run condition when fuel is available.
- 4.54 The Proposer noted that the Original proposal seeks to reflect the impact of generators of different plant type on incremental transmission network cost and does so based on an implicit underlying assumption that individual generators share transmission network capacity (i.e. do not run simultaneously, or 'counter correlate', running to a certain extent). The Proposer considered that this implicit assumption was consistent with those made by transmission network planners through the market models used to undertake cost benefit analysis and that the assumption is robust across the main interconnected transmission system.

- 4.55 Some Workgroup members believed that maximum sharing occurs when an area of the transmission system contains an equal amount of generation capacity of both low carbon and conventional thermal generation and that the optimum transmission boundary capacity would be 50% of the combined capacities. In practice such perfect sharing would not occur and at times some constrained action (i.e. re-dispatch of generation at an additional cost or SCEOD as set out in paragraph 4.16) would be required. In these circumstances a slightly higher volume of thermal plant to low carbon would reduce incremental constraint costs.
- 4.56 The saving in constraint cost compared to the impact of a full incremental 1 MW achieved by collective sharing of capacity across transmission boundaries is not only dependent on the volume that can share but the length of the boundary and thus the kilometres saved by sharing needs to be considered across transmission boundaries in addition to the volume that can potentially share. Further work was identified to potentially incorporate the volume that can potentially share behind a transmission boundary, the length of the boundary and the generator's annual load factor into a potential alternative based on a single background. This work is set out in more detail, below.

a) How charging structures should be applied geographically; in particular where areas are dominated by one type of generation

- 4.57 As noted above the Proposer undertook a significant amount of market modelling using the Electricity Scenario Illustrator (ELSI) model and a range of assumptions about background conditions in search of a method for taking into account the many characteristics of a specific generator in relation to its incremental transmission network requirements.
- 4.58 The convergence of long run (i.e. asset) and short run (i.e. constraint) costs on average over the long term when planning incremental transmission network capacity using a CBA approach was used, such that the relationship between a generator and incremental constraint costs arising out of a simple market model would be valid in its application to TNUoS tariffs calculated on the basis of incremental asset costs in the ICRP approach.
- 4.59 From this ELSI based analysis the Proposer believed that a simple proxy for a generator's incremental impact on transmission network costs existed in the form of its annual load factor and that this proxy could be incorporated into the existing ICRP approach in order to improve the cost reflectivity of this approach. The Proposer suggested this was because load factor is a manifestation of individual generation plant characteristics compared to the wider market operation.
- 4.60 As part of the analysis it also became clear that the relationship between a generator's annual load factor and incremental transmission network costs deteriorates over the long term in some areas on the extremities of the transmission system where one generation plant type dominates. This effect was corroborated by analysis undertaken by other Workgroup members, set out above, on a separate market model. However, given the uncertainty of when future generation will connect and where, it was difficult for the Workgroup to establish when the deterioration would become significant. Some Workgroup members believed that the relationship does not hold from the outset, regardless of background conditions.
- 4.61 The Proposer currently believes that the simplicity of a simple generator's annual load factor based approach outweighs any cost reflectivity benefits that a more complex approach taking account of generation plant diversity could bring.

- 4.62 The Workgroup began an investigation of the issue of generation plant diversity by investigating the annual load factor versus incremental constraint cost relationship. During this investigation the Workgroup expressed concern at the underlying complexity behind the results of the analysis, arising from the number of variables affecting the outcome. This made the graphs difficult to interpret in a Workgroup setting without a more thorough understanding of the underlying variables and their effect.
- 4.63 In advance of the Workgroup and in anticipation of such a concern, a simple to use interface was created for the ELSI market model in order to allow Workgroup members to undertake similar analysis utilising their own assumptions and test the nature and limitations of this relationship for themselves.
- 4.64 The capabilities of this interface and the underlying ELSI market model were improved based on feedback from the Workgroup by increasing the granularity of transmission network boundary modelling, inclusion of maintenance outages in annual network capabilities and the development of a whole new add-in to calculate generation availability probabilistically.
- 4.65 In addition to the use of the above ELSI model with associated interface created specifically for the CMP213 Workgroup process and a separate, generic market model that showed broadly consistent results the Workgroup also engaged in a detailed discussion of the underlying variables and their effects.

Exploration of Variables Affecting Incremental Constraint Costs

- 4.66 As the impact on incremental constraint costs are used to quantify the impact a generator with certain characteristics has on the need for transmission network capacity, the Workgroup considered that an understanding of what contributes to constraint costs is essential.
- 4.67 The Workgroup agreed that annual incremental constraint costs for a generator with a given TEC (i.e. £/MW/annum) are comprised of 2 main components, illustrated below in Figure 9, which could be further sub-divided into 5 variables.




Figure 9 – Components that drive transmission constraint costs

i) Generator output over the year

- 4.68 The Proposer believed that the output of an incremental MW of a generation type in a given area of the transmission network over a year of operation is the primary contributing factor to the impact of that unit on the volume of incremental constraints on the Main Interconnected Transmission System. Different generation types have quite different outputs as is illustrated very simplistically between Wind and CCGT in Figure 10, below.




Figure 10 – Simplistic illustration of output from different types of generation

- 4.69 The output of some generation plant types, such as wind, is largely dominated by the availability of its fuel (i.e. the wind). Due to the economics of wind plant and subsidies available for this plant type it is assumed that it will always seek to run when the wind is available. However, the output of other plant types such as coal and gas is driven more by short run marginal costs relative to other generators and demand levels. For example, when it is windy coal and gas generators are less likely to be called upon to run. In addition, when conventional plant do run they are more likely to run at full output as this is when they are at their most efficient; compared to wind plant by contrast, which is likely to only be at full output for a small proportion of the year.
- 4.70 All else being equal, a CCGT with a 70% load factor will drive a greater volume of constraints because of longer periods of running than a wind farm of the same MW capacity as shown in Figure 10 above. As noted previously, the Workgroup understood that this largely assumes that there is sufficient diversity of generation plant types behind the transmission boundary. For the avoidance of doubt this is the generator's annual load factor; some members of the Workgroup believed that daily or weekly generator load factors were more important. The Proposer noted the Original proposal does not seek to introduce sub annual measurements or of generator load factors in to the TNUoS tariff calculation.

ii) Correlation between generation running within an area

- 4.71 In making the implicit assumption that an additional 1MW of generating plant would require an additional 1MW of transmission network capacity, the existing charging methodology makes the simplistic assumption that all plant running is 100% correlated (at peak demand times).
- 4.72 However, if considered from a transmission system wide perspective, it can be simply appreciated that this cannot be the case at times of peak demand, let alone when moving further down the generation price curve at times of lower demand (when planning transmission capacity based on potential avoided constraint costs).
- 4.73 This is illustrated in Figure 11, below, which plots the background average sharing (scaling of generation capacity) at times of peak demand against the percentage of generation capacity installed on the transmission system over and above peak demand (i.e. the plant margin).




Figure 11 – Transmission Network Sharing at Peak Demand as Plant Margin Increases

- 4.74 As an example, this figure shows that if the capacities of all generating plant were stacked up against peak demand (i.e. the Plant Margin) and together exceeded that peak demand level by 40%, the generation plant capacity stack would need to be scaled by $100/140$,; i.e. 71.4%,; in order meet the peak demand.
- 4.75 As a 40% plant margin is not far from the existing background conditions it is clear from a transmission system wide perspective that, on average, 1MW of transmission network capacity would not be required for 1MW of generation capacity. Indeed, at times of peak demand this value is closer to 0.7MW on average across the transmission system. Taking account of annual variations in demand entails even greater average background sharing of transmission capacity as peak demand levels only occur in very few of the 8760 hours that make up a year.




Figure 12 – Annual Demand Load Duration Curve

- 4.76 Figure 12, taken from the Seven Year Statement, shows that transmission system demand levels are only above 80% of peak levels for 8% of the year and above 50% of peak levels for 78% of the year. The Proposer believes that Figure 11 and Figure 12 taken together demonstrate that a significant amount of sharing of transmission network capacity would take place on average across the transmission system as a whole over a year of operation.
- 4.77 Nevertheless, the Workgroup noted that in areas of the transmission network where there was only one type of generator, and particularly where it was expected to have a negative bid price, transmission network planners would tend to build a level of transmission capacity closer to the full output of those generators.

- 4.78 Due to the aforementioned changes to the way transmission network capacity is planned, the efficient level of network capacity for 1MW of generation capacity is dependent on the characteristics of an individual generating plant in relation to other plant on the transmission network. As network planning becomes more CBA driven, generation plant specific economics can lead to varying levels of efficient transmission network capacity.
- 4.79 When planning a transmission network for year round conditions, consideration of generation plant running across a year of operation is required, indeed, network planners need to make assumptions about running several years in advance. In practice it is the assumptions on individual characteristics of generating plant such as price and availability that will drive its running in the market model used to undertake the CBA. Simplistic illustrative examples of how correlation and counter correlation can occur between two generating units over a year are illustrated in Figure 13.




Figure 13 – Examples of Plant Correlation

- 4.80 The above simplistic illustration demonstrates that correlation of running between two co-located incremental 1MW of generation plant is dependent on both the load factor of that generator and the times of the year that they choose to run.
- 4.81 It can be seen that an incremental 1MW with a load factor of <50% (the top plots) have the ability to completely counter correlate (top left) and to completely correlate (top right) their output. The latter being the current assumption within the current ICRP charging approach. Generation plant with a load factor of >50% (the bottom plots) do not have the ability to completely counter correlate (bottom left), but do have the ability to completely correlate (bottom right).
- 4.82 All else being equal, in each of the examples illustrated, the optimum incremental transmission network capacity for one incremental MW of generation would never reach one whole MW of transmission network capacity. Whilst correlation of generation plant running has an impact, on the Main Interconnected Transmission System this is due predominately to the effect of price and availability, which both strongly influence a generator's annual load factor (i.e. its output over the year).
- 4.83 The Proposer noted that the effect of correlation of generation plant running on incremental constraint costs is reflected in the market modelling undertaken and shared with the Workgroup.

iii) Correlation between generator running and network constraint times

4.84 The final variable affecting the impact of an incremental 1 MW of generation on the volume of constraints is the correlation between generation plant running and times of transmission network congestion over the year. The times of network congestion are influenced by demand in a given area of the network and the availability of network capacity connected that area to the rest of the network.




Figure 14 – Correlation between plant running and network congestion

4.85 Consistent with the existing ICRP approach, the investigation into the impact on incremental constraint costs assumes that the transmission network can be expanded to exactly the optimum incremental capacity required.

4.86 Figure 14, above, illustrates how the output of an incremental 1MW of generation in an export constrained zone (GenA1_MW) interacts with the capacity of the transmission network out of that zone (Boundary_MW) over the 8760 hours that make up one year of operation.

4.87 The diagram shows that the output of the incremental 1MW over the year (i.e. its annual load factor) is again the predominant factor contributing to the incremental volume of transmission network constraints arising from transmission boundary flows over and above the optimum incremental boundary capacity. Nevertheless, the bottom right plot shows that correlation with times of constraint is also a secondary significant contributing factor.

4.88 This plot demonstrates that, whilst a generator may have an annual load factor of 80% over the 20 periods representing a year (made up of full output over 14 periods, half output – e.g. one unit unavailable – for 4 periods and no output – e.g. not dispatched – for 2 periods), for the periods when it is generating at only 50% capacity (i.e. < optimum incremental network capacity) mean that it does not contribute to constraints during these 4 periods, leading to a correlation with times of constraint of only 70%.

4.89 As shown simplistically above in Figure 10, a wind generator is much more likely to generate at less than full capacity throughout the year due to variability of wind and turbine power characteristics than a base load conventional generator, which will generally run at full output when in merit due to the efficiency gains in doing so.

4.90 All else being equal, in each of the examples illustrated, the optimum incremental transmission network capacity for one incremental MW would never reach one MW of transmission capacity on the Main Interconnected Transmission System. Whilst correlation with times of constraint has an impact, this is due predominately to the effect of the generation plant's annual load factor (i.e. its output over the year) as optimum incremental capacity would also reduce with load factor.

4.91 The Proposer noted that the effect of correlation with times of transmission network congestion on incremental constraint costs is reflected in the market modelling undertaken and shared with the Workgroup as this modelling varies demand levels, generation availability and transmission network availability throughout a year of operation.

- iv) Bid price of the marginal plant on the exporting; and
- v) Offer price of the plant on the importing side

4.92 The second main component of overall constraint costs is that of constraint price (£/MWh). Using the same simple example as in the section above, Figure 15 below illustrates how the Offer price (GenB1_£/MW) and Bid price (GenA1_£/MW) combine to create the constraint price for each of the 8760 hours in a year.




Figure 15 – Impact of bid and offer price on incremental constraint cost

4.93 For an export constraint the System Operator (SO) will accept bids from the marginal generation plant on the exporting side (of a transmission boundary) to reduce output and hence power flows across the congested section of the transmission network. In order to maintain the supply and demand balance the SO is also required to accept offers from the marginal generation plant on the importing side of a transmission boundary (assuming a balanced system – signals on system balance are delivered separately through the BSC). In theory the minimum price of this action typically occurs when bids and offers are accepted from the same generation plant type.

4.94 The illustration of the generator price stack (or merit order) on the right side of Figure 15 shows that for a given level of demand one generation plant will set the system marginal price. As this price is largely driven by fuel and other variable costs it is likely that there are other generators of a given similar type across the transmission system with will have very similar prices and these are bunched together and illustrated by the various colours on the stack.

- 4.95 Across a year of operation, different generation plant types will set the marginal price (increasing as one moves from the bottom to the top of the stack up to the marginal generator). This varies depending on both the total demand in a period and the availability of generation at the bottom of the price stack (e.g. wind) in a period.
- 4.96 When a constraint occurs in an area of the transmission network, the transmission system is essentially split into two from the perspective of the SO, due to being compelled to accept bids and offers from a reduced, limited pool of generation on either side of the congested transmission boundary.
- 4.97 Given the above, the Workgroup agreed that sufficient diversity of generation plant was an important factor contributing to the price and volume, and therefore cost, of incremental constraints.
- 4.98 The combined effect of all the above variables is illustrated in Figure 16, below.




Figure 16 Overall cost of a constraint

- 4.99 The Proposer noted that the effect of bid and offer prices on incremental constraint costs is reflected in the market modelling undertaken and shared with the Workgroup. Indeed the Workgroup noted that, where the relationship between incremental constraint costs and generation annual load factor was shown to deteriorate in future years, that this was largely in areas with increasing proportions of low carbon plant. Some members of the Workgroup noted that this effect was due to the characteristics of low carbon plant, in particular their relatively high bid prices, driven by low fuel prices and volume related subsidies.
- 4.100 Other members of the group disagreed noting that, whilst this may be the case for intermittent plant, that the bid prices of low carbon nuclear (driven by technical and safety related restrictions) are substantially different to those for (intermittent) wind (driven primarily by volume based subsidies). These members believed that a more granular distinction between generation plant types would be required as a result.
- 4.101 However, the Workgroup were minded not to look for a complex solution based on bid price.

Impact of Variables Affecting Incremental Constraint Costs on Generation Annual Load Factor vs. Annual Incremental Constraint Cost Relationship

4.102 The Workgroup continued by investigating the effect of the variables contributing to incremental constraint cost on the generator's annual load factor vs. annual incremental constraint cost relationship upon which the Original proposal is based. This investigation began with consideration of an illustrative version of this relationship, as shown below in Figure 17. The Workgroup noted that for simplicity the relationship was drawn as a perfectly linear one, but that this did not reflect the graphs shared with the Workgroup by the Proposer.




Figure 17 – Load Factor vs. Incremental Constraint Cost

4.103 Nevertheless, the majority of the Workgroup noted that the graphs presented by the Proposer did show that the relationship between a generation plant's annual load factor (% output over a year) and annual incremental constraint costs is a relatively strong one where sufficient diversity of plant type exists. Some in the Workgroup believed that, after having considered the full range of variables contributing to incremental constraint costs, as set out above, this is due to the fact that the primary factor of cost is the unconstrained dispatch of generation over the year. A minority in the Workgroup were still unconvinced that there was any relationship between generation annual load factor and constraint costs.

4.104 The Workgroup also recognised that, where this relatively linear relationship exists, the incremental constraint costs (i.e. short run marginal cost) caused by a generating plant with a 100% annual load factor (i.e. one that generates at full capacity for 8760 hours in a year) would set the maximum efficient incremental transmission network costs (i.e. long run marginal cost) for one incremental MW of transmission network capacity, as illustrated below in Figure 18.




Figure 18 – CBA driven incremental network costs for one incremental MW of network capacity

4.105 From this starting point, the Workgroup began to explore the volume and price component effects, set out above, on the generator’s annual load factor vs. incremental constraint cost relationship.

4.106 The illustration in Figure 19, below, shows the effect of changes in the correlation between generation plant running and of generation plant running at times of transmission constraints as set out in paragraphs 4.71 to 4.91.




Figure 19 – Correlation of generation plant running and with times of constraints

4.107 The varying slopes of the dotted lines on the above illustration show that, whilst a change in correlation of generation plant running or with times of transmission constraint has an impact on the slope of the overall linear relationship, such that a 1MW of a given plant type causes more or less incremental constraint costs, it would not negate the relationship between the generator’s annual load factor and annual incremental constraint costs. (i.e. generation plant with lower load factors have a lesser impact on incremental constraint costs even when the slope is higher or lower).

4.108 From this, the Workgroup agreed that when the transmission network capacity is set to that of an optimally invested network, the aforementioned correlations between generation plant running and times of constraint are fixed. The Proposer noted that the slope of this line is dictated by the long run marginal cost of an incremental 1MW of fictitious generation with 100% annual load factor and the impact of this 100% annual load factor

incremental 1MW is comparable to the impact of an incremental 1MW using the ICRP method in the Transport model.

- 4.109 Given the above, the Proposer believes that it is clear that a generating plant's annual load factor is one of the primary drivers of incremental transmission network costs when network capacity is planned using cost benefit analysis against future potential savings in constraint costs and it is assumed the network can be expanded in an optimum incremental manner (the latter of which is an existing assumption in the ICRP approach).
- 4.110 In addition to the volume effect on the generation annual load factor vs. incremental constraint cost relationship, the Workgroup also explored the price effect. In this area results from two sets of analysis undertaken using ELSI and a generic market model showed very similar results.
- 4.111 The Workgroup found that, where there was insufficient diversity of generation plant types behind a transmission network constraint, the SO would no longer be able to accept bids from a generator close to price of the system marginal plant. In this case the incremental cost of constraints would increase.
- 4.112 When the Workgroup delved deeper into the nature of this effect, it became clear that the generation plant setting the bid price was the primary factor affecting the price of constraints. Indeed, the Workgroup found that it was possible to broadly separate generating plant into two categories based on their bid prices.
- 4.113 Due largely to their 'must run' characteristics, resulting from the subsidies they receive, their extremely low fuel costs or other technical characteristics (reflected in the bid price), areas where low carbon plant set the bid price were seen to have a deviation from the largely linear annual load factor vs. incremental constraint cost relationship, such that more than one linear relationship emerged.
- 4.114 Specifically, the low carbon observed (and expected) to have these levels of bid prices are hydro, wind, wave, tidal, nuclear and carbon capture and storage (CCS). All other generation plant types were considered to be non low carbon. Some Workgroup members believed that nuclear generators should not be included in the low carbon category due to the combination of (i) higher load factor of nuclear plant and (ii) very high bid prices of nuclear plant compared with, for example, onshore wind.. Others believed that it should be included as its bid price characteristics were more similar to that of intermittent plant than conventional, non low carbon plant. The Workgroup agreed that further work was still required in this area with respect to the distinction between carbon and low carbon generation plant.
- 4.115 This divergence in the linear relationship between low carbon and non low carbon plant is illustrated in Figure 20, below.




Figure 20 – Divergence in the linear relationship between low carbon and non low carbon plant

4.116 When considering the results from the analysis, the Workgroup agreed that the bid price of a generation plant was also one of the primary factors affecting the annual load factor vs. incremental constraint cost relationship. However, it can also be seen from the above graph, which is illustrative in nature, that similar bid price generation still demonstrate a linear relationship, albeit on a different slope.

4.117 Taking the combined effects of all of the above elements together and considering how the individual points on the graph are plotted results in the illustration in Figure 21, below.




Figure 21 – Combined effect of price and load factor on constraint costs

4.118 From the above the Workgroup appreciated that, for areas of the transmission system with sufficient generation plant diversity and a correlation of running and constraints fixed at that of the optimally invested transmission network level (i.e. at the point where incremental constraint costs are comparable to the incremental cost of capacity arising from the Transport model), the incremental transmission network cost (shown in red above) is set by the annual load factor of the incremental 1MW of generation (the volume element; shown in grey above) and the bid price of the marginal non low carbon plant (the price element; shown in green). The market bid/offer premium is assumed to be 0.6 and 1.6 times the short run marginal cost, which is the value used by the Proposer in the ELSI market model used to produce the generation annual load factor vs. incremental constraint cost graphs shared with the Workgroup.

- 4.119 Alternatively, for areas of the transmission system with insufficient generation plant diversity and a correlation of running and constraints fixed at that of the optimally invested transmission network level, the incremental transmission network cost (shown in purple above) diverges such that for low carbon plant it is set by the annual load factor of the incremental 1MW of generation (the volume element; shown in grey above) and the bid price of the low carbon plant, which includes a low carbon bid premium - LC (the price element; shown in green). In this instance the incremental transmission network cost for non low carbon plant continues to be set by the factors in the grey and red boxes, as before.
- 4.120 In both cases the maximum incremental cost was set by the incremental cost of the fictitious 100% annual load factor, non low carbon generation plant as this cost was equivalent to the long run marginal cost (i.e. transmission asset cost) arising from the existing ICRP Transport model calculation.
- 4.121 The Workgroup concluded that this divergence effect occurred where low carbon plant dominated a particular area of the transmission network, all be it that some members of the Workgroup disagreed with nuclear being included in the low carbon plant definition used here.
- 4.122 As a result of (i) a review of the Proposer's analysis done in the ELSI model, (ii) additional work undertaken by the Workgroup in another generic market model and (iii) a detailed review of the variables impacting on incremental constraint costs and the resultant impact on the annual load factor vs. annual incremental constraint cost relationship, all set out above, the Workgroup came up with a number of potential alternatives to address the issues highlighted by this work. The first step was to develop a method for practically taking account of diversity in the Transport and Tariff model.

Practical methods for taking account of diversity in the Transport and Tariff model

- 4.123 The following section explores the approach developed by the Workgroup for incorporating an approach that some believe could better take account of generation plant diversity into the Transport and Tariff model.
- 4.124 Potential options and alternatives for addressing the issue of diversity all seek to identify, with increased granularity to the Original proposal, which of the wider incremental costs are shared and which are not shared based on the diversity of generation plant types in an area of the transmission system. As set out above, this is largely as a result of differences in bid and offer prices.
- 4.125 The first challenge is how the incremental costs can be split to provide the additional granularity required. To address this the Workgroup developed a method for calculating zonal boundary lengths utilising the expanded zonal incremental kilometres of transmission circuit routes arising from the Transport model and by defining a matrix of zonal transmission boundaries of influence (i.e. the path that an incremental MW would take, specifically which boundaries it would cross, to get to the notional centre of the transmission network).
- 4.126 First, the incremental kilometres are taken from the Transport model. For some potential alternatives the Year Round incremental kilometres are used, as those deemed to be shareable in the Original proposal. The Peak Security based incremental kilometres are not utilised. For other potential alternatives a single background may be used (i.e. the dual background approach, of Peak Security and Year Round, would not be utilised). An illustrative example of the Year Round incremental kilometres, taken from the Tariff model is shown in Figure 22, below.

Derivation of Zonal Generation Tariffs - Year Round				
Zone	Zone Name	Generation Charge Base: TEC Net Stn * ALF	Unadjusted Transport Zonal Wtd Marginal (km)	Unadjusted Transport Zonal Tariff (£/kW)
1	North Scotland	0.273	781.5	16.49
2	Peterhead	0.885	599.1	12.64
3	Western Highland & Skye	0.192	882.1	18.61
4	Central Highlands	0.201	679.7	14.34
5	Argyll	0.220	506.6	10.69
6	Stirlingshire	1.833	469.7	9.91
7	South Scotland	2.232	441.3	9.31
8	Auchencrosh	0.044	469.3	9.90
9	Humber & Lancashire	12.353	158.1	3.34
10	North East England	0.832	177.6	3.75
11	Anglesey	0.534	130.6	2.76
12	Dinorwig	0.493	95.4	2.01
13	South Yorks & North Wales	10.252	97.7	2.06
14	Midlands	5.042	41.4	0.87
15	South Wales & Gloucester	5.427	-132.7	-2.60
16	Central London	0.001	-308.2	-6.50
17	South East	9.421	88.9	1.88
18	Oxon & South Coast	0.348	-118.8	-2.51
19	Wessex	1.445	-231.9	-4.89
20	Peninsula	0.680	-350.1	-7.39

Figure 22 – Illustrative Year Round Zonal Incremental km

4.127 All potential options and alternatives for diversity utilise the fact that each of the zonal incremental kilometres (i.e. the Unadjusted Transport Zonal Wtd. Marginal km above) represents the incremental network requirements to the notional centre of the transmission network. Therefore, provided the path of the incremental 1 MW is known, one zonal incremental kilometre value can be subtracted from the other to calculate the transmission boundary length (i.e. distance from the demand weighted centre of one TNUoS zone to the next). This is done by establishing a zonal transmission boundaries of influence matrix for the TNUoS generation charging zones as represented diagrammatically in Figure 23, below.




Figure 23 – Diagrammatic representation of zonal boundaries of influence

4.128 The zonal transmission boundary length calculation, using the Year Round zonal incremental kilometres shown in Figure 22, for generation TNUoS zones 1 through 6 are shown in Figure 24, below.

Zone	Name	YR Incremental MWkm	Z1-Z4	Z2-Z4	Z3-Z4	Z4-Z6	Z5-Z7	Z6-Z7
1	North Scotland	781.53	1					
2	Peterhead	599.11		1				
3	Western Highland & Skye	882.10			1			
4	Central Highlands	679.74	-1	-1	-1	1		
5	Argyll	506.62					1	
6	Stirlingshire	469.68				-1		1
7	South Scotland	441.31					-1	-1
8	Auchencrosh	469.25						
9	Humber & Lancashire	158.11						
10	North East England	177.59						
11	Anglesey	130.61						
12	Dinorwig	95.37						
13	South Yorks & North Wales	97.65						
14	Midlands	41.39						
15	South Wales & Gloucester	-132.68						
16	Central London	-308.22						
17	South East	88.95						
18	Oxon & South Coast	-118.81						
19	Wessex	-231.88						
20	Peninsula	-350.14						
Incremental Boundary Length (400kV km)			101.80	-80.62	202.37	210.06	65.31	28.37
Zone			1	2	3	4	5	6

Figure 24 – Example of zonal transmission boundary length calculation

4.129 Using the approach outlined above, zonal transmission boundary lengths can be calculated for each TNUoS charging zone (e.g. 781.53 – 679.74 = 101.79, for Zone 1 in Figure 24, above). Hence for any TNUoS charging zone, the path that the incremental 1 MW takes to the notional centre of the transmission network can be broken down into its component boundary lengths. Potential options and alternatives for dealing with issues of diversity developed by the Workgroup would utilise this to establish the proportion of total incremental kilometres that are shared.

4.130 The zonal transmission boundaries of influence is also required to map the route of the incremental 1 MW as illustrated, again for generation TNUoS zones 1 through 6, in Figure 25 below. For example, in this illustration, each of the transmission boundary lengths that are crossed by an incremental 1 MW of generation from TNUoS zone 6 (i.e. Z6 → Z7 → Z9 → Z13 → Z14) will add up to the total incremental kilometres for zone 6, 469.68, as shown above.

Zone	Name	YR Inc. Boundary Length	Z1	Z2	Z3	Z4	Z5	Z6
1	North Scotland	101.80	1					
2	Peterhead	-80.62		1				
3	Western Highland & Skye	202.37			1			
4	Central Highlands	210.06	1	1	1	1		
5	Argyll	65.31					1	
6	Stirlingshire	28.37	1	1	1	1		1
7	South Scotland	283.20	1	1	1	1	1	1
8	Auchencrosh	27.94						
9	Humber & Lancashire	60.46	1	1	1	1	1	1
10	North East England	19.48						
11	Anglesey	32.96						
12	Dinorwig	-2.28						
13	South Yorks & North Wales	56.27	1	1	1	1	1	1
14	Midlands	41.39	1	1	1	1	1	1
15	South Wales & Gloucester	-13.86						
16	Central London	-308.22						
17	South East	88.95						
18	Oxon & South Coast	-118.81						
19	Wessex	-113.06						
20	Peninsula	-118.26						
Incremental MWkm			781.53	599.11	882.10	679.74	506.62	469.68
Zone			1	2	3	4	5	6

Figure 25 – Zonal transmission boundaries of influence to map the route of the incremental MW

4.131 Finally, potential options and alternatives would compare the cumulative proportion of low carbon (LC) and carbon (C) generation TEC behind each of the transmission boundaries to determine if sufficient diversity exists behind

the boundary for its previously calculated length to be shared. This is illustrated for TNUoS generation zone 1 in Figure 26 , below.

4.132 The reason a cumulative TEC value is used is that the underlying issue of diversity is one of sufficient low bid price generation plant (i.e. carbon plant; who would normally be willing to pay the System Operator for the avoided fuel cost of being bid off in the balancing mechanism) behind a transmission boundary.

4.133 The Workgroup noted that the exact groupings of carbon and low carbon plant were still being developed (based on bid/offer price characteristics) and that the numbers in Figure 26 were therefore only illustrative in nature to demonstrate the cumulative effect of TEC behind a boundary.

Name	Incremental Boundary (km)	Z1	
		LC	C
1 North Scotland	101.80	256	468
2 Peterhead	-80.62		
3 Western Highland & Skye	202.37		
4 Central Highlands	210.06	566	2068
5 Argyll	65.31		
6 Stirlingshire	28.37	1577	4472
7 South Scotland	283.20	5958	5558
8 Auchencrosh	27.94		
9 Humber & Lancashire	60.46	10518	21978
10 North East England	19.48		
11 Anglesey	32.96		
12 Dinorwig	-2.28		
13 South Yorks & North Wales	56.27	12832	36687
14 Midlands	41.39	15443	41974
15 South Wales & Gloucester	-13.86		
16 Central London	-308.22		
17 South East	88.95		
18 Oxon & South Coast	-118.81		
19 Wessex	-113.06		
20 Peninsula	-118.26		

Figure 26 – Cumulative LC and C generation TEC behind a boundary

4.134 Various options and alternatives were considered by the Workgroup, utilising the method for incorporating into the Transport and Tariff model set out above.

a) i) Plant type specific or ii) Zonal average diversity per TNUoS zone

4.135 The Workgroup discussed the possibility of addressing the diversity issue through both plant specific and zonal average generation diversity per TNUoS charging zone. In doing so, three possible methods were devised, which are summarised in Table 14, below.

Area	Original All wider Year Round (YR) shared	Method 1 YR zonal shared / not shared split	Method 2 YR zonal shared / not shared split	Method 3 Single background with zonal sharing factor
Dual background	Yes	Yes	Yes	No
Wider locational tariff components	2	3	3	1
MITS sharing	All YR incremental costs	YR split into shared / not shared	YR split into shared / not shared	All incremental costs with zonal sharing factors
Application of generator specific sharing factor	Yes	Yes; to shared element	Yes; to shared element	No

CMP213 Amendment Proposal

07 December 2012

Version 1.0

Page 52 of 199

Diversity calculation	None	Based on deterministic relationship between low carbon / carbon ratio	Based on minimum of low carbon / carbon generation in an area	Based on minimum of low carbon / carbon generation in an area
Method for split of Incremental Costs	None	Zonal boundary length using transmission boundaries of influence	Zonal boundary length using transmission boundaries of influence	Zonal boundary length using transmission boundaries of influence

Table 14 – Options considered for addressing generation plant type diversity issues

Method 1 – Year Round shared/not shared split based on low carbon / carbon generation ratio

4.136 The approach of Method 1 is to build upon the existing market modelling undertaken in ELSI which some Workgroup members agreed demonstrated that a relationship between the annual load factor of an individual generating plant and its impact on incremental transmission network costs exists, and the subsequent investigation by the Workgroup concluding that in areas of the transmission network with insufficient diversity of generation plant, the high bid prices of low carbon generators leads to a divergence of this relationship as set out in paragraphs 4.102 through to 4.121.

4.137 The aforementioned divergence is consistent with the ELSI based analysis undertaken by the Proposer that demonstrated a deterioration of the generation annual load factor vs. incremental constraint cost relationship in the long term in areas of the transmission system with insufficient diversity of generation plant. A snapshot of this analysis shared with the Workgroup is shown in Figure 27, below. These graphs show that in SYS Zone 1 the relationship breaks down as large proportions of low carbon generators are assumed to connect by 2020 (using NGET’s Gone Green scenario), but that in SYS Zone 6 the relationship remains reasonably robust due to the diversity of plant behind the relevant transmission boundary.




Figure 27 – Long term deterioration of the Load Factor vs. Incremental Constraint Cost relationship

4.138 Ultimately, Method 1 recognises the importance of two key factors contributing to incremental transmission network costs:

- Generation annual load factor – as in the Original proposal; and
- Diversity of low carbon and non low carbon generation plant in an area of the transmission system.

4.139 Whilst annual load factor is generation plant specific, the diversity element is related to the zonal availability of sufficient non low carbon plant (or simply – Carbon plant) in a TNUoS zone (i.e. plant with a near marginal bid price). As the Workgroup were minded not to look for a complex solution based on bid price, Method 1 would utilise the ratio of cumulative low carbon (LC) to carbon (C) generation TEC behind a zonal transmission boundary as set out in paragraph 4.131 to establish what proportion of the associated incremental kilometres making up the transmission boundary length were shared or not shared.

4.140 This led to an approach that can be summarised as follows:

- 1) Calculate expanded zonal transmission incremental kilometres using both the Peak Security (PS) and Year Round (YR) backgrounds and the apportioning method proposed in the Original.;
- 2) Derive the zonal transmission boundaries of influence and boundary length calculations using the YR background as set out above in paragraphs 4.127 to 4.130;
- 3) Split generation TEC in each generation TNUoS zone into carbon (C) and low carbon (LC) and calculate cumulative proportions of C and LC TEC from each TNUoS zone to the centre of the transmission network using the zonal transmission boundaries of influence;
- 4) Based on the result of analysis undertaken prior to finalising this potential alternative, compare the (C TEC)/(Total TEC) and (LC TEC)/(Total TEC) for each transmission boundary the incremental 1 MW of generation crosses with a predefined deterministic relationship (still being considered by the Workgroup, that would apply transmission network wide);
- 5) Using this predefined deterministic relationship, determine what proportion of each transmission boundary length is shared and what proportion is not shared. The Workgroup also considered that a potential alternative involving specific analysis of counter correlation of generation running behind a transmission boundary could be used at this point.
- 6) Total shared incremental kilometres form a separate shared YR tariff element and total not shared incremental kilometres form a separate not shared YR tariff element; and
- 7) Results in a four part wider TNUoS tariff using Annual Load Factor (ALF) as follows:

$$\text{(PS x TEC) + (YR}_{\text{not shared}} \text{ x TEC) + (YR}_{\text{shared}} \text{ x ALF x TEC) + (Residual x TEC)}$$

Where; YR_{not shared} and YR_{shared} are calculated using the pre-defined range of low carbon and carbon generation capacity ratios behind transmission boundaries, transmission boundary lengths and the transmission boundaries of influence defined above.

- 8) Intermittent plant *not exposed* to PS element on the basis that they are not modelled in this background for transmission network planning, but do contribute to the peak element inherent in YR.

4.141 The Workgroup noted that further consideration was required with respect to which generation plant types are included / excluded from the low carbon and non low carbon definitions that were proposed to be used and that this could result in a variation to any of the methods for addressing diversity developed by the group.

4.142 In addition the Workgroup noted that further analysis was required to determine how much sharing of transmission capacity occurs for different proportions of carbon and low carbon generation, as indicated in point 4 above and how specific analysis of counter correlation of generation plant running of all types could be included, as indicated in point 5, above.

Method 2 – Year Round shared/not shared split based on percentage minimum of low carbon or carbon generation to total

4.143 Some Workgroup members believed that maximum sharing occurs when a TNUoS zone contains an equal capacity of both low carbon and carbon generation and that the optimum transmission boundary capacity would be 50% of the combined capacities in this case. In practice perfect generation sharing would not occur and at times some constraint action (i.e. re-dispatch of generation at an additional cost) would be required. In these circumstances a slightly higher volume of thermal plant to low carbon would reduce incremental costs.

4.144 Method 2 builds on the premise set out above and defines the maximum amount of generation sharing that can occur on a transmission boundary as the percentage minimum of carbon or low carbon generation to the total generation behind a boundary, thereby limiting the total shared incremental kilometres to a maximum of 50%. Method 2 also uses cumulative low carbon (LC) to carbon (C) generation TEC behind a transmission boundary for this calculation as set out in Method 1, above.

4.145 Some Workgroup members did not follow the logic of why sharing would be limited to 50% of the transmission boundary length for this method. These members considered that sharable capacity could exceed 50% where an area had equal proportions of carbon and low carbon plant.

4.146 Development of method 2 led to an approach that can be summarised as follows:

- 1) Calculate expanded zonal incremental kilometres using both the Peak Security (PS) and Year Round (YR) backgrounds and the apportioning method proposed in the Original.;
- 2) Derive the zonal transmission boundaries of influence and boundary length calculations using the YR background as set out above in paragraphs 4.127 to 4.130;
- 3) Split generation TEC in each generation TNUoS zone into carbon (C) and low carbon (LC) and calculate cumulative proportions of C and LC TEC from each TNUoS charging zone to the centre of the transmission network using the zonal transmission boundaries of influence;
- 4) Calculate the total shared incremental kilometres per transmission boundary based on percentage of minimum of C TEC and LC TEC to total TEC behind a transmission boundary;
- 5) Total shared incremental kilometres form a separate shared YR tariff element and total not shared incremental kilometres form a separate not shared YR tariff element; and
- 6) Results in a four part wider TNUoS tariff using Annual Load Factor (ALF) as follows:

$$(PS \times TEC) + (YR_{\text{not shared}} \times TEC) + (YR_{\text{shared}} \times ALF \times TEC) +$$

$$(Residual \times TEC)$$

- 9) Intermittent plant *not exposed* to PS element on the basis that they are not modelled in this background for transmission network planning, but do contribute to the peak element inherent in YR.

Method 3 – Single background shared/not shared split based on percentage minimum of low carbon or carbon generation to total

- 4.147 Some members in the Workgroup were of the view that the approach used to incorporate recent changes to the NETS SQSS by splitting the TNUoS tariff into Peak Security and Year Round elements is overly complex and were unsure if the resulting separate incremental constraint cost signals are meaningful.
- 4.148 Some members also believed that the relationship between generation annual load factor and incremental constraint costs was not a robust one, and that generation annual load factor was not a significant factor in determining impact on incremental constraint costs.
- 4.149 Method 3 therefore proposes to do away with both the dual background (Peak Security and Year Round) approach and the use of a sharing factor based on generation annual load factor. It also uses the premise set out in Method 2 that a maximum of 50% of transmission network capacity can be shared on any transmission boundary.
- 4.150 This led to an approach that can be summarised as follows:
- 1) Calculate expanded zonal incremental kilometres using a single background with generation scaling factors similar to the Year Round (YR) background proposed in the Original.
 - 2) Derive the zonal transmission boundaries of influence and boundary length calculations using the YR background as set out above in paragraphs 4.127 to 4.130;
 - 3) Split generation TEC in each generation TNUoS zone into carbon (C) and low carbon (LC) and calculate cumulative proportions of C and LC TEC from each TNUoS charging zone to the centre of the transmission network using the zonal transmission boundaries of influence;
 - 4) Calculate the total shared incremental kilometres per boundary based on percentage of minimum of C TEC and LC TEC to total TEC behind a boundary;
 - 5) i.e. $\text{Min} [C \text{ TEC} / \text{Total TEC}, LC \text{ TEC} / \text{Total TEC}]$;
 - 6) Zonal shared incremental kilometres as a percentage of total incremental kilometres forms the zonal sharing factor (ZSF) applied to the wider tariff for that TNUoS charging zone; and.
 - 7) Results in a two part wider TNUoS tariff as follows:

$$(YR \times ZSF \times TEC) + (Residual \times TEC)$$

a) iii) Different treatment for positive and negative zones

- 4.151 In a minor change to one of the above potential alternatives, this approach would treat positive and negative TNUoS zones in a different manner when calculating charges.
- 4.152 The Workgroup discussed the current proposed treatment of TNUoS under the Original proposal in negative tariff zones. Some members of the

Workgroup considered that the application of a generation sharing factor to the Year Round element of the TNUoS tariff is less cost reflective than the baseline for negative zones and as a result improvements could be made to the proposed approach.

4.153 The Original proposal would calculate TNUoS tariffs in both positive and negative TNUoS zones for conventional power stations as follows:

$$\text{Peak Security } \text{£/kW} + (\text{Year Round } \text{£/kW} \times \text{ALF}) + \text{Residual } \text{£/kW}$$

4.154 The Proposer considered that the application of a generator’s annual load factor (ALF) to the Year Round element of the TNUoS tariff would make charging more cost reflective, taking into account the impact that an individual generating plant has on incremental transmission network costs.

4.155 Some Workgroup members considered that the effect of the Original proposal on TNUoS tariffs is to close the geographic differentials, meaning that in negative zones, generators’ TNUoS credit is significantly lower than is currently the case and the generators’ TNUoS charges paid in positive zones are lower. Some Workgroup members considered this to be more cost reflective than the existing ICRP approach and thus an improvement on the ‘baseline’; other Workgroup members disagreed.

4.156 Some Workgroup members believed that the effects highlighted above are correct only if the current TNUoS signal in negative zones is inaccurate; i.e. if it is over rewarding these power stations in negative zones and more generally in the southern part of the GB transmission system.

4.157 These members undertook some initial analysis within the ELSI model that calculated the impact on annual constraint costs of removing generation from the network, in order to test this. The results of this analysis, shown in Figure 28 below, compare annual TNUoS charges under the Original proposal (“Improved ICRP”) and the existing methodology (“Status Quo”) against the impact of removing the associated capacity of generation in the areas investigated.




Figure 28 – Comparison of TNUoS charges and impact on constraint costs (2012/13)

4.158 The Workgroup debated the analysis presented and considered the example of Centrica’s Langage CCGT power station (“Peninsula” in Figure 28). Some Workgroup members indicated that, under one scenario modelled, the analysis showed that removing Langage from the background of the model resulted in a system-wide increase in constraint costs of £9m per annum. This was believed by these members to be closer to the current TNUoS

credit of £5m per annum than the approximate £1m per annum TNUoS credit calculated by them using the Original proposal.

- 4.159 Some Workgroup members believed that, notwithstanding the fact that constraint cost savings should not necessarily equate to the same as the TNUoS payment, the change in the locational signal under the Original appears, at least in regions with low diversity, to be less cost reflective than the baseline (i.e. the existing methodology – “Status Quo” in Figure 28).
- 4.160 As a result of this analysis these Workgroup members considered that the Original proposal needs to be altered to make it more cost reflective in negative generation TNUoS zones and all TNUoS zones where there is little diversity of generation plant type.
- 4.161 Some members of the Workgroup questioned the input assumptions used to undertake the analysis set out above, and whether these assumptions were consistent with the underlying assumptions of the Original proposal. In particular, the assumptions used on transmission network boundary capacity were deemed important by some as the Original proposal is based on an optimally invested network, which would have a significant impact on constraint costs. Nevertheless, the Workgroup agreed that more work was required in this area.
- 4.162 Some in the Workgroup believed that suitable potential alternatives could include, but would not be limited to: (i) Applying TEC to the Year Round element of the TNUoS tariff rather than a generator specific sharing factor (based on a generator’s annual load factor); and / or (ii) Applying a diversity factor.
- 4.163 The majority of the Workgroup agreed that applying TEC to the Year Round element of the TNUoS tariff did not address the defect identified in the Original proposal and the Authority’s Direction; i.e. that TNUoS tariffs should reflect the differential impact of generation plant with different characteristics on incremental constraint costs.
- 4.164 Potential options and alternatives taking account of diversity are discussed above.

Q1: Do you believe that the Workgroup has fully considered the range of options for addressing how charging structures should be applied geographically to areas dominated by one type of generation, including on local circuits? If not, what other options would you like the Workgroup to consider and why?

b) Alternative approaches to ALF for reflecting user characteristics into charging

- 4.165 The Original proposal is for the Year Round element of the TNUoS tariff to be scaled by a generator specific sharing factor, based on the annual load factor (ALF) of the generator. This is to better reflect the impact that generators with different plant characteristics have on the incremental cost of transmission network capacity than is possible under the current approach. The purpose of this cost reflectivity is to allow individual generators to take the cost of transmission into account when making decisions about where to locate and when to close their plant.
- 4.166 The Original proposed approach is to calculate this generator specific Annual Load Factor (ALF) by using the last 5 years’ load factors for the individual power station concerned and calculate an average of the middle three values (i.e. ignore the highest and lowest values) as a proxy for the implicit

assumptions made when planning investment in transmission network capacity. This is illustrated in Figure 29, below.




Figure 29 – Calculation of ALF in the Original

4.167 The Workgroup discussed the benefits and drawbacks of the Original proposal in the context of the defect that CMP213 modification seeks to address, and developed a range of potential alternative options.

Relevant Background to Original Proposal

4.168 Under the Original proposal TNUoS remains a signal of long run (i.e. transmission network investment) costs. Network investment decisions are ostensibly driven by the Transmission License requirement on transmission companies to plan in accordance with the National Electricity Transmission System Security and Quality of Supply Standards (NETS SQSS) and an established link between the NETS SQSS and TNUoS exists within the charging methodology set out in section 14 of the CUSC.

4.169 The Transport model is and will, under the Original proposal, continue to be used to calculate the long run incremental cost at a given connection point on the transmission network. The proposed dual background approach, using both a Peak Security and Year Round background, ensures that this calculation remains consistent with updates to the NETS SQSS and thus maintains the link within the charging methodology.

4.170 It is proposed, in the Original, that locational incremental requirements on a transmission circuit route are allocated to one background or the other based on that leading to the maximum flows on that transmission circuit.

4.171 The scaling factors derived in the new NETS SQSS (under GSR-009) and used in the aforementioned two backgrounds were done on the basis of achieving transmission network boundary flows that result in a level of transmission network investment consistent with the outcome of a full blown cost benefit analysis (CBA). It is for this reason that these factors are valid for planning transmission network investment and for use in the Peak Security and Year Round backgrounds when calculating long run network costs in the Transport model.

4.172 Nevertheless, this very approach to calculating the NETS SQSS scaling factors is what potentially makes them inappropriate for calculating an individual generator's contribution to the need for this transmission investment. This is why it is necessary to go back to the original CBA approach upon which the background scaling factors are based, for it is only here that it is possible to investigate an individual generator's contribution to the need for transmission investment to the level of granularity required for cost reflective TNUoS charges (that are non-discriminatory in nature).

- 4.173 Ideally, when running the CBA resulting in the scaling factors, which in turn will lead to a certain level of transmission network investment, generators would tell the transmission company exactly what they were going to do over the 40 year transmission asset life and this would form an input into the CBA, allowing for the optimum investment and the ability to calculate charges on that basis.
- 4.174 However, some generating companies have made it clear during the Transmission Access Review (TAR) process that they cannot predict the future operation of their asset any better than a transmission company can. For thermal plant the limit was said to be beyond an approximately two year time horizon due to market variables such as fuel prices, CO₂ prices, etc. The Workgroup noted that this was not necessarily the case for individual generators with high upfront capital costs and low ongoing running costs. Nevertheless, some believed that the outcome of the TAR process was definitive.
- 4.175 Hence, as transmission access proposals with long term commitments from generators did not progress through the governance process to implementation, it is necessary for the transmission company to make assumptions about the characteristics of individual generators when undertaking their CBA. Some examples of these assumptions include the generating plant's capacity, efficiency, fuel prices, CO₂ prices, unavailability due to maintenance and faults, bid prices, offer prices, available subsidies, etc.
- 4.176 As outlined in the diversity section, above, it is clear that when the margin of generation capacity over and above peak demand is increasing, it would not be economic to build sufficient transmission capacity to accommodate the full output of all generators simultaneously.
- 4.177 Therefore, some implicit sharing by generation of network capacity does occur on the transmission network. The extent of this sharing is related to all the characteristics of individual generators outlined above, as assumed in the transmission network planning process.
- 4.178 In order to reflect transmission network sharing into the charging calculation for transmission network investment (i.e. long run) costs it is necessary to introduce a proxy for the assumptions made at the time of planning transmission network capacity about a generating plant's characteristics.
- 4.179 Through the results of market modelling (using the ELSI modelling tool) some in the Workgroup believed that a generating plant's annual load factor (which is a result of all its characteristics relative to the rest of the market) is a better proxy for its incremental impact on transmission costs than its TEC (MW) capacity alone.
- 4.180 It is for this reason that the Original proposal uses a sharing scaling factor based on a generator's annual load factor as a proxy for the assumptions made at the time of planning the transmission investment, the cost of which the TNUoS tariff is attempting to reflect.
- 4.181 The Proposer took the view that, in order to remain consistent with the sharing proposal and not introduce any perverse incentives or unnecessary complexity and volatility the sharing scaling factor:

should	should not
<ul style="list-style-type: none"> • in conjunction with TEC, contribute to the cost reflective signal, allowing generation plant to internalise the cost of transmission when making plant siting and closure decisions; 	<ul style="list-style-type: none"> • affect the efficient despatch of the most economic generation plant (i.e. running decisions) in a given market period;
<ul style="list-style-type: none"> • reflect implicit assumptions made about generation plant characteristics when planning the transmission network; 	<ul style="list-style-type: none"> • necessarily reflect actual, and potentially drastic, changes in generation plant characteristics in the short term;
<ul style="list-style-type: none"> • reflect the 'long-run' nature of investments in transmission network capacity and promote stability of TNUoS tariffs; 	<ul style="list-style-type: none"> • undermine the important commitment to pay charges for a set period, aspect of TNUoS tariffs;
<ul style="list-style-type: none"> • remain consistent with the implicit and ex-ante nature of the sharing assumption (i.e. Users do not provide explicit information); and 	<ul style="list-style-type: none"> • place additional burden on Users with the need to provide additional information as this was found to be too difficult under TAR; and
<ul style="list-style-type: none"> • be calculated in a simple, deterministic fashion to avoid the need for complex incentives and therefore promote simplicity and predictability of TNUoS tariffs. 	<ul style="list-style-type: none"> • place additional burden on Users with the need to predict the actual characteristics of competitors plant in order to forecast TNUoS tariffs.

4.182 The Proposer and some in the Workgroup believed that the Original proposal for the calculation of ALF had the following benefits:

- It recognises that most transmission network capacity is planned as a trade off with future potential constraint costs in a manner consistent with the NETS SQSS by introducing both a Peak Security and a Year Round element to tariffs;
- It utilises the relationship between generation annual load factor and constraint costs to calculate a simple proxy for the assumptions made when planning transmission network capacity;
- In doing so it takes into account the characteristics of a specific generating unit and its impact on the incremental cost of transmission network capacity, thereby increasing the cost reflectivity of TNUoS tariffs;
- By using the historic metered output of a generating unit to calculate an ex-ante annual load factor for the upcoming TNUoS year it maximises simplicity and transparency of commercial arrangements and the predictability of TNUoS tariffs for all Users;
- It minimises additional burden on transmission network Users by not requiring additional information from generators;
- An ex-ante approach does not undermine the commitment to pay TNUoS tariffs, for a fixed period, aspect of TNUoS (i.e. Users cannot avoid TNUoS simply by not running); and
- By using an average over a number of years and removing outliers it promotes stability of TNUoS tariffs and is more consistent with a cost reflective signal that is based on long-run incremental costs.

4.183 Others in the Workgroup believed that the Original proposal had the following disadvantages:

- It could be perceived as blurring the boundary between transmission (TNUoS) charges (to reflect and recover the long term costs of providing the transmission assets) and transmission system balancing (BSUoS) charges (to recover the cost of balancing the transmission system);
- It was not clear that the ALF approach is more cost reflective with the transmission system being developed in line with NETS SQSS (as amended by GSR009 which acts as a proxy for a full cost benefit analysis); and
- It could be perceived as backwards looking: a generator's past performance is not necessarily a good indication of its future use of the transmission network. For example, annual load factors for thermal generation will change depending on which fuel is in merit. In addition, annual load factors for such plants are expected to change as more wind generation connects to the transmission system. This could be an issue for generation seeing reduced annual load factors that would still be charged on a basis of higher usage in earlier years. The Workgroup also noted that the converse would be true for generation seeing increases in annual load factors.

4.184 The Workgroup also discussed the fact that the Original proposal would calculate ALF based on 5 years of historic data with the highest and lowest values removed and averaging the remaining three. As some in the Workgroup believed that the sharing scaling factor (i.e. ALF) should be representative of a generator's actual load factor, analysis was undertaken comparing the difference between calculated ALF and actual load factor using historic data for individual generators. An ALF method based on the Original proposal, based on a simple 3 year average of historic and based on the load factor from the previous year were investigated.

4.185 The conclusion of this analysis, the detail of which is presented in Annex 9 – Annual Load Factor Under the Original, was that the differences between a 5 and 3 year calculation were extremely small, but also that the difference between each of these and the actual load factor compared to the difference when using a single preceding year was not discernable for all generators analysed. Whilst there was some variation when looking at individual plant types, the general conclusions still held. Therefore the Workgroup did not investigate further the calculation of ALF using a different number of historic years.

4.186 Options and potential alternatives developed by the Workgroup to address the perceived disadvantages to the Original proposal range from making the ALF less specific, to making it more so. These are outlined in Table 15, below.

Num.	ALF	Description	Updated when?
i	TEC (MW)	ALF=100%, same charging result as approach used currently in the TNUoS charging methodology	TEC register
ii	NETS SQSS generic	Generation plant load factors from GSR-009	NETS SQSS updates
iii	Other generic	Generic historical average per generation plant type	At each Transmission Price Control Review
iv	User forecast	Ex-ante annual forecast, provided by the User, with ex- post reconciliation	Annually
v	Hybrid	Original proposal with option for User to provide own forecast (as per (iv))	Annually

Table 15 – Potential options and alternatives for ALF

b) i) TEC Only

4.187 This potential alternative would simply avoid the application of a sharing factor in the TNUoS tariff calculation altogether. Whilst the two part Peak Security and Year Round tariff elements would remain, the final TNUoS charge under this approach would be almost identical to that under the current Status Quo approach used in the charging methodology.

4.188 The Workgroup believed that this option, in its uniform treatment of all generation plant by using their TEC (MW) capacity only, was inconsistent with the Authority's SCR Direction and the Defect highlighted by the Proposer, in the Original proposal (see above and Annex 5 – Detail of Original Proposal), to better reflect the impact generators with different characteristics have on the cost of incremental transmission network capacity.

4.189 For this reason and the fact that the existing TNUoS charging approach would always remain an option if the Authority rejected the Original and any WACM(s), the TEC only option was discarded as a possible alternative by the Workgroup.

4.190 The Workgroup noted that the potential alternatives under consideration for the sharing aspect of the Original that take account of generation plant diversity and the potential for different treatment between positive and negative TNUoS zones, set out above, could include capacity (MW) based elements.

b) ii) & iii) SQSS or Other Generic load factor

4.191 Another potential alternative approach would be to use a generic annual load factor for all types of generating plant, potentially using (i) the background scaling factors set out in GSR-009 or (ii) the generic load factors based on historic data put forward in the Original proposal for use when actual metered data is not available (e.g. for new generators).

4.192 Some in the Workgroup believed that this could provide advantages over the Original proposal in that it could be perceived as:

- More closely related to the transmission investment decisions in line with the NETS SQSS as amended by GSR-009 (noting that the Original proposal deemed this approach invalid due to the way in which NETS SQSS factors have been calculated with a focus on transmission boundary flows);
- More consistent with the long run nature of transmission network investment (i.e. the sunk cost of transmission investment does not change with the characteristics of generation plant over time). The Workgroup noted that the TNUoS signal was ostensibly a forward looking one.;
- More stable avoiding year on year fluctuations caused by volatility in fuel prices, generator maintenance plans, etc.. Some in the Workgroup believed that the ALF calculation proposed in the Original would be sufficiently stable given that it is, in essence, a rolling average; and
- Removing an element of complexity and volatility making TNUoS charges more simple and predictable.

4.193 The drawback to this approach is that the generation technology categories may be too wide, potentially leading to significant variation within one technology category (for example, depending on where in the life cycle a gas plant is, or whether wind is onshore or offshore). It may be possible to develop more specific categories to address this. The Workgroup investigated historic bid and offer prices to see if more granular generic load factors could be developed in a non-discriminatory fashion.

4.194 Whilst the analysis did show discernable groupings for high level plant types (i.e. wind, nuclear, coal, CCGT), it was not deemed possible to distinguish with any increasing granularity to achieve more specific generation technology categories.

4.195 Analysis was also undertaken on the above potential alternatives to illustrate the effect of using generic generation annual load factors, in preference to specific generation annual load factors, on the cost reflectivity of the solution. Both the northern Scotland (Planning Zone T) and southern Scotland (Planning Zone S) regions of the transmission network were investigated and generator's annual load factor vs. incremental constraint cost graphs created for specific load factors (i.e. actual modelled LF), GSR-009 based load factors and generic historic load factors as outlined above.




Figure 30 – Zone S; Use of generic factors in preference to specific actual




Figure 31 – Zone T; Use of generic factors in preference to specific actual

4.196 The results of the analysis undertaken for two areas of the transmission network (North of Scotland –‘T’ and South of Scotland –‘S’) illustrated in Figure 30 and Figure 31, above, show that the use of GSR-009 scaling load factors would not adequately distinguish between generating plant of different characteristics in a non-discriminatory manner.

4.197 Whilst the use of generic, historic, load factors by generation plant type is shown to be better than the GSR-009 scaling factors, it was noted by the Workgroup that increased granularity of plant type would be required in order to achieve something that was approaching the cost reflectivity of the annual load factor based approach proposed in the Original.

More Specific Approaches

4.198 In order to more accurately reflect transmission system usage and sharing by generation, a more specific annual load factor approach has also been discussed by the Workgroup.

4.199 If a more specific approach was favoured, the Original proposal provides benefits compared to the generic load factor approaches discussed above. However, some Workgroup members felt that the Original proposal was not specific enough, and by reflecting historic rather than future use it cannot take account of situations where a generation plant is subject to a change in its role in the wholesale electricity market.

4.200 Others in the Workgroup were of the view that the TNUoS charging signal should not necessarily reflect sudden changes in the position of a generation plant in the wholesale electricity market,

4.201 The Workgroup discussed two high-level types of change in role:

Periodic step changes:

- These changes may occur on a regular (e.g. change in season) or irregular (external influence) basis;
- Regular changes are more likely to “average out” year to year, meaning the generator would only be subject to short-term gains and losses; and
- Irregular changes are less likely to average out and could be unidirectional;.

One-off step changes:

- These changes will tend to have a unidirectional effect on a generation plant’s load factor that will not change in the foreseeable future;
- The event may be predictable, such as the date that a new regulation comes into force or a fuel supply contract ends; and
- It could also be unpredictable, such as a catastrophic generation plant failure.

4.202 The Workgroup discussed several different scenarios in more detail, which are all included in Annex 6 – ALF vs. Annual Incremental Cost Analysis. However there was not a consensus amongst the group as to whether the calculation of a sharing factor should closely match a change in role of a particular generator year on year.

4.203 Some Workgroup members noted that many of the scenarios discussed would currently have to be managed by generators under the existing charging approach, that generators would still have the option to increase or reduce their TEC for some permanent changes, and most importantly that many of changes considered would not be taken into account by the transmission network planner and hence would not have an immediately obvious impact on the incremental cost of capacity planned using cost benefit analysis techniques.

4.204 Others in the Workgroup were clear that they believed a more specific approach would be more cost reflective and potential alternatives were discussed in the group, as set out below.

b) iv) NGET and/or User forecast

4.205 A potential alternative approach to the Original proposal would be to have a full forward looking forecast of generation plant load factor for the next (charging) year provided by each individual User (prior to the start of the charging year). This would give the generator an opportunity to signal, to National Grid, what it intends to use (in the context of transmission network capacity), rather than being held to its past plant performance.

4.206 Some in the Workgroup believed that it would be logical to time the provision, by the User to NGET, of such a forecast with the timescales for notification of TEC reduction (i.e. 1 year and 5 days ahead of the TNUoS charging year in question) to remain consistent with the current length of commitment to pay TNUoS charges. Others believed that User forecasts could be provided in the November before the start of the (April) TNUoS charging year, before NGET publish draft TNUoS tariffs in December.

4.207 The disadvantage of this approach is that there would be an incentive for a generator to underestimate its forecast annual load factor, unless some form of incentive and ex-post reconciliation was included, in order to obtain a lower TNUoS charge. Full overrun charging, such as proposed in CAP162, might not be possible as it would be a locational constraint charge which could be interpreted as not allowable under the Transmission Licence (due to a restriction put in place at the time of Connect and Manage, not to target the impact of Connect and Manage locationally).

4.208 However, a simple incentive could be created such as charging a multiple of the TNUoS for any overrun over and above the forecasted annual load factor. For example, a generator could be charged twice its normal TNUoS rate for any overrun. An underestimate of its annual load factor by 10% would result in the generator paying 110% of the charge it would have paid had it estimated its load factor correctly. Thus, in a simple example, if a generator forecast an annual load factor of 50% and, as a result, it was due to pay £500k in TNUoS but ended up having an outturn annual load factor of 60% it would be charged £660k (£100k for the 10% extra plus £60k as the 10% additional charge / incentive).

4.209 In order to keep the incentive on the generator to estimate its annual load factor as accurately as possible, it would not seem appropriate to allow refunds for any over estimates (by the generator). Otherwise, the generator could play safe and estimate as high a load factor as it could (100%) and receive a refund to reflect the actual value. Any over recovery of allowable revenue made because of these charges could be rolled over to offset against the allowable revenue to be recovered in for the next TNUoS charging year. For negative TNUoS zones the incentive might be to overestimate the annual load factor so as to expose the generator to a higher negative TNUoS charge.

4.210 The possible arbitrary nature of a 'doubling' factor and concerns about the potential that any overrun charge could be considered as penal were noted. However, some members believed these factors already exist in other areas of the charging methodology and that further work could be done to balance the incentive provided and the cost reflectivity. It was suggested that any bandwidth / margin developed on an estimate would itself involve an incentive to under / over forecast.

b) v) Hybrid Approach

4.211 Both the Original proposal and the User forecast options set out in the preceding section provide more specific estimates of a generator's annual load factor. As discussed above, both options have benefits and drawbacks. A potential hybrid option would allow each generator to decide (on an annual basis; possibly with a year and 5 days notice or the November prior to the start of the charging year in April) whether to accept National Grid's annual load factor forecast for its plant (the Original proposal) or whether to submit its own forecast of its forecast annual load factor.

4.212 This would allow generation plant that do not expect a change in running hours (for example low-carbon generation) to benefit from the simplicity and stability of the Original proposal, and avoid exposure to an ex-post reconciliation process. At the same time it would allow those generators who are expecting their annual load factors to significantly change from historic performance (for example thermal generators expecting a reduction in load factor due to increased intermittent generation on the transmission system, or a plant planning a long outage for maintenance) to signal this and avoid being, what some in the Workgroup believed was, overcharged for transmission network capacity it will not use.

4.213 Other Workgroup members believed that the ALF calculation in the Original proposal would be more cost reflective of the long-run nature of transmission investment and the kind of assumptions made by transmission planners when undertaking cost benefit analysis for investments in transmission capacity. Consequently, these members did not believe that the averaging effect of the ALF was overcharging for transmission network capacity and that it was more reflective of incremental costs than both the existing

capacity based (i.e. TEC only) approach and a more specific factor that changed year on year.

4.214 The Workgroup considered two possible downsides of the Hybrid approach:

- Generators would likely only self-report changes to their annual load factors that are in a favourable direction; i.e. reductions in load factors in positive charging zones and increases in negative charging zones; and
- The ability of generators to significantly reduce TNUoS tariffs ahead of their plant closure: it would be possible for a generator to declare a 0% annual load factor to remove the Year Round element from its TNUoS charge (it would still be charged for Peak and Residual – unless it is intermittent in which case it is only the Residual, so it would not be possible to receive a ‘payment holiday’ by declaring a 0% ALF). Nevertheless, given the relative size of the Year Round element of TNUoS charges in some areas of the transmission network, such an approach could have a significant effect on the commitment aspect of TNUoS (i.e. the requirement to provide a year and five days notice or TEC reduction to avoid an annual commitment to pay TNUoS) in these areas.

b) vi) Alternative Measures for ALF

4.215 The Original proposal provides for calculation of a sharing factor, annual load factors – ALFs, based on the 5 years historic output of each individual generation plant. Currently the ALF would be calculated based on each power station’s metered output (MWh) and TEC (MW).

4.216 The Proposer confirmed that NGET would calculate each generators’ ALFs no more frequently than on an annual basis (in the absence of any extraordinary circumstances) to have effect throughout the following charging year.

4.217 For the potential alternatives pertaining to the inclusion of a generator ALF in the TNUoS charge calculation, the Workgroup also considered the following alternative different data sources to metered output in calculating ALF:

- Use of Final Physical Notification (FPN) as an alternative to metered output; or
- Forward looking Grid Code data items that could be used to provide a forecast output slant on the ALF calculation.

4.218 The potential for a better approach to calculating historical ALFs was discussed by the Workgroup during their fourth meeting. The debate focused on whether a historical generator ALF should be based on metered output or historical FPNs (PN at Gate Closure). The key points of the discussion were:

- Metered output is wholly reflective of actual generator output and it is simple to source and collate. However, it could be “distorted” by System Operator action in the balance mechanism (e.g. BOAs, constraint management contract instructions, etc.); and
- FPNs are a forecast and therefore may differ from actual output (and therefore use of the transmission system). However, FPNs are a statement of commercial intent by the generator; i.e. leaving aside the constraints or needs of the System Operator, the FPN represents the extent to which a generator would use the transmission system during a particular settlement period.

4.219 Workgroup members questioned what ALF was intended to, or should represent. Should ALF be a reflection of a generator’s actual export to the transmission system or should it be an expression of the extent to which a

generator would use the transmission system but for the limitations that the System Operator may impose on that generator?

- 4.220 The Workgroup believed that it could be argued that use of metered output would suppress ALFs for generators connected behind transmission constraints, where generation was curtailed due to network limitations. Calculating ALFs in a way that reduces TNUoS costs, relative to those TNUoS costs that would arise through use of an ALF based on FPN, to generators that are also considered to be particularly associated with constraint costs may be perceived as being not in the best interest of effective competition in generation.
- 4.221 However, during the discussions in Workgroup meeting 4, the possibility of a generator that is not connected behind a transmission network constraint intentionally withholding (MW) capacity with a view to deploying that capacity in the Balancing Mechanism (BM) marketplace was also considered. In such circumstances, an ALF based on a generators' FPN may be considered to artificially suppress the TNUoS costs of that generator.
- 4.222 In considering the best approach on balance, the Workgroup returned to the discussion of why ALFs were being proposed in the first place. The ALF is proposed as an approach to adjusting TNUoS charges in order to reflect the differential impact on incremental transmission network costs of different generation plant types, a feature driven by the Authority's Direction to better take account of "*the economic trade-off each Transmission Owner makes between expected constraint costs and the cost of new transmission reinforcements*". If the driver for the ALF is to more effectively target transmission investment signals channelled through constraint costs it would seem counterintuitive to then ignore the effect of constraints upon the ALF.
- 4.223 Ultimately most Workgroup members agreed that there are potential flaws associated with both the Metered Output and FPN approaches to determining the ALF. However, the Workgroup noted that a calculation based on actual Metered Output would appear to deliver an ALF more aligned with the aims of the Project TransmiT SCR and the Defect identified by the Proposer (in CMP213) than an ALF based on FPN.
- 4.224 In addition to the above, the Workgroup also considered the possibility of using other forward looking data that may be available through the commercial framework.
- 4.225 The Workgroup felt that the ALF calculation approach set out in the Original proposal was blind to any forecast operating information that may be available from the generator and which may give a useful indication of a generator's plans to deviate from the "routine" operating pattern indicated by the 5 year historical average based approach for determining the ALF. Such information may be particularly relevant to generating plant that can contemplate base load or flexing operation.
- 4.226 The Workgroup noted that ideally no additional information would be requested from generators.
- 4.227 There the following forward looking Grid Code data items already provided by generators to NGET were considered by the Workgroup as potentially being appropriate for inclusion in an ALF calculation approach:

BC1 - Pre-Gate Closure

- PNs (and FPNs) – duty to provide PNs at 11:00am of the day prior to the trading day.
- Maximum Export Limits (MEL)
- Bid offer data (including dynamic parameters, QPNs etc.)

OC2 – Outage Planning

- OC2 Data – Outage planning up to 5 years ahead of real time.

Planning Code Data

- Output Data – Specifically, Output Data submitted annually by generators under PCA3.2.

4.228 The Workgroup discussed the fact that BC1 data is a short term view of likely generation plant operation. BC1 data is typically submitted or updated so close to real time as to be irrelevant for the purposes of a calculation that is conducted annually and which seeks to provide a medium to long term indication of ALF.

4.229 Planning Code Output Data (taking account of OC2 data), on the face of it, was considered to convey a generator’s forecast operating patterns which would seem likely to be of interest to NGET in establishing a generator’s forecast take up of transmission system capacity. Whether this data can be incorporated into a “simple” ALF calculation approach was unclear (and the benefits of using this data relative to using a “User Forecast ALF”, as proposed in the possible alternative above, is also unclear).

4.230 The Workgroup concluded that if a forward looking approach was desired, either in part (as a feature of a hybrid approach) or in full, a User Forecast ALF with appropriately weighted incentives (as outlined in the potential alternative described above), would seem a more efficient and effective approach relative to the use of forward looking Grid Code data.

b) vii) Ex-ante or Ex-post

4.231 As set out above, the Original proposal would derive a generator specific Year Round TNUoS tariff (utilising the zonal Year Round tariff and a generator specific ALF), which will be applied to all generators to better reflect their use of the transmission system and provide signals as to where to most efficiently locate new generation (and retire old generation).

4.232 A key element of this calculation will be the application of an ex-ante Annual Load Factor (ALF), based on an average of each generation plant’s historic load factors (using running information from the previous 5 years, with the highest and lowest discarded).

4.233 The Workgroup considered that either an ex-ante or ex-post approach could be used to derive generator specific or generic ALFs. These are discussed in more detail below, along with the associated benefits and drawbacks.

4.234 An ex-ante ALF would be calculated using each generators’ previous years’ data (as in CMP213 Original), or forecast by either NGET or the generator and then applied at the start of the TNUoS charging year (1st April). It is assumed that under a “pure” ex-ante approach, there would no reconciliations or changes to ALF against the actual running of the particular generation plant during the charging year in question.

4.235 The Workgroup noted that using the historic data generation plant load factor (produced by NGET) or the forecast generation plant load factor (provided, in advance, by each generator) to derive forward-looking TNUoS charging signals through an ex-ante ALF could be argued to be more consistent with the ICRP principles that underpin TNUoS. It could provide a better proxy for transmission investment decisions that the Transmission Licensees make and that generators should consider in their own investment decisions.

Ex-ante

- 4.236 The ex-ante determination of ALF would provide generators with clarity of the ALF that is to be used to calculate their TNUoS charges for each charging year and is unlikely to overly influence operational decisions.
- 4.237 If an averaging approach (such as the 5 year one used in CMP213 Original) is adopted in the ex-ante ALF, the impact on generators operational behaviour is likely to be further limited, therefore maintaining the distinction in signals between TNUoS and BSUoS. The Workgroup believed that, if this benefit is realised, an ex-ante application of ALF could also result in more stable ALFs year-on-year. In addition, it could mitigate instances of generators reducing their annual load factors to achieve TNUoS “payment holidays”.
- 4.238 The key drawback to the use of an ex-ante ALF is that it will not reflect known market and operational conditions that impact the running regimes of (particularly conventional) generation plant. In particular, it will not take account of:
- Known changes to the generation merit order arising from variations to fuel prices;
 - Long-term planned generation outages for large-scale maintenance/overhaul;
 - Mothballing of generation plant; and
 - Time limited generation running hours under LCPD and IED.
- 4.239 For example, current and forecast gas prices mean that many marginal gas generation plants are unlikely to run significantly (if at all) for the foreseeable future (2-3 years out). Ex-ante ALF calculations will not take account of these forecast changes to generation running regimes when setting TNUoS charges. If the premise of TNUoS charging is to remain forward looking and cost reflective, it could be argued that this effect may not be consistent with the underlying TNUoS charging principles.
- 4.240 Some Workgroup members argued that year on year changes to a generators running regime in the short-term would be unlikely affect incremental transmission network capacity requirements and that a historic averaging approach was therefore not inconsistent.

Ex-post

- 4.241 Under an ex-post approach, ALF would be calculated using data (for example metered output or bid/offer information) taken throughout a charging period and used to derive generation ALFs and resultant TNUoS charges that would be recovered at the end of that charging period. The Workgroup noted that the charging period referred to here is likely to be monthly / quarterly / seasonally rather than the ‘traditional’ single charging year (1st April to 31st March).
- 4.242 There are a number of approaches that could be used to calculate the ALF ex-post. They are all likely to produce ALFs that better reflect generation plants’ running regimes over the charging period but would also be significantly more volatile as they would require either monthly/seasonal profiling or end of (charging) year reconciliations to ensure appropriate revenue recovery. Possible models could include:
- An ex-post rolling monthly ALF and charge; and
 - An ex-post quarterly/season ALF and charge.

- 4.243 Some Workgroup members believed that an ex-post approach to setting generation ALF would invariably lead to a more accurate ALF that could be used in the derivation of TNUoS charges. In particular, it would better take account of factors that change the running regimes of (particularly conventional) generation.
- 4.244 However, the Workgroup noted a number of potential drawbacks to calculating ALFs on an ex-post basis. In particular is that it could begin to blur the distinction between the roles of BSUoS and TNUoS, in that it could become an operational signal rather than the intended locational signal of the cost of incremental transmission network capacity. Generators could start to factor in the ability to reduce their ALF in to their operational decisions, in order to benefit from reduced TNUoS charges.
- 4.245 Further, in being backward looking, ex-post ALFs would likely de-link TNUoS charges from the forward looking transmission investment decision making process upon which they are meant to be predicated. The Workgroup understood that Transmission Licensees do not make transmission infrastructure investments based on generators' historic running regimes; rather they are made using forecasts of future market conditions and associated generation annual load factors over a number of years.
- 4.246 Finally, the Workgroup believed that introducing ex-post elements to the TNUoS charge could result in significant TNUoS charging shocks for generators. Material changes to the load factors assumed for individual or classes of generators could result in large reconciliations being required during or at the end of each charging period, in order to ensure accurate revenue recovery. Whilst this could be mitigated to some extent through profiling or shorter charging periods, it would still result in TNUoS charges that could vary significantly over relatively short timescales. The risks associated with this potential volatility (in TNUoS charges) would then likely be factored into generator costs / operating decisions (leading to higher wholesale, and thus end consumer, prices).
- 4.247 Whilst some Workgroup members preferred an ex-post based approach, the majority supported an ex-ante approach to calculating the generator ALF for TNUoS charging purposes.

Q2: Do you believe that the Workgroup has sufficiently reviewed all the necessary options on how a sharing factor (i.e. ALF) could be calculated. Are there any areas that you think may need further development? If so, please specify along with an associated justification.

c) Whether intermittent generation technology types should be exposed to the peak element of the tariffs

- 4.248 The Original proposal would split the existing wider locational element of the TNUoS tariff into two elements, the Peak Security element and the Year Round element, consistent with the bifurcation of backgrounds in transmission planning introduced into the NETS SQSS through GSR-009.
- 4.249 In addition the Original proposal would levy the Year Round element on all generation plant types in proportion to their ALF (a generator specific load factor based %) and TEC (MW), whereas intermittent plant types would not be exposed to the Peak Security element on the basis that these plant are not considered present at times of peak demand when planning transmission network capacity at times of peak demand (i.e. the NETS SQSS does not plan capacity for intermittent generation at peak).

4.250 The resulting tariff structure is shown in Figure 32, below.




Figure 32 – Tariff structure in the Original Proposal

4.251 The Authority's SCR Direction specifically set out a consideration of whether intermittent generation technology types should be exposed to the Peak Security element of the TNUoS tariff. The Workgroup considered 2 possible changes to the Original that could be made:

- i) That intermittent plant were exposed to the Peak Security element to some extent; or
- ii) That intermittent plant exposure to the Peak Security element be index linked to an appropriate factor.

c) i) Exposed to some extent

4.252A potential alternative approach could be where intermittent generation would be exposed to a proportion of the Peak Security element of the TNUoS tariff. The Workgroup began by considering both how often intermittent generation (predominately wind) would run over times of peak demand and how the NETS SQSS GSR-009 group came to their conclusion to scale wind to 0% when planning for demand security at peak.

4.253 The Workgroup discussed the fact that the two main reasons why wind generation often has a low output over times of peak demand is that peak electricity demand in GB tends to occur during the coldest weather in a year and that these cold weather periods normally coincide with high pressure systems in which wind speeds are very low.

4.254 This is exacerbated by the fact that at very low wind speeds, there is insufficient torque exerted by the wind on the wind turbine blades to make them rotate. However, as the speed increases, the wind turbine will begin to rotate and generate electrical power. The speed at which the wind turbine first starts to rotate and generate power is called the cut-in speed and is typically between 3 and 4 metres per second (of wind at the hub height).

4.255 Use of historical weather data is often used as a means of estimating wind production. Actual wind farm production data is available, but is limited in extent. By way of illustration, both wind speed and temperature data was obtained from the Glasgow area for the years 2006 – 2012. This data, with an hour by hour granularity, was reduced to the months of November, December, January and February between the times of 16:00 and 19:00 (i.e. 3124 periods in total) on the basis that these are the times when peak electricity demand is most likely to occur.

4.256 The frequency of a given wind speed by temperature was subsequently plotted and is shown in Figure 33, below.




Figure 33 – Glasgow Frequency of Wind Speed by temperature

4.257 The above plot shows that the temperature during the aforementioned periods varied from -11 °C to 14.5 °C, whilst the wind speed varied from 0 m/s to 31 m/s. The plot also shows a clear relationship between temperature and wind speed, with the mean and deviation increasing with temperature. The dark blue areas represent an occurrence of wind speed at a given temperature of between 0 and 5 periods (i.e. between 0% and 0.2% of the sample set), the red indicates an occurrence of between 5 and 10 periods (i.e. between 0.2% and 0.3% of the sample set), etc.

4.258 Despite the fact that wind speeds have not been converted to those expected at hub height (i.e. speeds would normally be expected to be somewhat greater at hub height) a representative cut-in speed is overlaid along with a representation of the historic maximum temperature over the appropriate GB Triad periods in order to assist in visualising the proportion of time wind generation that could have been at 0% output over times of peak electricity demand. This is shown below in Figure 34.




Figure 34 – Glasgow Frequency of Wind Speed with Temperature w. Turbine cut in speed and representative max. historic temp.

- 4.259 The Workgroup agreed that the above analysis is by no means conclusive for a number of reasons (including the simplifications highlighted). However, the Workgroup agreed that it does corroborate the notion that wind generation output over times of peak electricity demand (i.e. the time at which the transmission network is planned for demand security) is more likely to be less than at times of lower electricity demand, when the temperature is higher. The GSR-009 NETS SQSS modification group came to a similar conclusion using a different and much more substantial data set.
- 4.260 It was noted that the GSR-009 consultation stated, “A scaling factor of 0% for intermittent generation is simplest to articulate and implement, but analysis of the wind data supports the inclusion of wind generation at 5% of Registered Capacity. This is because, against the dataset used, the GB 2020 wind fleet will be at 0-2% total output for an average of only 4 hours per year; whereas it will be at 2-7% output for an average of 160 hours per year. The working group’s view is that there will be limited practical difference if a factor of 0% is used (especially given the scale of most transmission reinforcements), but requests industry views on the proposed 5% level at which to include intermittent generation in a demand security assessment. Wind generation is expected to account for the vast majority of Great Britain’s intermittent generation for the foreseeable future.”
- 4.261 On the basis of the above, the Workgroup considered the possibility of intermittent being exposed to the proposed Peak Security element of the TNUoS tariff. It was considered that this contribution may be justified somewhere around 5% (from the GSR-009 conclusions) or above, but that it likely be much less than 100% given the proportion of the year that wind generators are at this level of output as illustrated above in Figure 10 Figure 10 – Simplistic illustration of output from different types of generation.
- 4.262 Some Workgroup members noted that one difficulty with this approach would be the justification for this exposure to the Peak Security element. Despite actual historic wind output over times of peak demand, the deterministic standards against which transmission network capacity for demand security reasons is planned currently dictates that wind generation has no influence on the incremental need for transmission network capacity at times of peak electricity demand.
- 4.263 A potential alternative considered would be to update TNUoS charging as and when the NETS SQSS plans for intermittent generation to be present at peak conditions (see below).

c) ii) Index linked to something

- 4.264 The Workgroup considered whether the exposure of intermittent generation plant to the Peak Security element of the TNUoS tariff could be index linked to something and agreed that the most appropriate linking would be directly with the NETS SQSS.
- 4.265 It was believed that this approach would ensure that the TNUoS charging arrangements remained consistent with the NETS SQSS if wind generation were to drive transmission investment at peak in the future.
- 4.266 The mechanism by which this linking could be achieved would be to add a plant type (PT) multiplier to the Peak Security element of the TNUoS tariff. The Workgroup considered that this multiplier would be set to 1 for conventional plant and 0 for intermittent plant in the Original proposal.

Q3: On the subject of whether intermittent generation should be exposed to a Peak Security element of the tariff, do you have any views in addition to those discussed by the Workgroup?

Potential Alternatives

(i) Sharing potential alternative 1 – Sharing applies to local

4.267 The Original proposal would apply the concept of sharing to the entire wider transmission network (i.e. it would reflect the differential impact on incremental network costs of generation plant with differing technology characteristics). However, when planning local transmission circuits for generation, the Original proposal recognises that this is normally done on the basis of generation plant capacity (MW) and the various other characteristics of plant therefore do not tend to lead to a different impact on the need for transmission capacity.

4.268 A number of Workgroup members challenged this assumption, arguing that there is some sharing on local transmission networks and that there is likely to be more in the future. There was general agreement in the Workgroup that transmission network sharing should be signalled to generators where it occurs, but there was debate over the timing of the charge, the evidence required and how exactly this should be translated into TNUoS tariffs.

4.269 The Workgroup discussed how local transmission circuits would be planned and also requested a clarification of the distinction between network capacity treatment in the transmission TNUoS charging calculation and transmission network planning. These are covered in turn below.

4.270 The discussion of the Workgroup in this area related to the diversity issue outlined above in that it considers the concept of sharing on local transmission circuits where it is actually deemed to exist (or could potentially exist in future). The group considered that this was similar to the diversity it sought to apply the concept of the differential impact on incremental constraint costs of different generation plant types with a greater granularity than the Original proposal. Both were considered to be seeking to adjust the transmission boundary where sharing is accounted for.

Planning of ‘Local’ Circuits

4.271 Network investment decisions are made by Transmission Owners in accordance with their Transmission Licences. These stipulate that the network should be planned to the NETS Security and Quality of Supply Standards (NETS SQSS). Within the NETS SQSS, the nearest concept to ‘local’ (in the TNUoS sense) is that of a ***Generation Circuit***, which is defined as, “The sole electrical connection between one or more onshore generating units and the Main Interconnected Transmission System i.e. a radial circuit which if removed would disconnect the onshore generating units.”

4.272 For generation TNUoS tariffs, the locational element is comprised of both a ‘local’ and ‘wider’ component. The boundary between the ‘local’ and ‘wider’ transmission network, for charging purposes, is defined on a nodal basis. From the generator’s perspective the wider transmission network begins at the first Main Interconnected Transmission System (MITS) node. MITS nodes are defined, in the CUSC, as:

- Grid Supply Point connections with 2 or more transmission circuits connecting at the site; or
- Connections with more than 4 transmission circuits connecting at the site.

- 4.273 Therefore, any transmission circuit between a generator and the first MITS node is considered a ***Local Circuit***.
- 4.274 Whilst there is significant overlap between the definition of a *Generation Circuit* and a *Local Circuit*, the two are not synonymous. Nevertheless it is likely that, in most instances, a *Generation Circuit* would be a subset of the *Local Circuit* (i.e. the *Local Circuit* would be expected to extend deeper into the transmission network).
- 4.275 *Generation Circuits*, as defined in the NETS SQSS and set out above, are designed to background conditions that set the active power (MW) output of the power station equal to its *registered capacity*. Registered Capacity is defined as the maximum amount of active power (MW) deliverable or normal full load capacity (in the case of a CCGT or power park module) as declared by the generator at the Grid Entry Point.
- 4.276 This is equivalent to a generator's Connection Entry Capacity (CEC) as defined in the CUSC, which a generator declares within the Standard Planning Data submissions forming part of their application for connection to the transmission system.
- 4.277 Consistent with the above, the NETS SQSS states that the minimum capacity of a *Generation Circuit* is normally planned to 100% of CEC. This is currently under review in GSR-010,⁹ which proposes to formalise existing practice in some geographic areas within GB where the characteristics of the generation connected can be taken into account when planning *Generation Circuits*. Under these GSR-010 proposals the deterministic minimum criteria would be amended to reflect the differing size (capacity, MW) and intermittency (load factor, %) of new generation technology, effectively reducing the level of redundancy provided for small and intermittent generation. The Workgroup noted that GSR-010 was not proposing to alter the capacity, only the number, of transmission circuits for a given connection.
- 4.278 Regardless of the minimum capacity requirements dictated in the NETS SQSS it is generally not possible for the Transmission Owner to match generation capacity requirements exactly in an economic manner (due to the finite amount of varying sizes of transmission equipment available). As such, the actual transmission network capacity put in place is often greater than the minimum required by generation.
- 4.279 Beyond *Generation Circuits*, but within the definition of a *Local Circuit*, it is also possible that the TO will be aware of a number of generators wishing to connect, but will not have financial commitment from all of them. In this case, where it is not possible to economically build incremental transmission capacity for each project (such as is the case with island connections), the TO would need to take a view as to how much generation may come along in future. In these instances it is also likely that transmission circuits could be oversized to accommodate future generation development in the most economic manner.
- 4.280 The Workgroup noted that, whilst the NETS SQSS sets out minimum transmission capacity requirements, the nature of available transmission assets and the timelines of multiple generation projects wishing to connect will often lead to the most economic investment on *Local Circuits* being one where the physical transmission capacity being put in place (by the TO) is greater than 100% of that required by the minimum deterministic standard.

⁹ <http://www.nationalgrid.com/NR/rdonlyres/0B7065FD-CA38-44A3-9162-8E2CBEB66A6E/54246/EntryWGRReportFinalJune2012.pdf>

- 4.281 There was further debate in the Workgroup as to whether, GSR-010 aside, the NETS SQSS minimum standards would necessarily apply in the case of a connection for an intermittent generator. Once beyond the definition of a *Generation Circuit*, but possibly still within the definition of a *Local Circuit*, the NETS SQSS allows the TOs to make judgement as to the likely output of a generator over the course of a year of operation when setting out minimum transmission capacity requirements.
- 4.282 Particularly for intermittent generators connected via relatively expensive transmission technology there is precedent for reduced minimum transmission network capacity requirements as a result of making an economic trade off between the value of lost energy versus the cost of additional transmission capacity (i.e. cost benefit analysis - CBA). This precedent is codified for offshore transmission connections. Proposed generation connections to the islands share some of the defining characteristics of offshore transmission for the purposes of planning transmission network capacity. Some members of the Workgroup noted that there were also many differences between island connections and offshore.
- 4.283 In these cases the Workgroup noted that the economic capacity of a Local Circuit connection would therefore be dependent on the outcome of the aforementioned cost benefit analysis, coupled with the specificity of capacity with which the relevant transmission assets are available (as set out in paragraph 4.278) and taking account of any uncertainty in the generation background.
- 4.284 Whilst the exact level of transmission capacity that may be built on a local circuit is somewhat uncertain, the Workgroup discussed the fact that there is not an exact link between transmission planning (NETS SQSS) and transmission charging (TNUoS) due to planning necessarily occurring on the basis of all background conditions and the TNUoS charging calculation being undertaken on the basis of the incremental impact on transmission investment costs (i.e. the charging calculation, both under the existing methodology and the Original proposal, does not explicitly take account of the physical transmission network capacity available on the network).
- 4.285 Some Workgroup members were not comfortable with this concept and further discussion ensued on the difference between transmission network planning (NETS SQSS) and transmission network charging (TNUoS).

Planning versus Charging of 'Local' Circuits

- 4.286 The Workgroup sought to gain insight into, and examples of, the main differences between the planning of transmission network capacity on radial circuits connecting both generation and demand and the TNUoS charging calculation associated with these transmission circuits.
- 4.287 The Workgroup noted that the planning of transmission network capacity is a relatively complicated process that must take a large number of factors into account, some of which are set out above. However, the intention was not an attempt to explain all the intricacies of transmission network planning, but rather to seek to highlight the main distinction between planning and charging for transmission.

Network Planning

- 4.288 When assessing the impact of additional generation connecting at a point on the transmission network the transmission network planner will model the anticipated generation capacity (MW) and its output (MWh) over time and investigate the transmission network power flows across the system that

result from the disposition of all the generation relative to the location of demand.

4.289 Where issues arise, both the transmission network reinforcement options and any system operational solutions available are considered to solve them in the most economic fashion. The Workgroup noted that the key characteristics of this process, relevant to the comparison, are, that transmission planning:

- 1) is done against forecasts of the total additional generation capacity that may connect or disconnect in a particular part of the transmission network which, due to limited User commitment (i.e. financial commitment) and a general inability to predict the future, also includes a level of uncertainty; and
- 2) must work within the limitations of the finite number of transmission network reinforcement solution options, each available in only a limited number of standard sizes (i.e. where transmission reinforcement occurs it is generally 'lumpy' in nature, such that capacity will seldom match requirements MW for MW).

4.290 This concept of capacity in the context of transmission network planning is illustrated in Figure 35, below, showing that actual investment in transmission capacity is put in place to accommodate generation capacity, but rarely matches requirements on a 1:1 basis due to a number of factors.




Figure 35 – Capacity in a transmission network investment context

Network Charging

4.291 TNUoS charges are based on the principle of Investment Cost Related Pricing (ICRP), which calculate the incremental cost of transmission investment. The Transport model, used to calculate the locational signal calculates the incremental costs of investment in the transmission system which would be required as a consequence of an increase in generation (or demand) at each connection point on the transmission network.

4.292 One measure of transmission investment costs is in terms of MWkm (i.e. unit capacity over a distance). Hence, marginal transmission network costs are estimated initially in terms of increases or decreases in units of kilometres (km) for a 1 MW injection on to the transmission system. The Workgroup noted that the key characteristics of this process, relevant to this comparison, are that the TNUoS charging calculation:

- 1) Uses the impact of the incremental 1 MW injection in conjunction with the cost and length of existing transmission routes to calculate the incremental cost. In doing so it assumes that the cost of future additional transmission network capacity will be the same as that currently on the transmission network; and
- 2) Assumes that additional transmission network capacity (MW) requirements for a generator of a given size can be added to exactly the capacity (MW) size required for that generator.

4.293 This concept of capacity in the context of TNUoS charging is illustrated in Figure 36, below, showing that charging for transmission network capacity assumes that the transmission network can be sized exactly to meet the requirements of generation. The incremental cost signal is based on the costs and lengths of existing transmission routes and technologies.




Figure 36 – Capacity in a TNUoS ICRP context

4.294 From the above, the Workgroup appreciated that the incremental nature of the TNUoS charging calculation meant that it does not explicitly take account of the physical transmission network capacity available on the network.

4.295 The Workgroup agreed that the incremental impact on transmission network investment costs from generators with different characteristics would not vary for local transmission circuits planned in accordance the deterministic criteria. (i.e. the relevant characteristic in this case would solely be the capacity of the generator in question).

4.296 However, there was a view from some Workgroup members that for connections of intermittent generation with relatively expensive transmission technology, as seen with offshore connections and described briefly above, the transmission planner may undertake a cost benefit analysis (CBA). In many cases this CBA could underpin transmission funding requests to Ofgem.

4.297 The Workgroup surmised that as part of this CBA, Transmission Licensees may need to develop annual generation profiles for different generation technologies types. In this instance some Workgroup members believed that any counter-correlation between generators using the same local transmission circuits could support the economic case for sharing of that transmission capacity. Others in the Workgroup believed that, for local circuits planned on the basis of capacity, this economic case would not be apparent.

- 4.298 An introduction to research commissioned by some Workgroup members, undertaken by Heriot-Watt University, was presented to the Workgroup in a meeting during November 2012. The analysis behind the summary provided to the Workgroup looked at individual and combined generation profiles in relation to power exports from the islands relative to varying amounts of transmission network capacity. The analysis was centred on the Orkney Islands which, at least initially, will be connected to the mainland via a local transmission circuit.
- 4.299 Orkney Islands wind, wave and tidal data was used together with response characteristics of typical generation plant. The method used statistical analysis to isolate and represent non-random and random variations in output over the year and build up probabilistic half hourly generation profiles for each generation technology type. This dataset then underpinned a number of generation scenarios which give a picture of how generation technology type combinations might collectively export power from the islands using the island transmission connection.
- 4.300 During the Workgroup meeting in November, where this analysis was presented, an example of 300MW wind generation, 600MW wave generation and 500MW tidal generation (i.e. a total installed generation capacity of 1,400MW) was used, which was called “Orkney Gone Green 2022”.
- 4.301 The Workgroup was informed that one thousand simulations were run of each half hour comprising a year of operation (i.e. 1,000 x 17,520) on the Orkney Gone Green 2022 background. Whilst the group did not have sufficient time to fully understand the modelling methodology utilised in this research, it was agreed that, provided the modelling methodology was sound, the number of simulations undertaken was sufficiently statistically robust to cover the vast majority of potential outcomes.
- 4.302 The Workgroup was shown a plot of peak weekly outputs (i.e. 52 data points, each representing the peak output of generation in the 1,000 simulations undertaken on the 336 half hours making up one week). The plot for the combined background of all generation (in the Orkney Gone Green 2022 background) is shown in Figure 37, below.




Figure 37 – Weekly peak output for all 1,400MW of generation capacity

- 4.303 The Workgroup spent some time debating and attempting to understand what the plot was actually demonstrating. More of the same plots were also shown for each generation technology type in isolation, which showed that for the wind and tidal technologies modelled on Orkney, peak weekly output would reach installed capacity in a high number of weeks within the 95th percentile of simulations. These are illustrated in Figure 38, below.




Figure 38 – Weekly peak output for wind and tidal in isolation

4.304 On the other hand, wave generation was shown to exhibit the lowest number of weekly peak outputs at installed capacity within the 95th percentile as shown in Figure 39, below.




Figure 39 – Weekly peak output of wave generation in isolation

4.305 Some Workgroup members believed that, providing the modelling methodology was sound, the data showed that when wind, wave and tidal generation combined in the aforementioned proportions were situated on Orkney that the chance of the power exported, via the local transmission circuit, from the islands being equal to the installed capacity of all the generation was minimal (i.e. it appeared that a maximum output of 1,200MW occurred within the 95th percentile of the 1000 x 17520 simulations).

4.306 Others in the Workgroup were concerned that, whilst this may be the case for the 95th percentile, that there may yet be other simulations outside this range where weekly peak combined generation output did reach installed generation capacity and that the cost of these periods could be high given the subsidies in place for these generation technology types. Yet others in the group were of the view that if the transmission network was planned on the basis of installed generation capacity, then the TNUoS charging arrangements should reflect this.

4.307 The Workgroup was also introduced to a concept set out in the model as the “sharing factor” expressed as:

$$\text{Sharing Factor (\%)} = 100 \times \left(1 - \frac{\sum_{\text{devices}} \text{outputs}}{\sum_{\text{devices}} \text{rated capacity}} \right)$$

4.308 This “sharing factor”, expressed as a percentage, was meant to show the percentage of spare transmission network capacity at any one time, if the network was sized to rated generation capacity. The Workgroup was shown a plot of this “sharing factor” similar to those above across 52 weeks, which

is replicated in Figure 40, below. Some Workgroup members believed that this plot demonstrated that “sharing” by generation of between 10% and 40% of transmission capacity occurred across a year.




Figure 40 – Deemed "Sharing" factors of peak outputs

4.309 Subsequently the Workgroup was introduced to a “risk factor” expressed as:

$$\text{Risk (\%)} = 100 \times \frac{\text{Count of simulations where } \sum_{\text{devices}} \text{output} > \text{Grid capacity}}{\text{Count of all simulations}}$$

4.310 This “risk factor” quantified the percentage of the total number of simulations (i.e. 1,000 x 17,520) that the combined output of each of the generation technology types would exceed the transmission network (i.e. “Grid”) capacity if that capacity were sized to match the total capacity of generation.

4.311 Figure 41, below, shows this “risk” factor plotted against transmission network capacity (if transmission network capacity = installed generation capacity). The Workgroup noted that, for example, the combined output of the generation only exceeded 850MW for 5% of the total number of simulations run.




Figure 41 – "Risk" against transmission network capacity

4.312 Some Workgroup members believed that the above plot showed that generators could simply book a Transmission Entry Capacity (TEC) that was lower than the generation capacity, such that the Transmission Licensee could build less transmission network capacity and that this would be reflected in the TNUoS tariff they were charged. Others were of the view that, as individual generation projects did not have the sight of other generation projects, this approach of booking less TEC for a single generation project was not viable. These members also believed that taking this view (about TEC) precludes reflecting any benefits of counter-correlation of output between different generation technologies; such as wind, wave and tidal in the Orkney Gone Green 2022 scenario.

4.313 It was also pointed out that for onshore and island transmission connections, the relevant TO will often be planning the transmission network for a combination of demand and multiple generation Users and would usually be the party making the economic investment case.

4.314 Finally, against the Orkney Gone Green 2022 scenario, the Workgroup was also shown a graph showing the potential loss of Renewable Obligation Certificate (ROC) revenue against transmission network ("Grid") capacity and the "sharing factor".




Figure 42 – Loss of ROC revenue vs. transmission network capacity and "sharing factor"

4.315 The plot in Figure 42, above, shows that for a transmission network capacity of approximately 1,150MW, the loss of ROC revenue would be negligible for both the median and 95th percentile of the simulations undertaken. It also shows that the loss of ROC revenue increases rapidly for lower network capacity in the 95th percentile, but only a very small amount in the median. The Workgroup noted that the analysis estimated that a transmission network capacity of half the installed generation capacity would lead to £90m per annum in lost ROC revenue in the 95th percentile.

4.316 Some Workgroup members believed that the analysis demonstrated that:

- A. There is likely to be an economic case for building local transmission circuits that are sized under the combined rated capacity of the various generator technology types using (or expected to use) the circuits; and
- B. That this case holds for intermittent, renewable generators sharing access to a local transmission circuit;
- C. That there may be a case for different generation technology types sharing between low carbon, intermittent, generation anywhere on the network.

4.317 The Workgroup noted that any potential local sharing alternative would need to apply to all local transmission circuits, not only those connecting Scottish islands.

4.318 There was general agreement that where the local transmission network is planned on the basis of there being network sharing by generators, that this should be reflected in TNUoS tariffs. There was a range of views within the group over whether local transmission circuits that were planned in accordance with the deterministic standard to the full capacity of the generation (or their TEC) should have a sharing element in the TNUoS tariff.

4.319 The possible methodology for incorporating this sharing due to explicit counter-correlation was discussed by the Workgroup. With reference back to the issues of diversity, set out above, it was clear to some Workgroup members that this may require a slightly different approach to that taken on the wider transmission network where counter-correlation may not be the main driver behind the differential impact on incremental costs by generators of different plant types. Some in the Workgroup considered that it would be possible to incorporate the results of the analysis presented for Orkney to the diversity options and alternatives set out above.

4.320 The Workgroup debated a number of potential alternatives for reflecting generation sharing on local transmission circuits, where it was demonstrated that sharing would occur due to explicit counter correlation of the generators in question. Four possible options were identified for reflecting sharing into the local circuit TNUoS tariff:

- i) Add a sharing component to the local circuit TNUoS charge by applying the ALF to any calculated tariff;
- ii) Add a sharing component to the local circuit TNUoS tariff that is calculated on a specific amount of calculated sharing;
- iii) Establish a new designation of “shared local” and apply a sharing factor to the local circuit TNUoS tariff; and
- iv) Establish a new designation of “island local” and apply a sharing factor to the local circuit TNUoS tariff.

i) Add a sharing component to the local TNUoS charge by applying the ALF to any calculated tariff

4.321 This approach would use the five year average based ALF, as set out in the Original proposal, as the sharing factor for all local transmission circuits. The benefit of this option is that it is simple in application due to being the same as the wider TNUoS tariff sharing factor. However, the Workgroup felt that it would not be cost reflective as in many cases there is no sharing of local transmission circuits. On that basis the majority of the Workgroup felt it tipped the balance between simplicity and cost reflectivity, and was not supported.

ii) Add a sharing component that is calculated on a specific amount of calculated sharing

4.322 The Workgroup believed that this would allow for a sharing element to be factored into the local TNUoS tariff on a more specific basis. The difficulty with this potential alternative would be in deciding what proportion of sharing was present. Two sub-options were developed, both of which were considered as potential alternatives.

a) Sharing factors derived from the assumptions made by the TOs when planning the transmission network

- 4.323 This potential alternative would draw on the cost benefit analysis undertaken by Transmission Licensees and would require communication between the Transmission Owners (TOs) and System Operator (SO) on the sharing factors used. The Workgroup agreed that there should be some oversight to check economic efficiency of the assumptions, although most thought this implicit in the transmission network planning process which requires Ofgem approval. Another route by which this could be achieved is through checks and balances of the SO through the STC.
- 4.324 Linking any local transmission circuit sharing factors to TOs planning assumptions would provide stability – once agreed and approved – and could be considered consistent with the evidence base used for the Original. It may also be considered consistent with the concept of implicit sharing of the Original, as opposed to explicit sharing and a reliance on third parties to set TNUoS tariffs.
- 4.325 Some in the Workgroup thought that the signalling of local circuit sharing could unlock some areas transmission network development projects currently stalled by the need, for economic efficiency, to corral many dispersed and diverse generators, but with generators unwilling to be the first (high-risk) mover.
- 4.326 Before the factors are agreed by the TO / SO / the Authority they might be difficult for Users to predict unless there was some published guidance on their use in cost benefit. The Workgroup felt in any event that there would need to be transparency in the setting and agreeing of the factors.

b) Sharing factors derived from the actual mix of generation connected via a local transmission circuit; updated annually

- 4.327 This approach would update the local transmission circuit sharing factors using specific data on generators joining each specific local transmission network. Suggestions included:
- a simple ratio of capacity (MW);
 - a simple ratio of generator annual load factors (%); and
 - modelling counter-correlation factors.
- 4.328 Some in the Workgroup believed that a simple ratio of (MW) capacity would be inaccurate where there were diverse generation technology types. These members also believed that moving down the list increases accuracy, and the majority agreed that the last is more complex than the first two. Annual updates would give only little stability as the local circuit TNUoS tariffs would be updated each year. It was noted that TNUoS is in any event annually recalculated, although some in the Workgroup were concerned that tariff swings due to sharing may be quite pronounced. Other Workgroup members were of the view that the analysis on volatility, in Annex 8 – Comparison of Tariff Volat, seemed to indicate that volatility could be reduced in terms of the Original proposal.
- 4.329 The Workgroup debated whether a simple ratio of capacity provided equivalence with the existing offshore TNUoS charging methodology where generator capacity exceeds the offshore transmission network export capacity. Some believed that this could be achieved by allocating annual revenue recovery across total generator MWs rather than circuit capacity MWs (or a simple ratio of load factors). This may be appropriate when using specific costs to derive an expansion factor. Other Workgroup members

believed that the use of revenue to calculate a TNUoS tariff for a transmission circuit owned by an incumbent onshore Transmission Owner may not be possible, or could be inconsistent with the rest of the charging methodology for non-OFTO assets.

iii) Establish a new designation of “shared local” and apply sharing to the calculated TNUoS tariff

4.330 This method would introduce some kind of designation of certain local transmission circuits in order that they can be charged, for the purposes of TNUoS, as shared. This might be on the basis of a certain level of diversity using the transmission circuit(s) or some other defining feature. The Workgroup could not define what this might be, so this option was not developed further.

iv) Establish a new designation of “island local” and apply sharing to the calculated TNUoS tariff

4.331 This potential alternative would allow certain island transmission circuits to be designated as “island local” and then apply a sharing factor (ALF or something else as agreed) to any calculated TNUoS tariff. However, there would need to be a demonstration that local transmission networks on an island were being shared by generators, and a CUSC definition of “islands” would be needed which set this out clearly and takes account not just of the Scottish islands (generally the main focus of the debate around island TNUoS charges to date) but all islands in GB (to avoid any unintended consequences) in a non-discriminatory manner.

4.332 The Workgroup felt that this was essentially the same as potential alternative (iii), above, but with islands as the designated feature. There was majority agreement in the Workgroup that islands per se could not be used as a defining feature unless there was something unique about island transmission circuits.

Sharing with Demand

4.333 All of the debate described above under local sharing, above is concerned with generation sharing transmission network capacity with other generators. Some members of the Workgroup believed that demand also ‘shares’ local transmission capacity in so far as its presence can reduce the need for export capacity. There was some in-depth discussion within the Workgroup around whether this is, or is not, already accounted for in the TNUoS charging methodology.

4.334 Others Some in the Workgroup noted that, as the TNUoS charging signal is calculated in an equal and opposite manner between generation and demand, the netting effect of demand on transmission network power flows (and hence the need for export capacity) is already taken into account. These members believed that the comparison of transmission network capacity in a planning context (Figure 35, above) and transmission network capacity in a TNUoS ICRP context (Figure 36) made it absolutely clear that generation did not share transmission network capacity with demand.

4.335 Generation TNUoS is an incremental signal which does not see spare or under-capacity, so is neutral to under- or over-sizing of, cables transmission capacity against booked generation capacity (as set out above).

- 4.336 Nevertheless some Workgroup members noted that Demand TNUoS in its raw form is equal and opposite to the generation signal at a node. However, a proportion of Demand TNUoS is charged against usage rather than booked demand capacity and embedded generators are credited with some of the import avoided by their presence. There was concern in the group that this should not be double-signalled through Generation TNUoS
- 4.337 The Workgroup debated further the nature of the equal and opposite nodal TNUoS tariffs for demand and generation, and whether these gave comparable locational signals. In the context of the islands, generation TNUoS has a highly specific nodal local charge, whereas nodal demand TNUoS calculated in the TNUoS model is averaged across the whole of the north of Scotland demand TNUoS charging zone, including the islands (as it is in all 14 GB demand TNUoS charging zones). So whilst some believed that the generation TNUoS is an extremely sharp signal on the islands, they also believed that demand TNUoS is very diluted; although it was noted that this effect was replicated (to a lesser extent) across GB, where the generation and demand TNUoS charging zones are different.
- 4.338 Disaggregating Demand TNUoS has been suggested in the past, which should benefit island-based consumers. One member pointed out that the Common Tariff Obligation (CTO) prohibits suppliers giving consumers in the north of Scotland different terms on the basis of location. This is designed to protect them from high distribution costs in the Highlands and islands of northern Scotland. SHEPD's distribution business is also subsidised by around £53m a year, through TNUoS charges on suppliers, to keep average costs down.
- 4.339 Nevertheless, some in the Workgroup believed that disaggregating demand TNUoS could be possible.
- 4.340 However, the Workgroup noted a number of issues associated with this possible approach set out below.
- 4.341 Firstly, the removal of the CTO could only be undertaken by the UK Government, rather than via a CUSC Modification.
- 4.342 Secondly, if it were removed it would expose those parts of the Highlands and islands in the north of Scotland which did not have generation in their locality to higher transmission and distribution charges.
- 4.343 Thirdly, it was noted by some that CMP213 only relates to transmission charges which, according to the Authority¹⁰, account for 5% of a typical household bill whilst distribution charges account for 18%. Thus even for those islands which did have generation in their locality, if the transmission element of the island consumer use of system (T & D) charges (23% of the total bill) were to be negative it was unlikely to counteract the much higher distribution charge that would arise if the CTO were to end (and consumer on that island were then exposed to the actual use of system (T & D) charges for the network associated with the island).
- 4.344 Fourthly, in the future, it would expose those parts of the Highlands and islands in the north of Scotland which did have generation in their locality to higher transmission and distribution charges if (when?) that generation left the system.
- 4.345 Fifthly, much of the generation on the islands is renewable and there is already a well established mechanism for local communities to share the

¹⁰ <http://www.ofgem.gov.uk/Media/FactSheets/Documents1/household-bills.pdf>

benefits of having that generation in their locality via the 'Community Benefit' arrangements. Some Workgroup members wondered if Demand Disaggregation were to be implemented would this result in any net benefit to local communities if it resulted in a corresponding reduction in 'Community Benefit'.

4.346Sixthly, any benefits that accrue from the sharing of the local transmission assets would, currently, be shared (via the CTO obligations) with all demand consumers in the north of Scotland (including those on the islands) who have, since privatisation, been paying a higher use of system charge to help pay for the higher costs of operating and maintaining the transmission and distribution networks in the north of Scotland. This, in the view of some Workgroup members, was equitable as it would mean that any benefits for demand of local sharing would be shared with all those consumers (in the north of Scotland demand TNUoS zone) who had paid the higher charge in the past. Otherwise there was a danger that where transmission network costs (to certain localities) are high (or a 'dis-benefit') they are 'socialised' but where there are 'benefits' (in terms of low, or negative, transmission network costs) these are 'localised'.

4.347As a result of the above, the Workgroup did not develop any potential alternatives for sharing with demand.

(ii) Sharing potential alternative 2 – Alternative Allocation of MWkm

4.348In the Original proposal circuit flows in the Transport model are compared between the two background load flows, and the background settings causing the higher transmission circuit flow is considered as the triggering criterion. The logic behind this approach is that, where transmission investment is made against these deterministic criteria, it would be done to facilitate the most onerous condition. This is considered to remain robust when considering the impact of an incremental 1 MW on the transmission network, which assumes that the network can be optimally sized (i.e. it does not take into account the capacity of the transmission network).

4.349The Workgroup considered a potential alternative approach where two separate DC load flow backgrounds are set as per the Original proposal, using background scaling factors consistent with the NETS SQSS.

4.350In the potential alternative approach, transmission circuit flows are still compared between the same two load flows, but rather than defining an entire transmission circuit as either Peak Security or Year Round, the relative proportions of flows on that circuit are compared and apportioned between the two criteria. The reasoning behind this approach sets aside the notion of a 'triggering criterion' and considers that investments in transmission network capacity would be utilised under both the Peak Security and Year Round conditions and, as such, should be considered under both criteria.

4.351The process is best illustrated through use of an example. Consider the circuit shown in Figure 43, below.



Figure 43 – Ratio of power flows for PS and YR

4.352In this example, a load flow using the Transport model has resulted in a Peak Security flow of 600MW on transmission circuit A-B and a Year Round flow of 400MW. Under this potential alternative approach, 60% of the MWkm 'cost' of transmission circuit A-B would be attributed to the Peak Security

criterion, whilst 40% of the MWkm 'cost' of transmission circuit A-B would be attributed to the Year Round criterion. The Original proposal, as it currently stands, would apportion 100% of the MWkm 'cost' to the Peak Security background (and 0% to Year Round). This potential alternative approach would not alter the incremental MW assessment.

4.353 The impact of this potential alternative approach to apportioning MWkm has been assessed using the 2011/12 Transport model. Figure 44, below, shows the unadjusted zonal MWkm for both the Original proposal ("Strawman") and this potential alternative ("Alternative") approach for both backgrounds. It can be seen that this potential alternative approach would reduce the zonal MWkm attributed to the Year Round element and increase the Peak Security MWkm relative to the Original Proposal. The overall zonal MWkm would not alter significantly.




Figure 44 – Comparison of relative MWkm for Original ("Strawman") and potential alternative ("Alternative")

4.354 Whilst there was no clear consensus amongst the Workgroup members as to which approach was best from a theoretical perspective, there were no strong views that the approach set out in the Original proposal should not remain. Therefore no changes were being considered in this area.

(iii) Sharing potential alternative 3 – Single background – Year Round only

4.355 The Original proposal seeks to replace the existing peak background in the Transport model with two separate background conditions, representing Peak Security and Year Round conditions respectively. Whilst the existing loadflow in the Transport model sets up the peak demand background by scaling down the contracted (MW) TEC of all generators in GB equally to meet total GB demand, the Original proposal would setup two peak demand conditions and scale generation differently under each to reflect the values used in the NETS SQSS. Some of these values would be fixed (charging) year on (charging) year and some would vary depending on the demand level in the charging year under consideration.

4.356 Some members of the Workgroup raised the possibility of not utilising a dual (Peak Security and Year Round) background approach and, instead, calculating TNUoS tariffs on the Year Round background only, thus leading to only a single element of the wider locational TNUoS tariff on this basis that this would be less complex and, in their view, potentially more robust.

- 4.357 It was noted that this approach would be inconsistent with the approach taken to planning transmission network capacity in the NETS SQSS and also inconsistent with the terms of the SCR Direction which set out that the CMP213 modification proposal should set (TNUoS) tariffs using a dual background approach:].
- 4.358 Nevertheless, the Workgroup believed that the use of the Year Round background only could form part of a potential alternative to address the issues of generation plant diversity (i.e. Method 3), highlighted above. Therefore discussion on this potential alternative was taken forward in that area.

(iv) Sharing potential alternative 4 – Full market model

- 4.359 The Original proposal seeks to make incremental improvements to the existing Investment Cost Related Pricing (ICRP) TNUoS charging methodology. As such, it proposes to use the existing Transport and Tariff model, altered to reflect the dual (Peak Security and Year Round) background approach used in transmission planning and incorporate a sharing factor to account for the differential incremental cost impact of generators with different characteristics on the transmission network.
- 4.360 As part of the detailed analysis undertaken by the Workgroup, two separate market despatch models, such as those used to undertake CBA based transmission network planning, were used to explore options for a simple proxy that could be used to reflect the numerous characteristics of a generator that can have an impact on incremental transmission network costs (e.g. the Annual Load Factor in the Original).
- 4.361 One member of the Workgroup considered that a potential alternative to this incremental approach of improving ICRP would be the use of a full market model to set TNUoS tariffs.
- 4.362 The Workgroup debated this possibility and considered that there could likely be benefits associated with enhanced cost reflectivity over and above both the Status Quo and the Original proposal.
- 4.363 However, the drawbacks of such an approach were considered to be significant and included the need to obtain all the relevant characteristics such as the fuel price, efficiency, plant availability, bid price, offer price, etc., for each generator as well as updating and running a complex model each charging year. In addition the Workgroup noted that transparency and predictability of TNUoS tariffs under such an approach would likely deteriorate appreciably.
- 4.364 On the basis of the above the Workgroup agreed not to proceed with the development of this option.

(v) Sharing potential alternative 5 – Separate charging background scaling factors

- 4.365 The Original proposal seeks to replace the existing peak background in the Transport model with two separate background conditions, representing Peak Security and Year Round conditions respectively. Whilst the existing DCLF in the Transport model sets up the peak demand background by scaling down the contracted (MW) TEC of all GB generators equally to meet total GB demand, the Original proposal would set up two peak demand conditions (Peak Security and Year Round) and scale generation differently under each to reflect the values used in the NETS SQSS. Some of these

values would be fixed (charging) year on (charging) year and some would vary depending on the demand level in the charging year under consideration.

- 4.366 One member of the Workgroup raised the possibility of utilising background scaling factors in the Transport model other than those introduced into the NETS SQSS by GSR-009.
- 4.367 The Workgroup considered how such an approach might work. In doing so it became clear that an entirely new set of generation scaling factors, which were still relative to the manner in which additional capacity on the transmission network is planned, would need to be developed. The Workgroup could not think of a way of doing this so that it would not be considered arbitrary in nature and, therefore, the Workgroup considered that it would be difficult to arrive at a robust methodology using this approach.
- 4.368 In addition it was noted that this approach would be inconsistent with the approach taken to transmission planning network capacity in the NETS SQSS and also inconsistent with the terms of the SCR Direction.
- 4.369 The Workgroup considered how best to codify the background generation scaling factors that would be used and believed there to be two options:
- i) simply refer to the way TO's plan transmission network capacity without an explicit reference to the NETS SQSS; and
 - ii) hard link the generation scaling factors used in the TNUoS charging methodology to those used in the NETS SQSS.
- 4.370 The Workgroup preferred the second approach, but noted that it would require a future modification to the CUSC should TO's change the way in which they planned the transmission network. The fact that TO's are obliged through their Transmission Licence to plan the transmission network in accordance with the NETS SQSS was deemed sufficient in this respect.

(vi) Sharing potential alternative 6 – Anticipatory application of sharing

- 4.371 The Original proposal applies the principles of sharing set out within it to all parts of the transmission network considered to be part of the Main Interconnected Transmission System (MITS; i.e. 'wider') for TNUoS charging purposes. Implicitly this would also include any island connections that are classed as 'wider'.
- 4.372 However, the Workgroup noted that some islands may initially be classed as local under the existing definition, but subsequently become wider due to a change in configuration (such that they become part of the MITS).
- 4.373 In this context, the Workgroup investigated the concept of applying the sharing approach outlined above to local transmission circuits on an anticipatory basis, especially for situations (e.g. islands) where generators find it hard to proceed individually, but may proceed collectively.
- 4.374 Some Workgroup members believed that on the basis that TNUoS is, where possible and desirable, future-looking, it should be proposed as a potential alternative to signal, through existing TNUoS charges, the benefits of future sharing of local transmission circuit(s) in order that generators make the right locational choices.

4.375 Two options for this forward-signalling were debated:

- i) Charging Users on the assumption there is sharing; and
- ii) Charging Users sharing TNUoS tariffs only if sharing materialises, but publishing forward looking sharing TNUoS tariffs on a range of realistic assumptions; e.g. sharing and non-sharing TNUoS tariffs published based on connection offers or expressions of interest from generation developers, or on TO assumptions underpinning building of transmission capacity.

(i) Charging Users on the assumption there is sharing

4.376 Where there is not actual sharing, this is signalling the spare transmission network capacity available to generators for sharing. The Workgroup debated the circumstances under which this might be reasonable. There was general consensus that it would be difficult and probably not appropriate to do so for speculative generation sharing, not least because there would be little if any information on which to base the generation sharing factors.

4.377 Some Workgroup members believed that it might be appropriate if transmission assets had been triggered and built on the assumption of generators sharing those transmission assets. The Workgroup was not clear on whether generation sharing would be taken into account when building a local circuit part of the transmission network – some thought that the TOs would include sharing in their Cost Benefit Analysis (CBA) and proceed if it made economic sense, others thought that there would be a straight match of build to booked generator TEC or CEC as set out in paragraphs 4.271 through to 4.284

4.378 In any event, whilst there was general agreement in the Workgroup that sharing should be reflected when and where there is actual sharing, by generators, of transmission assets, there were differing opinions on whether existing generators should pay for anticipatory transmission investment which included sharing assumptions.

4.379 Some Workgroup members believed that such a potential alternative would also keep TNUoS tariffs stable over time, and remove dependency on other generation projects which are unlikely to connect to the transmission network all at the same time. However, as a sharing TNUoS tariff is likely to be beneficial (lower) than one without sharing, a number of members noted that the temptation may arise for a generator to ‘engineer’ a sharing TNUoS tariff. This might be achieved by that generator setting up a number of ‘shell projects’ with some minimal underwriting, triggering transmission investments based on sharing (of those transmission assets) and then withdrawing those ‘shell projects’ prior to completing those generation projects. The proponents of the potential alternative countered that ‘gaming’ could simply be avoided by applying risk-reducing milestones such as those applying to pre-commissioning projects under post CMP192 User Commitment as a prerequisite to generation projects considered in the sharing of the assets. In any event the likelihood of sharing any risk of generators not coming forward would need to be taken into account when transmission investments go through the regulatory approval process.

4.380 Others in the Workgroup thought that TNUoS charges should reflect the transmission network capacity being used and were concerned about charging prior to diversity in generation on local transmission assets actually occurring. For instance, a generator of 500MW solely using a 750MW local transmission network would be using two thirds of the local transmission capacity and should be charged accordingly. If another counter correlated 500MW generator could be subsequently accommodated on the same local

transmission network (without additional transmission investment), then there may be a case to charge (via the TNUoS tariff) a lower proportion to both generators so that the 1,000MW combined generation capacity shares the cost of the 750MW of local transmission assets.

4.381 These Workgroup members believed that, it is only when the second generator turns up that it could be said that the transmission network is actually being shared in this manner. If the second generator failed to turn up then 500MW of transmission capacity would still be needed by the first generator and it would be wrong to charge it TNUoS on the shared basis.

(ii) Publishing tariffs on the basis of sharing and not sharing

4.382 If sharing was to be reflected through tariffs only as and when the generators who shared were actually connected to the transmission network, some workgroup members felt that it would be important to signal the benefits of sharing through forecasting indicative tariffs with and without sharing.

(vii) Sharing potential alternative 7 – Explicit Sharing

4.383 The industry began a process of reviewing the commercial framework to reflect changes in the way the transmission network is used by generators through the Transmission Access Review (TAR) process from 2007 to 2010.

4.384 During this process, the possibility of explicitly recognising the differential impact on transmission network costs by generators with different characteristics into transmission charging (TNUoS) and transmission access arrangements was considered in some detail through various modification proposals and alternatives.

4.385 Ultimately, this process culminated in the Secretary of State rejecting this explicit recognition in favour of a form of Connect and Manage. In recognition of this the Original proposal does not seek to alter the form of transmission access rights afforded to generators (in the form of Transmission Entry Capacity - TEC) through the UK Government's decision. Rather, it seeks to improve the cost reflectivity of TNUoS tariffs for generators by implicitly recognising that this sharing, of transmission network assets, takes place and is taken into account in an equally implicit manner in the transmission network investment planning process.

4.386 The Workgroup briefly considered the possibility of taking account of the differential impact on incremental transmission network costs from generators with differing characteristics explicitly through a change in transmission access rights.

4.387 It was noted by the Workgroup that the Authority had explicitly stated in their Project TransmiT SCR Conclusions document¹¹ that, “the [Project] TransmiT SCR CUSC amendment process will not seek to change users' transmission access rights.”

4.388 The Workgroup also noted that whilst the ability for co-located generation plant to come to a bilateral agreement in order to share the same TEC (MW) already existed within the current CUSC framework¹² in practical terms it was not usable in near 'real time' situations. However, the Proposer also noted that this existing TEC sharing arrangement did not address the implicit assumptions made about the incremental impact on the need for additional

¹¹ Page 24, Paragraph 3.48;

<http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/TransmiT%20SCR%20conclusion%20document.pdf>

¹² Known as 'Temporary TEC Exchange' see:

<http://www.nationalgrid.com/uk/Electricity/Codes/systemcode/entexchange/>

transmission network capacity for generators on the wider transmission network.

- 4.389 One member brought forward a potential alternative for how Users could share the capacity of the wider transmission network in excess of their individual Transmission Entry Capacity - TEC (MW) holding subject to voluntary curtailment arrangements administered by the System Operator.
- 4.390 This potential alternative would allow a User to dispatch their generation plant in excess of their contracted TEC (MW), subject to (i) there being sufficient capacity on the local transmission network; and subject to (ii) that generator being fully exposed to the risk of curtailment by the System Operator. This would be in the form of an availability restriction that seeks to prevent any incremental costs of re-dispatch that may occur as a result of accommodating the additional delivered electricity on the GB electricity transmission system.
- 4.391 The member considered that the TNUoS charging arrangements for this type of transmission use would require development so that the revenue requirements of the TOs are recovered in the current ex-ante manner, but that this is expected to be overly complex.
- 4.392 Whilst the Workgroup saw merit in the development of an approach for explicit sharing of transmission access rights, it was not believed that this should be developed in the context of this CMP213 Modification Proposal.

(viii) Sharing potential alternative 8 – Including Circuit loading

- 4.393 The Original proposal seeks to make incremental improvements to the existing Investment Cost Related Pricing (ICRP) TNUoS charging methodology. As such, it proposes to use the existing Transport and Tariff model, altered to reflect the dual (Peak Security and Year Round) background approach used in planning the transmission network and incorporate a sharing factor to account for the differential incremental cost impact of generators with different characteristics on that network.
- 4.394 As set out in the 'Sharing Applies to Local' section above, the Workgroup discussed the fact that the incremental nature of the TNUoS charging calculation meant that it does not explicitly take account of the physical transmission network capacity available on the network (see Figure 36 – Capacity in a TNUoS ICRP context).
- 4.395 One Workgroup member suggested that a potential alternative approach could be to take into account the capacity of transmission circuits and the level of power flows through these circuits relative to that capacity in the Transport and Tariff model when setting TNUoS tariffs.
- 4.396 The Workgroup discussed how this might be accomplished and considered that this approach would be similar to the Long Run Incremental Cost (LRIC) and Forward Cost Pricing (FCP) methodologies upon which the use of system charging methodology for higher voltage network users (the EDCM) of Distribution networks is based.
- 4.397 However, the Workgroup also considered whether such an approach would address the defect highlighted by the Original proposal and there was general agreement amongst the Workgroup that it did not.
- 4.398 Given that this approach would be a significant change from the current TNUoS charging methodology used for Investment Cost Related Pricing in TNUoS, that a whole host of issues associated with the use of such a

methodology for transmission network charging would need to be discussed and resolved and that such an approach does not address the CMP213 defect, the Workgroup decided not to proceed with the development of this potential alternative.

(ix) Sharing potential alternative 9 – Application of Load Factor to the Residual

- 4.399 The residual component of the TNUoS tariff aims to ensure that the System Operator is able to fully recover the total allowed revenue (set under the Transmission Price Controls) for all transmission owners (TOs).
- 4.400 As such, for the 27% of total revenue to be collected from generators, the residual is currently charged on capacity, on a £/kW basis shared equally across all generators in GB irrespective of their technology type and location.
- 4.401 The Original proposal would calculate the wider locational element of generation TNUoS tariffs in a different manner by introducing both a Peak Security and a Year Round tariff component, as well as multiplying the Year Round element by a sharing factor to take account of the differential impact on incremental transmission network costs from generators of differing characteristics. The Original proposal does not propose to alter the residual element of the generation TNUoS tariff on the basis that its sole purpose is to recover the total allowed revenue.
- 4.402 The Workgroup discussed a potential alternative method to calculate the residual by basing it on energy (MWh) generated rather than generation capacity (MW). This could be done by two methods:
- (a) Using a generator's annual load factor (ALF) as part of the residual calculation to convert a £/kW figure into a £/kWh figure; or
 - (b) Simply using total demand (minus exports) to obtain a p/kWh figure for total energy generated (which ignores the effects of losses).
- 4.403 Option (a) would allow for the final value to simply be added to the locational element of the wider TNUoS tariff. Option (b) would result in TNUoS tariffs being charged in two parts: one in £/kW (locational) and one in p/kWh (residual).
- 4.404 The Workgroup discussed the fact that using either method will result in generators with a lower annual load factor paying a lesser share of the residual, when compared to their equivalent under Status Quo and the Original proposal, as these generators will generate less over the charging year. Conversely, a generator with a higher lower annual load factor will pay a greater share of the residual.
- 4.405 Some Workgroup members stated that such an approach could be argued to be more cost reflective than the Original proposal, thus better meeting the Applicable CUSC Objective on cost reflectivity. Others in the Workgroup noted that the costs recovered through the residual do not represent specific transmission assets and could therefore be argued not to reflect transmission network costs.
- 4.406 Consideration was also given to the effect that generators with 0% load factor (i.e. those not generating) in a given charging year, would have on the overall revenue recovery using this approach. The Workgroup noted that in this situation, generators with a positive load factor would see an increase in their TNUoS tariffs as the value of their residual share would increase, potentially making the overall TNUoS tariffs (charging) year on (charging) year less predictable and more volatile.

4.407 In order to address this situation the Workgroup considered that there may be merit in splitting the residual into two parts, with 50% being energy (MWh) related and 50% being capacity (MW) related. Some believed that this may produce a more cost reflective outcome. Those who did not believe that the residual was reflective of transmission network costs did not agree.

4.408 The Workgroup also discussed and noted the illustrative impact on TNUoS tariffs, calculated using 2011/12 data, for different generation types and shared with the group.

4.409 The Workgroup noted that there would be an impact on generators in negative TNUoS charging zones, particularly those with higher load factors, but that this did not affect the locational signal. It was observed that the generation residual value, using option (a) from the above, would see an increase of around 131% from 3.284 £/kW to 7.589 £/kW, based on the load factor assumptions utilised in the analysis. The residual value charged on energy generated was also calculated as 0.087p/kWh (it was noted that this value was calculated including energy exported).

4.410 The Workgroup also debated the pros and cons of such an approach. This is summarised in Table 16, below.

Pros	Cons
<ul style="list-style-type: none"> • Investment in the transmission network is dependent on the size of connections, larger connections are provided with a greater level of transmission assets. The NETS SQSS proposal show this with multiple busbar and two or three transmission connection for the largest power stations. Smaller power stations receive a much lower standard of transmission connection. In general larger power stations can have higher annual load factors thus charging the residual on an annual load factor basis would bring an element of cost reflectivity with this aspect of transmission design. • Charging the residual on an energy (MWh) capacity basis will have a positive effect on market generation competition as, residual charged on a delivered energy basis would have the effect of reducing the marginal cost of power as low load factor plant will have a low marginal cost when it is running. This will bring benefits to all customers. • Some elements of the cost of transmission are load related based on ;e.g. some maintenance cost, provision of reactive equipment etc.; so charging an 	<ul style="list-style-type: none"> • The TNUoS charging signal is provided through the locational wider tariff component. The residual is there to recover the allowed TO revenue. Long term cost drivers on the transmission system are Users' capacity requirements. Through CMP213 adjustments are made to locational TNUoS charges to take into account sharing of transmission capacity leaving a £/kW locational charge for each TNUoS zone. • Economically it is important that any residual allocation does not distort the relative cost message provided by the wider TNUoS tariff. The residual is made up of transmission network costs unrelated to locational transmission costs (otherwise they should be in the locational charge). • Applying the residual on basis of energy (MWh), rather than capacity (MW), introduces a new cost driver and will distort the relative level of Users' TNUoS charges. This may lead to perverse and uneconomic outcomes.

element of the residual on annual load factor would produce a more cost reflective outcome.	
<ul style="list-style-type: none"> • It is simple to implement and would be charged on estimated metered output with an end of charging year reconciliation in a similar way to BSUoS. Such a methodology is already in place for Demand TNUoS charges. 	<ul style="list-style-type: none"> • It is more complex to administer (multi tariff). It may need more information; e.g. a forecast of energy will be needed to create the p/kWh charge..
<ul style="list-style-type: none"> • There is less risk of under/over recovery as the total delivered energy volume is more stable than the increase/reduction in TEC of power stations . 	<ul style="list-style-type: none"> • It introduces risks of material under- or over-recovery of allowed TO revenue recovery as kWh would only ever be a forecast.

Table 16 – Pros and Cons of a volume based TNUoS residual

4.411 There was no consensus within the Workgroup as to whether a change to the residual element of the TNUoS tariff was within the scope of the CMP213 Modification Proposal.

4.412 The Workgroup therefore decided not to develop this potential alternative any further.

(x) Sharing potential alternative 10 - Increase locational revenue recovery

4.413 The locational differences in the wider TNUoS tariff are derived from the Transport model using the unit cost of different types of transmission technologies in use on the transmission network and the incremental requirement for these different technologies based on the power flow of an incremental 1MW. The resultant nodal incremental impact is dependent on the flow of this incremental 1MW from its source (at the node in question) to the centre of the transmission network through the various circuits in proportion to their relative impedance (the value that dictates power flows through the network).

4.414 Rather than simply utilise the signal arising from this application of an incremental 1MW on a representation of the transmission network based on the underlying cost of the transmission assets, the Workgroup considered the possibility of collecting more revenue through the locational element of the TNUoS tariff as some believed this may increase cost reflectivity.

4.415 The result of collecting more revenue through the locational element of TNUoS could be to remove the need for the residual. This could be achieved by changing the centre of the transmission network, such that a different proportion of revenue is collected overall.

4.416 Figure 45, below, illustrates the impact of collecting both 0% of generation revenue (i.e. 0% of the 27% of total allowed revenue to be collected) and 100% of the generation revenue from the locational element of TNUoS tariffs. The TNUoS tariffs under these two scenarios are plotted against the actual locational element in 2011/12.




Figure 45 – Moving the reference node to collect more revenue from the locational element

4.417 Whilst, in practice, the model could be altered to achieve either of the above scenarios there was some debate in the Workgroup about whether (i) there would be any benefits of this approach and (ii) what it would actually be any more cost reflective than the Status Quo or the Original proposal given that the locational differentials remain unaffected.

4.418 The Workgroup also considered the possibility of collecting more revenue through the locational element of TNUoS by altering the unit cost assumptions used in the Transport model (i.e. the expansion constant and expansion factors). This began with a consideration of how transmission network costs are currently calculated and how these costs can vary for a given transmission technology.

Unit Cost Calculation

4.419 When calculating the generic expansion constant and expansion factors onshore, NGET accounts for the cost of the physical transmission circuit equipment (e.g. conductor, towers, and cable sealing ends) and average installation costs for each transmission circuit construction type incurred over a ten year period. No substation equipment, such as switchgear, or reactive compensation equipment is included in the calculation.

4.420 Once the typical cost for each transmission circuit construction type has been determined, the result is divided by the associated circuit rating is used to determine a £/MWkm cost for each type of transmission circuit. The weighted average cost per MWkm of installed circuit is calculated for that classification of transmission circuit (e.g. 400kV OHL, 400kV cable, etc.) based upon the total length installed. This is then annuitised, and a factor (currently 1.8%) of the pre-annuitised £/MWkm cost to cover annual transmission overheads (maintenance, rates, etc.) is added to give the final annual £/MWkm cost that forms the expansion constant or is used to determine the expansion factors.

4.421 For offshore transmission circuits, a project specific expansion factor is determined, by pro-rating the OFTO allowed revenue against each transmission asset by asset value, summing this up for circuit related items and then dividing by the larger of the circuit rating and the generator TEC (to avoid charging the generator more for an asset than the associated revenue).

- 4.422 In this case the OFTO allowed revenues associated with reactive compensation and harmonic filtering equipment are included within the expansion factor calculation, as onshore the equivalent equipment associated with onshore generators are owned by the generator. The cost of HVDC converter stations (that do not parallel the AC network) are also included in the circuit expansion factor calculation, as this is considered as being a cost incurred directly as a result of the chosen circuit technology.
- 4.423 The Workgroup consider analysis undertaken on cost data for 400kV OHL incurred over the past 10 years. It was noted that the most popular type of transmission technology used was utilised for 87% of 400kV OHL installed by NGET. Whilst there were some outliers (in comparison with the cost of this technology (-17% to +39%), these were typically short lengths in total (<3km in total for each technology installed over the 10 year period), and just under 97% of installed 400kV OHL was within +/-11% of the cost of the most utilised transmission technology.
- 4.424 The Workgroup noted that the largest range of transmission network costs expected would relate to 132kV overhead line, due to the difference in construction type (woodpole vs. steel tower). This can be observed by looking at the range of 132kV expansion factors used in the calculation of local transmission circuit tariffs (between 4.423 for large capacity (steel tower) double circuits, and 10 for low capacity (wood pole) single circuits). However, when looking at the wider cost, the use of an up-rating factor for the wider 132kV OHL expansion factor calculation (assuming that a higher voltage would be used for reinforcing a proportion of these circuits) confuses the issue somewhat. Nevertheless, comparing this to offshore where the expansion factors currently range from 63 to 150, it is clear that there is a much larger cost differential.

Consistency with GSR-009

- 4.425 Whilst reviewing GSR-009, one Workgroup member noted the cost of transmission investment used within the cost benefit analysis (CBA) which developed the deterministic NETS SQSS criteria upon which the Transport model scaling factors are based within the Original proposal. This annuitised value, of £100 per MWkm p. a.¹³, was based on an assumption of a generic reinforcement price of £1,000 per MWkm capital over ten years. In order to test the robustness of the CBA results to changes in input assumptions annuitised values of £50 per MWkm and £200 per MWkm were also investigated by the GSR-009 group.
- 4.426 The CMP213 Workgroup discussed the consistency of these values with those used in the TNUoS charging model (i.e. the Expansion Constant and Expansion Factors) in the context that some of the GSR-009 outcomes were being proposed to be used for TNUoS charging purposes.
- 4.427 The Expansion Constant (and Expansion Factors used in the TNUoS charging methodology are updated at each Transmission Price Control Review and increased by RPI in the interim period. As such, the existing Factors will not have been updated since 2007, during which time capital costs are known to have risen above inflation. The annuitised values currently used (2012/13) in NGET's area for the TNUoS charging calculation are shown in Table 17, below

¹³ Review of Required Boundary Transfer Capability with Significant Volumes of Intermittent Generation, Ref. GSR-009, 11 June 2010, Appendix 5, p. 55

Technology	Value relative to 400kV OHL	Unsecured value in £/MWkm	Security Factor	Secured value in £/MWkm
400kV OHL	1	£11.724	1.8	£21.103
275kV OHL	1.14	£13.365	1.8	£24.075
132kV OHL	2.80	£32.827	1.8	£59.089
400kV Cable	22.39	£262.5	1.8	£472.5
275kV Cable	22.39	£262.5	1.8	£472.5
132kV Cable	30.22	£354.299	1.8	£637.738

Table 17 – Existing expansion factors for NGET area

4.428 In calculating the incremental cost of transmission at a node on the transmission network, the Transport Model adds 1MW to that node and removes 1MW from the notional centre of the transmission network. The path that the incremental 1MW takes in various proportions through various transmission technologies (all with unique costs) over the distance to the centre of the transmission network sets the locational signal.

4.429 The following diagram, Figure 46, illustrates the relative costs used in the Transport and Tariff model and within the NETS SQSS CBA. Some Workgroup members believe that the same range of the Annuitised Unit Costs should be used in both the NETS SQSS and Charging methodologies to harmonise the basis for planning transmission investments and charging Users for use of the networks.




Figure 46 – Illustrative spread of charging and SQSS annuitised cost assumptions

4.430 The main sources of variation between these costs are the aforementioned misalignment due to the period over which costs are updated in the TNUoS charging methodology and, more importantly, the marginal nature of the cost assumptions used for GSR-009 (i.e. what is the cost of the next transmission technology that is likely to be used; including HVDC, which is not incorporated into the current TNUoS charging methodology) versus the average nature of the cost assumptions used for TNUoS charging (i.e. dictated by the existing transmission technologies on the network and the path of the incremental 1MW).

4.431 The Workgroup found that although differences between the NETS SQSS GSR-009 cost of transmission and those in the TNUoS charging model were evident, the reasons for these differences were such that they did not invalidate the use of the GSR-009 conclusions (i.e. background scaling factors for generation) in the Transport model of a potential future TNUoS charging methodology.

4.432 In addition, the Workgroup concluded that a review of transmission unit costs was not within the scope of this CMP213 Modification Proposal.

(xi) Sharing potential alternative 11 - Alternative Zoning

- 4.433 In order to promote stability in the charging signal TNUoS tariffs are calculated on a zonal, rather than nodal, basis. For demand, the zones are fixed to historical GSP Groups (equivalent to the 14 GB DNO areas). For generation this is done by comparing nodal marginal km arising from the Transport model with those at other geographically and electrically proximate nodes. Generation TNUoS zones are subsequently created by grouping those nodes that are both geographically proximate and no more than +/- £1/kW apart. A weighted average of nodal marginal km is subsequently taken to calculate the zonal TNUoS tariff.
- 4.434 Currently there is only one single set of marginal kms against which this zoning process takes place and all generators regardless of technology type are exposed to this tariff. The Original proposal sets out a dual background (Peak Security and Year Round) approach to setting two elements of the overall TNUoS tariff. In addition it proposes that intermittent generation are is not exposed to the Peak Security element. As all generators are exposed to the Year Round element of the TNUoS tariff, and due to the fact that this element represents over 80% of the total marginal kms, the Original proposes that the generation zoning process is done on this background.
- 4.435 There are many potential alternative approaches to generation TNUoS zoning. Two of the primary considerations when deciding on an approach should be the year on year stability of TNUoS tariffs against the cost reflectivity under one approach versus another.
- 4.436 In one potential alternative approach, generation TNUoS zones could be aligned with GSP Groups (i.e. with the 14 demand (DNO) zones). This would likely increase the (charging) year on (charging) year stability of wider generation TNUoS tariffs, but would have a trade-off in reduced cost reflectivity associated with having less granularity in the TNUoS charging signal.
- 4.437 A second potential alternative would be to zone generation TNUoS on the total marginal kms arising out of both the Peak Security and Year Round backgrounds, rather than simply those from the Year Round background.
- 4.438 Whilst the Workgroup discussed the above potential alternative approaches to generation zoning TNUoS tariffs, no specific potential alternative was proposed.

Other issues covered

- 4.439 The calculation of TNUoS tariffs for both Short Term TEC (STTEC¹⁴) and Limited Duration TEC (LDTEC¹⁵) currently utilises the final annual TNUoS tariff expressed in £/kW. Although different elements of the generation TNUoS charge exist at the moment, these are charged against the same chargeable MW capacity (TEC), and so can be simply added to reach the final TNUoS tariff utilised.
- 4.440 However, the proposed solution under the Original proposal will result in generation TNUoS charges that are no longer solely based upon the product of TEC and a tariff (e.g. the use of a load factor in the Year Round charge). This therefore raises the potential need for a consequential CUSC Modification Proposal to review the calculation of STTEC and LDTEC TNUoS tariffs. Such a modification may also need to look at the chargeable

¹⁴ <http://www.nationalgrid.com/uk/Electricity/Codes/systemcode/stfirm/>

¹⁵ <http://www.nationalgrid.com/uk/Electricity/Codes/systemcode/ldtec/>

capacity (MW) applied in the STTEC/LDTEC charge calculation, which may need to be considered in light of the changes made to the chargeable capacity under the Original CMP213 proposal.

4.441 Nevertheless the Workgroup did note that the relevance, and therefore use, of these transmission access products had reduced significantly since the introduction of a connect and manage approach to transmission network access and that this issue was likely to be minor as a result.

Q4: Do you consider that the Workgroup has adequately set out and considered all relevant options and potential alternatives on the *sharing* aspect of this modification proposal? If not, what other options would you like the Workgroup to consider and why?

Q5: What are your overall views on how best to reflect the differential impact of generators with distinct characteristics on incremental network costs into the TNUoS charging methodology?

Introduction

- 5.1 Currently the element of the TNUoS charging model that calculates nodal incremental costs does this using a set of input data including nodal generation and demand, transmission circuits and their characteristics (length, impedance, voltage and whether cable or overhead line). This is called the Transport model.
- 5.2 The Transport model then uses the DCLF ICRP transport algorithm to derive a resultant pattern of power flows based on the transmission network impedance for both a 'base case' and 'incremental 1MW' scenario. This is used to calculate the incremental network MWkm for 1MW of generation and demand (equal and opposite to generation) for a given node on the transmission network.
- 5.3 The Transport model employs the use of transmission circuit length expansion factors to reflect the difference in cost between:
 - i) AC cable and overhead line routes; and
 - ii) 132kV, 275kV and 400kV AC circuits
- 5.4 As the Transport model expresses cost as marginal kilometres (irrespective of transmission technology) and uses 400kV overhead line as the base technology, some account needs to be taken of the fact that investment in other transmission technologies is more expensive. This is done by effectively 'expanding' these more expensive transmission circuits by the relevant circuit expansion factor, thereby producing a larger marginal kilometre to reflect additional cost.
- 5.5 In order to accommodate increasing volumes of new generation connecting to the transmission network, the Transmission Owners have proposed the use of High Voltage Direct Current (HVDC) circuits¹⁶ that parallel the AC transmission network and would be routed offshore in order to avoid planning and consenting constraints (and associated timescales) onshore. These HVDC transmission circuits are not currently catered for in the Transport model.
- 5.6 In order to incorporate parallel HVDC transmission circuits into the TNUoS charging calculation two main issues need to be addressed:
 - i) treatment of flows in the DC load flow element of the charging model, in light of the inherent controllability of power flows through an HVDC transmission circuit; and
 - ii) calculation of the expansion factor (i.e. relative unit cost) for these HVDC transmission circuits.
- 5.7 The pattern of power flows set out in paragraph 5.2 is a key aspect of setting the locational differential between the TNUoS charging zones. With existing AC transmission technologies, this pattern is dictated by the relative impedance of the circuits that comprise the transmission network. This impedance is an inherent physical characteristic of an electricity conductor.
- 5.8 The Original proposal would treat power flow down a parallel HVDC transmission circuit in the Transport model on a simplifying assumption due to the controllable nature of these circuits relative to power flows on the AC transmission network, which are dictated solely by the impedance of a transmission circuit that is fixed.

¹⁶ One example can be found at: www.westernhvdclink.co.uk

- 5.9 This simplified approach would model HVDC transmission circuits that parallel the AC transmission network as a pseudo-AC circuit, thus requiring the calculation of a notional impedance for the HVDC circuit. This would be done by first calculating a base case flow down the HVDC circuit, which would subsequently be used to calculate the notional impedance for it in the Transport model.
- 5.10 The base case flow down the HVDC transmission circuit would be calculated as a ratio of power flows to circuit ratings across a transmission network boundary 'crossed' by the HVDC circuit. This approach would calculate a desired power flow for the HVDC circuit on each transmission boundary that the link 'crosses' and then average this flow across those multiple transmission boundaries.
- 5.11 In terms of the calculation of the expansion factor for an HVDC transmission circuit, the Original proposal would do so on a transmission circuit specific basis and would include both sub-sea cable and the HVDC converter station costs. This approach is consistent with offshore (OFTO) situations, where both costs are implicitly included in the expansion factor calculation for HVDC.

Inclusion of HVDC links

- 5.12 The Workgroup were required to consider the issues raised under this aspect of the CMP213 Modification Proposal and were asked to report on the following specific issues in line with/in addition to those set out in the Authority's SCR Direction by the CUSC Panel:
 - a) how often the parameters associated with the proposed approach should be updated (e.g. annually, every 4 years, every 8 years)
- 5.13 In the second meeting the Workgroup considered both the terms of the SCR Direction and the specific request from the CUSC Panel and compiled a single list of options and potential alternatives to be investigated from the outset. These are explored further below.

Initial scoping of the Original

- 5.14 The Workgroup agreed the areas to be considered for the HVDC aspect of the Original proposal could be summarised as:

Considerations from the Direction	Potentials changes to Original
a) Whether the cost of HVDC converter stations should be included in the expansion factor calculation	i) Remove all converter station costs from the calculation
	ii) Remove some converter station costs from the calculation
	iii) Treat HVDC cost as onshore AC transmission technology cost when calculating the expansion factor

Areas for development of Original and Potential Alternatives

- 5.15 The Workgroup also discussed further areas where the Original could be developed not highlighted by the Direction or where the potential alternatives could be developed and discussed each of these in turn.

Potential Alternatives	
i.	Review the overhead factor (i.e. 1.8%) used when annuitising the capital cost in the calculation of the HVDC expansion constant
ii.	Calculated the 'desired flow', and hence notional impedance, by balancing flows across the single most constrained transmission boundary rather than all the transmission boundaries the HVDC link 'crosses'
iii.	Review security factor calculation in light of long (MWkm) HVDC links comprised of single transmission circuits that parallel the AC transmission network

Discussion on the Original and potential alternatives

5.16 The following section presents the Workgroup detailed discussion on the issues identified above.

a) Whether the cost of HVDC converter stations should be included in the expansion factor calculation

5.17 As set out above, the Original proposal would include all the costs of an HVDC converter station into the expansion factor calculation. This is deemed to be consistent with the approach taken for offshore (OFTO) transmission TNUoS tariffs.

5.18 The Workgroup investigated alternatives to this approach.

5.19 In doing so they noted that there are basically two cost elements associated with HVDC transmission circuit, namely (i) the cost of the sub-sea cables and (ii) the cost of the onshore converter stations that converts the electrical current between AC and DC so that it can be transferred along the sub-sea cables. The Workgroup considered how these two cost elements could be included within the Improved ICRP solution.

a) i) Remove all converter costs from the calculation

5.20 The Workgroup discussed a potential alternative where 100% of the cost of the sub-sea cables would be included in the expansion factor and 100% of the cost of the onshore converter stations would be excluded from the expansion factor calculation on the basis that some members of the Workgroup believed that the HVDC converter station costs should be treated as fixed costs.

5.21 The reason some members came to this view is that the locational element of the ICRP charging methodology is underpinned by a MWkm (distance related) methodology with fixed elements, such as transformers, being excluded from the calculation of the locational element of the tariff and instead being recovered through the residual element.

5.22 These members believed that HVDC converter stations exhibit the same traits as other fixed elements of the transmission system. For example, that they have broadly the same function as transformers/substations in that they effectively link different elements of the transmission system. In addition and they can also provide system services (specifically reactive compensation and post-fault power flow redirection).

5.23 On this basis these members believed that including any fixed costs in the calculation of expansion factors would cause a distortion in the locational

element of the TNUoS tariff. They believed that this is particularly the case with HVDC transmission circuits as the converter station costs are such a significant proportion of the total cost. They were of the view that including fixed costs in the calculation of the HVDC transmission circuit expansion factor will cause a distortion in the locational element of the TNUoS tariff and would make it inconsistent with the existing TNUoS charging methodology expansion factors calculations.

- 5.24 One Workgroup member cited an example, using numbers in the Project Transmit Technical Working Group Report and taking the cable cost as including the converter station costs then the cost of the Western 'bootstrap' HVDC transmission circuit is £1bn, the capacity 2GW and the distance 370km. The cost, in this example, of the converter stations is £550m. In a distance related model, it would be expected that if the distance halved, the effective cost of the cable would reduce in proportion. However, including the converter station costs means that when the cable length is halved, the effective cost in £/MWkm in the model would increase by 55%.
- 5.25 Some Workgroup members believed that this could not be a proper reflection of the locational element of the costs. That can only be reflected by excluding the costs of the converter stations from the calculation of the cable expansion factor and allocating the converter station costs to the residual element of TNUoS tariffs.
- 5.26 The Proposer noted that, as the Original Proposal was proposing to calculate HVDC expansion factors on a circuit specific basis, the issue of fixed costs not altering with distance would not be an issue (i.e. each circuit would have a fixed distance). Indeed, the Proposer believed that in order to use HVDC cable technology converter stations are necessary, that these converter stations add to the cost of this transmission technology and as such should be included in the locational signal so that transmission network Users can properly take account of the cost of transmission when deciding to locate their generation plant.
- 5.27 Some Workgroup members believed that there are wider issues in relation to expansion factor calculations. Reinforcement by HVDC circuit is taking place for the benefit of Great Britain customers and generators. Using HVDC is driven by the UK and Scottish Governments climate change obligations and targets together with the difficulties in getting planning for overhead transmission lines. However, these members believed that this should not result in excessive costs being allocated to those generators on one end of the HVDC transmission circuit. In particular, these members believed that it should not be for those generators to pick up the fixed costs of reinforcement through a locational tariff. Indeed, without the removal of these fixed costs, the resulting TNUoS charges may prevent the investment in the very generation that the HVDC cables are intended to serve.
- 5.28 Others in the Workgroup believed that the costs of the HVDC converter stations represented the actual costs of investment in that transmission technology and therefore did not consider that these costs could be considered as excessive. These members were of the view that, if a potential investment in generation in one area of the transmission network was made uneconomic by TNUoS tariffs, that this simply represented a project that was not viable when including the cost of delivering their product to market. They believed that, this may represent the best outcome for consumers. Nevertheless, some Workgroup members were of the view that this could prevent a number of GW of low carbon generation from contributing to UK sustainability targets.

a) ii) Remove some converter costs from the calculation

5.29 The Workgroup identified 2 possible alternatives for the removal of a portion of the HVDC converter station costs from the expansion factor calculation:

- i) Remove a percentage of the costs based on those elements of the converter station that are similar to elements of the AC transmission network that are currently not included in the locational signal (such as substation equipment); and/or
- ii) Remove a portion of the costs based on the similarity between the power flow redirecting capability of HVDC converters and that of Quadrature Boosters (QBs) that are currently not included in the locational signal;

i) Remove a percentage of the HVDC converter station costs based on elements similar to AC substations

5.30 The TNUoS charging methodology currently does not include many of the costs of the transmission network that do not vary with distance, such as substation costs, in the calculation of expansion factors. On this basis, and the fact that a proportion of HVDC converter station costs are related to AC substation equipment, the Workgroup believed that a possible alternative to the Original proposal could be to remove those cost elements from the calculation of the expansion factor. This approach would maintain the DC elements, such as the switching equipment, required for the use of DC cables.

5.31 The Workgroup recognised that one of the difficulties with this approach was that there have not yet been any HVDC transmission links established to date and that these projects were often procured on a turn-key basis with minimal cost breakdown.

5.32 Nevertheless, the Workgroup did manage to find a breakdown of costs for a typical HVDC converter station from Cigre paper 186, working group 14.2 (June 2001). The cost breakdown from this paper is reproduced in Table 18, below.

Breakdown of Typical HVDC Converter Station costs			
	Cost Elements	Proportion of Cost	Characteristic (AC/DC)
(1)	DC switchgear	6%	DC
(2)	Valve group	22%	DC
(3)	Control, Protection, Comms	8%	Shared
(4)	Converter transformer	22%	AC
(5)	AC switchboard and filters	9%	AC, but filter DC
(a)	Civil, mechanics and works	13.5%	split in proportion to (1)-(5)
(b)	Auxiliary power	2.5%	
(c)	Project engineering and admin	17%	

Table 18 – Cost breakdown of a 'typical' HVDC converter

5.33 Having considered the numbers presented in Table 18, above, the Workgroup noted that approximately half the cost of a typical HVDC converter station is akin to AC substation elements not included in the locational (TNUoS) signal throughout the rest of the transmission network.

5.34 As a result, some Workgroup members believed that it may be reasonable to take this into account when calculating the expansion factor for a HVDC circuit that parallels an AC network.

5.35 Depending on the specific application of an HVDC transmission circuit, in particular the length of the cable, the Workgroup considered that converter station costs were likely to comprise somewhere between 30% to 50% of the total costs of the HVDC link. In this case, removing half the cost (of the converter station) from the expansion factor calculation would reduce the expansion factor by between 15% and 25%.

ii) Remove a percentage of the HVDC converter station costs based on controllability similar to QBs

5.36 The Workgroup also considered the controllability of HVDC transmission circuits and the potential benefits that may be afforded to the System Operator as a result of this controllability. Some in the Workgroup believed that these benefits should be reflected in a reduction of the expansion factor.

5.37 After some debate, the Workgroup agreed that, for Current Source Converters, these benefits are likely to be somewhat nebulous, difficult to quantify and may result in a lower BSUoS tariff, but that they were unlikely to be relevant to the incremental cost of transmission capacity upon which TNUoS charges are based and expansion factors are calculated.

5.38 Some members believed that this was not necessarily the case for Voltage Source Converters, as planned for use in some island connections. This is outlined further in the islands aspect of this proposal.

5.39 One item of transmission technology that does allow the System Operator to better utilise existing transmission network capacity is the Quadrature Booster (QB), which can be used to redirect power flows on transmission circuits. As such, this benefit could be considered to be relevant to the incremental cost of transmission capacity. However, currently QBs are not factored into the locational signal.

5.40 In April of 2006 National Grid undertook a review of the elements included in the incremental cost of capacity as part of GB Charging Condition 2¹⁷. This review considered the addition of QBs and reactive compensation devices into the calculation of locational differentials.

5.41 At that time National Grid concluded that, due to the way in which they redirect power flow on the transmission system, rather than provide additional transmission capacity, the addition of QBs was likely to be subjective. Condition 2 proposed that the potential increased cost reflectivity of inclusion of QBs in the Transport model was outweighed by the increased subjectivity and complexity that this would introduce.

5.42 In addition to providing transmission capacity, HVDC converter stations can also be used to redirect power flows and in this sense are similar to QBs. Some Workgroup members believed that as QBs were not included in the locational signal, the equivalent cost should also be removed from the HVDC expansion cost calculation.

5.43 The relative cost of a representative HVDC versus a QB and a transformer was presented to the group by National Grid and is shown in Figure 47, below.

¹⁷¹⁷ <http://www.nationalgrid.com/uk/Electricity/Charges/gbchargingapprovalconditions/2/>




Figure 47 – Relative cost of CSC HVDC, QBs and Transformers

- 5.44 This cost comparison indicates that if QB costs were to be removed from the HVDC converter station cost element, that this would likely amount to the order of a 10% cost reduction to the converter station (i.e. 3% to 5% of the total HVDC link cost).
- 5.45 Having considered the two potential alternatives above, the Workgroup concluded that there were potential alternatives that would remove either 10% or 50% of the total converter station costs from the overall HVDC circuit expansion factor, depending on the logic used for justifying this cost removal. Some Workgroup members were of the view that both a 10% and 50% removal of costs would be justified.

a) iii) Treat HVDC cost as onshore AC transmission technology cost when calculating the expansion factor

- 5.46 Some of the Workgroup believed that the expansion factor calculation for HVDC transmission circuits should be based on actual HVDC unit costs in order to be cost reflective.
- 5.47 One Workgroup member cited several public documents setting out the cost of the Western HVDC ‘bootstrap’ transmission circuit:
- 1) the joint statement from National Grid and Scottish Power in July 2012 concerning the Western HVDC ‘bootstrap’ and, in particular, the statement “...that the cost of onshore reinforcement would be similar to that of an offshore HVDC alternative¹⁸”; and
 - 2) the joint DECC / Ofgem ENSG report ‘Our Electricity Transmission Network: A Vision For 2020’ (February 2012) and, in particular, that the onshore circuits “...did not represent the most economic solution. The total length of the new circuits would be in excess of 600km; this resulted in a total project cost that was higher than the undersea HVDC option.”¹⁹
- 5.48 Some of the Workgroup believed, in the case of the Western HVDC link, that it should be treated in exactly the same way as the equivalent parallel (onshore) AC 400kV transmission circuits in the TNUoS charging methodology.
- 5.49 It was appreciated by the Workgroup that this approach would apply the existing expansion constant (i.e. an expansion factor of 1) to the HVDC transmission circuit, and that this would ultimately result in a reduction in tariffs in TNUoS zones north of the HVDC transmission circuit.

¹⁸Planning Statement Western Link July 2012, paragraph 2.5.2

¹⁹ Page 70 of this report

- 5.50 These Workgroup members believed that to do otherwise would be to unduly discriminate against certain Users as they would be exposed to a higher TNUoS charge, even though the actual cost and MW capacity of the two comparable links (one 400kV AC onshore / one 600kV HVDC offshore) were similar. These members considered that in addition to being discriminatory it would also not be cost reflective given that both the cost and capacity were similar, but one option (the onshore AC) would, if built, have resulted in a substantially lower TNUoS charge than the other option (sub-sea HVDC).
- 5.51 The Workgroup discussed the differences between a sub-sea HVDC transmission link and the alternative (onshore) 400kV AC transmission reinforcements in terms of capacity provided, costs and timescales. Not all members of the Workgroup were convinced that both cost and network capacity provided by the onshore AC and sub-sea HVDC options were comparable.
- 5.52 One significant difference identified by some Workgroup members was the significant annual constraint costs that would be incurred during the planning delays expected to occur during the building of the aforementioned onshore alternative transmission system reinforcement.
- 5.53 In particular, based on recent experience with long distance onshore 400kV overhead transmission line construction, it is generally anticipated that building an equivalent onshore transmission link could take more than 10 years, from concept to commissioning. This was likely to be halved for an equivalent HVDC transmission link, leading to a period of time where such an HVDC link provided relief, from constraint costs, compared to the equivalent onshore link. In the view of some Workgroup members this should result in a discount, on the HVDC TNUoS charge, to reflect the constraint costs saved (over the period of time in question). However, other members of the Workgroup noted that constraint costs were not charged locationally.
- 5.54 A potential alternative where a sub-sea HVDC transmission circuit is treated as if it were (onshore) 400 kV transmission technology was deemed plausible by some members of the Workgroup., but was not widely supported by Workgroup members.

Q6: Do you believe that the Workgroup has considered all relevant options and potential alternatives for how the expansion factor (i.e. unit cost) for an HVDC circuit paralleling the AC network should be calculated for inclusion in the TNUoS charging calculation? If not, please provide suggestions with an associated justification.

Potential Alternatives

i) Review the overhead factor (i.e. 1.8%) used when annuitising the capital cost in the calculation of the expansion constant

- 5.55 When annuitising capital costs of transmission assets to calculate the expansion constant and expansion factors, the TNUoS charging methodology utilises a weighted average cost of capital assumption of 6.25% and a transmission asset life of 50 years to calculate an annuity factor of 0.066.
- 5.56 In order to account for operational expenditure an additional overhead factor is calculated at the start of each Transmission Price Control Review period by taking the average annual operational expenditure over the period and dividing by the gross asset value. Currently this value is set at 1.8% and

applies equally across all transmission technologies through the annuity process.

5.57 Despite the global nature of this value, the Workgroup discussed whether it would still be appropriate for it to be applied to an HVDC transmission link with sub-sea cables, given the differences with existing AC transmission technology. The investigation began with consideration of what proportion of the operational expenditure included in the overhead factor calculation would be transmission asset specific.

5.58 Figure 48, below, shows the approximate break down of operational costs over the next (RIIO-1) Transmission Price Control Review period. The Workgroup considered that only those costs that were controllable could change on an (transmission) asset by asset basis.




Figure 48 – Average PCR breakdown of OPEX

5.59 The Workgroup also considered further the breakdown of controllable costs into (i) direct OPEX, (ii) closely associated indirect costs and business support costs, (iii) Critical National Infrastructure and (iv) Innovation Funding Initiative costs. Of these costs, 40% were direct OPEX, and it is these costs that are transmission asset related.

5.60 From the above, the Workgroup concluded that approximately 25% (i.e. 40% of 62%) of the 1.8% overhead factor could vary for different transmission asset types.

5.61 Using the Parsons Brinkerhoff Transmission Costs report (2012)²⁰, the Workgroup also investigated how lifetime operational costs vary for the different transmission assets used. Figure 49, below, illustrates the differences of lifetime OPEX over build costs for various transmission technologies.




Figure 49 – Lifetime OPEX/Build Cost for various transmission asset types

²⁰ www.theiet.org/factfiles/transmission.cfm

5.62 From the above Figure 49 the Workgroup concluded that, despite variances in lifetimes for the transmission assets considered, the differences were such that the overheads for (offshore) HVDC transmission circuits were likely to be higher than those of other transmission assets such as (onshore) overhead lines and underground cables.

5.63 The Workgroup discussed the benefits of simplicity and stability arising from the use of a single overhead factor for all transmission assets and concluded that the minor increase in cost reflectivity associated with a more specific treatment did not warrant consideration of a potential alternative in this area.

ii) Calculate the 'desired flow', and hence impedance, by balancing flows across the single most constrained transmission boundary rather than all the transmission boundaries the circuit crosses

5.64 As set out in paragraph 5.10, above, the Original proposal would calculate the base case flow down the HVDC transmission circuit as a ratio of power flows to circuit ratings across a transmission network boundary 'crossed' by the HVDC circuit. This approach would calculate a desired power flow for the HVDC circuit on each transmission boundary that the circuit 'crosses' and then average this flow across multiple transmission boundaries.

5.65 The Workgroup appreciated that the calculation of an impedance in order to model the HVDC transmission circuit as a pseudo-AC transmission circuit was not an exact science due to the controllable nature of the HVDC circuit. In addition, the Workgroup appreciated that this impedance calculation would have a significant impact on the proportion of the incremental MW that would use the HVDC circuit. As the route of this incremental 1MW is used to calculate the locational signal, the potential impact on TNUoS tariffs of this calculation was clear.

5.66 As a potential alternative to calculating the base case flows across individual transmission boundaries and subsequently averaging the flows across all these boundaries that the HVDC transmission circuit 'crosses' in order to calculate the impedance, the Workgroup considered simply calculating the base case flows on the single most constrained transmission boundary that the HVDC circuit reinforces.

5.67 The logic behind this approach was that it is this most constrained transmission boundary that would limit the additional network capacity provided by the installation of the HVDC circuit on the overall transmission system.

5.68 The impact of calculating base case flows on a single, rather than multiple transmission boundaries, would be a reduction in the impedance (i.e. the base case flow on the HVDC transmission circuit would increase) and a resultant increase in incremental flows down the HVDC link. The Workgroup appreciated that this would increase the locational differentials relative to the multiple transmission boundary approach proposed in the Original.

Q7: Do you believe that the Workgroup has satisfactorily considered all the options and potential alternatives for how an HVDC circuit paralleling the AC network should be modelled in the DC load flow element of the TNUoS charging calculation? If not, what other options would you like the Workgroup to consider and why?

iii) Review security factor calculation in light of long (MWkm) HVDC transmission circuits comprised of single circuits that parallel the AC transmission network

- 5.69 Currently, the locational onshore security factor for the wider transmission network is derived by running a secure DCLF ICRP transport study based on the same market background as used in the DCLF ICRP Transport model. This calculates the nodal marginal costs where peak demand can be met despite the Security and Quality of Supply Standard (NETS SQSS) contingencies (simulating single and double circuit faults) on the transmission network.
- 5.70 The calculation of secured nodal marginal costs is identical to the process outlined above except that the secure DCLF study additionally calculates a nodal marginal cost taking into account the requirement to be secure against a set of worse case contingencies in terms of maximum flow for each transmission circuit.
- 5.71 The secured nodal cost differential is compared to that produced by the DCLF ICRP Transport model and the resultant ratio of the two determines the locational security factor using the Least Squares Fit method.
- 5.72 The prevailing security factor for the wider transmission network is currently 1.8 and is based on an average from a number of studies conducted by NGET to account for future transmission network developments. The security factor is reviewed for each Transmission Price Control Review period and fixed for the duration of that Review period.
- 5.73 Some Workgroup members believed that the introduction of a single circuit HVDC transmission circuit (i.e. connected via a single bi-pole) warranted a review of whether it was still cost reflective to apply a security factor of 1.8 for this part of the transmission network.
- 5.74 The Workgroup discussed the fact that if HVDC were to be introduced into the existing secured DCLF calculation that it would be unlikely to materially affect the outcome if a global factor remained.
- 5.75 One Workgroup member considered that if the cost of the HVDC transmission circuit was to be multiplied by 1.8 in the TNUoS tariff calculation, that this should be done on the unit cost of a double transmission circuit rather than the single transmission circuit that was planned.
- 5.76 This member pointed out that the reverse had been done for single transmission circuit connections when local transmission circuit charging was introduced.
- 5.77 Nevertheless it was the Workgroup's view that the unit cost of a double circuit HVDC transmission circuit was likely to be similar to that of a single transmission circuit link. Whereas onshore transmission circuits would see a cost difference due to savings in towers, etc., a second HVDC circuit would likely also require an additional converter station and would hence likely have a very similar unit cost.
- 5.78 As a result, no potential alternatives were considered by the Workgroup in this area.

Q8: Do you consider that the Workgroup has adequately set out and considered all relevant options and potential alternatives on the HVDC circuit aspect of this modification proposal? If not, what other options would you like the Workgroup to consider and why?

Q9: What are your overall views on how best to incorporate HVDC circuits that parallel the AC network into the TNUoS charging methodology?

Introduction

- 6.1 CMP 213 seeks to develop a methodology for calculating cost reflective TNUoS charges for transmission spurs (connecting generation and demand) and comprised of transmission network technology not included in the expansion factors set out in clause 14.15.47 and 14.15.49 of the CUSC such as those which may be established between the Scottish mainland and the Scottish islands of Western Isles, Orkney and Shetland.
- 6.2 Whilst charging for island connections comprised of sub-sea cables is not currently codified in the CUSC, it was the subject of a charging consultation²¹ published in November 2009 that proposed the use of specific expansion and security factors on the basis that these connections to the transmission network would be classed as local transmission assets under the current definition.
- 6.3 In order to calculate cost reflective TNUoS charges for this type of sub-sea transmission circuit configuration the Original proposal also addressed how the expansion and security factors should be calculated for the underground and subsea transmission technologies proposed for island connections and not included in the TNUoS charging methodology.
- 6.4 As outlined above for HVDC transmission circuits, the TNUoS charging methodology incorporates the unit cost of various transmission technologies by calculating the cost of a given technology relative to the cost of a 400kV (AC) overhead transmission line. This allows for the calculation of a multiplier, known as an expansion factor, which is used in the Transport model to calculate the locational signal within TNUoS charges.
- 6.5 For transmission spurs, such as those connecting Scottish islands, the Original proposes to calculate new expansion factors for each type of transmission network technology planned. Where such circuits are comprised of HVDC technology, the methodology would be consistent with that for HVDC transmission circuits paralleling the AC transmission network.
- 6.6 The Original proposal would not alter the definition of a MITS node (i.e. connected via > 4 transmission circuits or 2 transmission circuits + a Grid Supply Point). The consequence is that, with the connections currently proposed, some circuits connecting islands to the mainland would be classed as 'local' and others would be classed as 'wider'.
- 6.7 In addition, the Original addresses circumstances where a reinforcement creates a MITS node but where a significant proportion of the transmission spur has no redundancy, but is still deemed to be part of the wider transmission network for TNUoS charging purposes. Rather than apply the current GB average cost of security (using a Security factor of 1.8), the Original proposal applies the actual level of security (1.0). It does this by adjusting the length of the relevant portion of the transmission circuit in the Transport model to compensate by multiplying its actual length by 1/(Locational Security Factor).
- 6.8 As the sharing aspect of the Original proposal assumes that sharing occurs implicitly across the wider transmission network, generators connected to nodes on islands classed as part of the Main Interconnected Transmission System (MITS) for TNUoS charging purposes would pay a two part tariff,

²¹ <http://www.nationalgrid.com/NR/rdonlyres/5492DC2B-5A82-478A-8673-0EBAC44D2C69/39267/GBECM20Consultationv11.pdf>

including the sharing factor (based on their plant's annual load factor), associated with this aspect of the Original proposal.

- 6.9 For the avoidance of doubt, the Original proposal assumes that no sharing occurs on transmission circuits classed as local, based on how these types of circuits are planned in the NETS SQSS.
- 6.10 The Workgroup were required to consider the issues raised under this aspect of the CMP213 Modification Proposal and were asked to report on the following specific issues in addition to those set out in the Authority's SCR Direction by the CUSC Panel:

Inclusion of Island Connections

- a) ensure that the charging solution is commensurate with transmission access rights;
 - b) consider appropriate approach for islands that form part of integrated offshore networks; and
 - c) review the application of the expansion factor in the tariff calculation.
- 6.11 In the second meeting the Workgroup considered both the terms of the SCR Direction and the specific request from the CUSC Panel and compiled a single list of options and potential alternatives to be investigated from the outset. These are explored further below.

Initial Scoping of the Original

- 6.12 The Workgroup agreed the areas to be considered for the sharing aspect of the Original proposal could be summarised as:

Considerations from the Direction	Potentials changes to Original
a) Whether Islands classed as 'wider' for charging purposes should have a 2 part wider TNUoS tariff as determined by the sharing aspect of the Original proposal	i) Islands classed as wider do not have a two part TNUoS tariff
b) Whether Islands classed as 'local' for charging purposes should have TNUoS tariffs consistent with the current existing methodology for local circuit and local substation tariffs	i) Review local/wider definitions and perhaps consider an alteration/addition to accommodate Scottish Islands (e.g. look at MITS)
	ii) Apply sharing to local circuits incl. Scottish Islands
c) Whether the expansion factor should be calculated in a generic manner across all Islands or whether it should be island link specific	i) Across all islands regardless of transmission technology
	ii) One generic factor for AC, and one for DC
	iii) Island (i.e. not link) or Island Group ²² specific

²² 'Island Groups', for the purposes of Workgroup discussions were considered to be those in Scotland, and in particular (i) the Western Isles (ii) Orkney and (iii) Shetland only.

d) Whether, for islands classed as 'wider', the global locational security factor should be used without further modification or whether any lack of redundancy should be reflected in the expansion factor calculation	i) Yes; apply 1.8 for two circuit cases
	ii) Yes; some other factor between 1 and 1.8
e) Whether the expansion factor calculation for radial island links comprising HVDC technology should be the same as that for HVDC links that parallel the (onshore) AC transmission network	i) Yes (on all elements of HVDC options)
f) Whether an anticipatory application of the MITS definition to islands is appropriate and how this could be done.	i) Yes; just to islands
	ii) Yes; to everything

Areas for development of Original and Potential Alternatives

6.13 Given the extensive nature of the SCR Direction in this area, the Workgroup could not think of any further areas where the Original could be developed not already highlighted by the Direction or where any additional potential alternatives might be developed.

Discussion on the Original and Potential Alternatives

6.14 This section covers the Workgroup discussions on each of the individual issues above. It does so by taking each of six main considerations from the SCR Direction in turn, with each of the potential changes to the Original covered under these main considerations.

a) Whether Islands classed as 'wider' for charging purposes should have a 2 part wider tariff as determined by the sharing aspect of the proposal

6.15 The Original proposal applies the principles of sharing set out within it to all parts of the transmission network considered to be part of the Main Interconnected Transmission System (MITS); (i.e. 'wider'); for TNUoS charging purposes. Implicitly this would also include island connections that are classed as 'wider' because they are part of the MITS.

6.16 In the calculation of a 2 part wider TNUoS tariff, the Original proposal uses the background assumptions set out within the NETS SQSS, which sets out minimum deterministic standards to which the TOs are required to plan their transmission networks in accordance with their Transmission Licences.

6.17 These backgrounds include a Peak Security background, where the need for transmission capacity is assumed to be driven by the capacity of generators that have a high probability of being available at times of peak demand and a Year Round background, which represents a pseudo-cost benefit analysis (CBA) approach to transmission capacity planning.

6.18 These two separate backgrounds are used by the Transport model to allocate incremental transmission network requirements to Peak Security and Year Round elements, ultimately leading to a two part TNUoS tariff. On the basis that the Year Round background is representative of the pseudo-

CBA approach developed in the NETS SQSS, incremental requirements allocated to this element are deemed to be planned using a CBA approach to transmission network investment (i.e. involving a trade-off between investment costs and potential future operational costs).

- 6.19 Where a CBA approach to transmission network investment is used, the TO will seek to optimise network costs such that additional transmission capacity will only be added where the cost of installing that additional capacity is outweighed by potential future constraint costs. As a result, in the long term one would expect that the cost of reinforcing a given area of the transmission network would converge with the associated operational costs on average.
- 6.20 In terms of incremental transmission network requirements (i.e. on a MW by MW basis) as used in the TNUoS calculation, the Original proposal would continue to calculate incremental transmission network costs (i.e. the Long Run Marginal Cost – LRMC) using the impact of an incremental 1 MW in the Transport model for each of the two backgrounds (Peak Security and Year Round).
- 6.21 In order to differentiate between the impact on transmission network costs of generation plant with different characteristics, extensive analysis of the impact of these plant types on the operational costs in a given area of the transmission network was undertaken using National Grid's ELSI model (which is an Excel based model that was circulated to the Workgroup). The Proposer believed that this analysis demonstrated that there is a discernable relationship between a generator's annual load factor and its impact on incremental operational costs (i.e. the Short Run Marginal Cost – SRMC) of the transmission system.
- 6.22 Due to the aforementioned convergence of the LRMC and the SRMC on average over the long term where the transmission network is planned using the cost benefit analysis, the Original proposal introduces a generation sharing factor multiplier (using annual load factor) based on the results of the ELSI modelling to the Year Round element of the tariff calculated in the Transport model.
- 6.23 The Workgroup investigated potential alternatives to this approach.

a) i) Islands classed as wider do not have a 2 part wider tariff

- 6.24 As set out in the 'Discussions on Sharing' section, above, the Workgroup has also undertaken analysis that demonstrates a degradation of the relationship between a generator's annual load factor and incremental transmission network costs over the longer term as the capacity of low carbon generating plant (with zero and negative bid prices in the balancing mechanism) increases in a given part of the transmission network. This effect is most prominent on the extremities of the system.
- 6.25 The Original proposal accepts some degradation of the established relationship in the future in a small number of areas of the wider transmission network in order to maintain the benefits of a simple and transparent annual load factor based approach to reflecting the characteristics of different generators on incremental transmission network costs.
- 6.26 The Workgroup discussed whether this balance between cost reflectivity and simplicity of the TNUoS tariff calculation established within the mechanics of the Original proposal would be maintained for an example case where only wind generators were connected behind high unit cost island transmission links.

- 6.27 Some in the Workgroup believed that this balance would unlikely be maintained – i.e. that the application of an annual load factor based sharing factor to the Year Round element of the tariff under the Original was stretched too far for long, high unit cost (i.e. sub-sea) radial transmission spurs put in place for and utilised predominately for low carbon generation. However, there was disagreement on how to address this.
- 6.28 There was general agreement amongst Workgroup members that if island nodes were classed as MITS, there would be no justification for generators located on islands not to have a two part, Peak Security and Year Round, TNUoS tariff consistent with those connected to the MITS on the mainland, as per the Original proposal.
- 6.29 Whilst there was agreement around the application of the two part TNUoS tariff, there was concern amongst some in the Workgroup that the automatic application of the sharing factor to islands nodes which became classed as MITS (but that also shared many characteristics of a local circuit in terms of transmission network planning) may tip the balance between cost reflectivity and simplicity too far and in so doing undermine the Original proposal. In particular some believed that the relatively high cost of island sub-sea island transmission connections exacerbated the issue.
- 6.30 Some in the Workgroup believed that the potential alternatives to the Original being considered that take account of the diversity of generation plant types (in particular bid price diversity) in an area of the GB transmission network (including, but not limited to, islands) or potential alternatives arising from the island specific analysis carried out by Heriot-Watt would deal with this problem sufficiently. These options are outlined in more detail in the sharing section, above..
- 6.31 In the context of the Original proposal, which would apply a generation sharing factor to the entire wider transmission network without consideration for diversity, the Workgroup looked at how this perceived imbalance between cost reflectivity and simplicity for high incremental cost island cases could be addressed.
- 6.32 Hence, the Workgroup also investigated potential alternatives to this approach, set out in (b) (i) and (ii) below.

b) Whether Islands classed as ‘local’ for charging purposes should have tariffs consistent with the current existing methodology for local circuit and local substation tariffs

- 6.33 Currently, for generation Users, the locational element of the TNUoS tariff is comprised of three separate components; (i) a wider component that reflects the costs of the wider transmission network (comprised of MITS nodes), and the combination of (ii) a local substation and (iii) a local circuit component that reflect the costs of the local transmission network.
- 6.34 Local components were introduced into the TNUoS charging methodology in 2009²³ in order to provide a cost reflective signal for transmission assets local to generation. This was to provide the appropriate charging signal to Users in choosing between differing levels of transmission investment through the NETS SQSS connection design provisions such, that these decisions (by the User) are made which result in the most economic and efficient outcome.

²³ GB ECM-11 ‘For the charging arrangements for Generator Local Assets’ Conclusions report; http://www.nationalgrid.com/NR/rdonlyres/27F920CA-C678-4D91-A3D1-701E909BDAFB/28281/GBECM11ConcReport_final_HR.pdf

- 6.35 It was noted that in many instances Users are given a connection with a design variation (single circuit connection) by the Transmission Owner as the only practical/economic connection option (i.e. not all Users have a choice over the design of their local assets) and that in these cases it was not appropriate to apply the Global Locational Security Factor (1.8) applied to the remainder of the transmission network. This is addressed in the Original through an adjustment to the expansion factor, as set out above.
- 6.36 All generation that is subject to TNUoS and not connected directly to a Main Interconnected Transmission System (MITS) substation will have a circuit component to their local (TNUoS) charge. For charging purposes a MITS substation is defined as: (i) a Grid Supply Point (GSP) connection with 2 or more transmission circuits connecting at the substation; or (ii) more than 4 transmission circuits connecting at the substation.
- 6.37 Cost differentiation for wider transmission infrastructure for generation Users is currently managed via a zoning process whereby geographically and electrically proximate generation nodes on the transmission network are grouped together into zones providing their nodal incremental costs are within +/-£1.00/kW. Other than in exceptional circumstances, zones are fixed for the duration of a Transmission Price Control Review period.
- 6.38 In the process of generation zoning, individual nodal costs (not more than +/-£1.00/kW apart) are averaged across the TNUoS charging zone in accordance with the demand weighting at each node to achieve a single zonal wider TNUoS tariff.
- 6.39 As the proposed connection designs for the Western Isles and eventually Orkney could lead to nodes on these islands being classed as MITS, thereby subsuming the island links to those islands into the wider element of the TNUoS tariff, there was some discussion in the Workgroup about how an island tariff would differ between a situation where it was classed as wider, and one where it was classed as local.
- 6.40 As the sub-sea transmission technologies proposed to connect these islands to the rest of the transmission network do not exist in the current TNUoS charging methodology, new expansion factors (i.e. annuitised unit costs) will have to be calculated for these. As a result of this limited pool of transmission assets the expansion factors for a circuit classed as local would be the same as that classed as wider.
- 6.41 On the main interconnected transmission system, where there are many nodes on the transmission network that are geographically and electrically proximate and connected by relatively low cost transmission technologies, the zoning criteria set out in paragraphs 6.37 and 6.38 will lead to a single average zonal TNUoS cost (comprised of individual nodal costs).
- 6.42 The Workgroup appreciated that, for island nodes classed as MITS in the future, the TNUoS charging methodology zoning criteria would result in the island (MITS) node itself being classed as a separate zone due to the relatively high cost of the sub-sea links used to connect them to the mainland. As a result of this zoning and the specific expansion factor the Workgroup noted that the island generation tariff for an island link classed as local or wider would be very similar. The only difference noted by the Workgroup would occur if the treatment under the sharing aspect of the modification varied between local and wider elements of the transmission network.

b) i) Review of Local/Wider definitions in the context of islands

- 6.43 All non-embedded generation that is subject to TNUoS and not connected directly to a Main Interconnected Transmission System (MITS) substation will have a circuit component to their local TNUoS charge. For charging purposes a MITS substation is defined as:
- (a) a Grid Supply Point (GSP) connection with 2 or more transmission circuits connecting at the substation; or
 - (b) more than 4 transmission circuits connecting at the substation.
- 6.44 The Workgroup considered that high unit cost transmission spurs connecting generation and demand that are comprised of network technology not included in the current expansion factors set out in the CUSC, such as those proposed between the Scottish mainland and the Scottish islands of the Western Isles, Orkney and Shetland were not considered at the time of defining the boundary between local circuits and the MITS.
- 6.45 According to the current island connection design proposals from TOs in Scotland, some island substations would be classified as MITS under the existing definition as soon as the island link has been constructed. The Workgroup has discussed this issue and concluded that, as the principles of the TNUoS charging methodology seek to calculate a locational signal that is cost reflective, the ultimate TNUoS tariff arising out of island links forming either part of a local circuit tariff or part of the wider tariff would be the same.
- 6.46 Given the unique nature of the proposed Scottish island transmission links in terms of cost and configuration, the Workgroup will need to consider which of the following approaches to incorporating islands into the TNUoS charging methodology is most efficient:
- i) Utilise the unique characteristics of island connections to exclude island substations forming part of the MITS, such that all island transmission links would form part of a local circuit tariff and only the issues associated with this would have to be addressed;
 - ii) Utilise the unique characteristics of island connections to include island substations as part of the MITS, such that all island transmission links would form part of the wider TNUoS tariff and only the issues associated with this would have to be addressed; and
 - iii) Maintain the existing definitions of local and wider and address the issues that arise for each category.
- 6.47 The Workgroup considered that there did not appear to be any justification to altering the definition of local and wider and maintaining an outcome where some island transmission links form part of a local circuit TNUoS tariff and others the wider TNUoS tariff.
- 6.48 To aid with the Workgroup's decision on how to proceed, a table outlining the high level issues associated with island links as 'Local' or 'Wider' was created, as set out in Table 19 below.

Issues to be addressed for island connections forming part of the 'Local' or 'Wider' network

Charging Mechanism	(i) All Classed Local	(ii) All Classed Wider	(iii) Maintain Existing Definition
<i>Existing elements of the methodology</i>			
1 Expansion Factor	ACTION REQUIRED: A transmission technology specific expansion factor would have to be calculated as existing technology types (i.e. 132kV, 275kV and 400kV OHL and underground cable) insufficiently cost reflective.	ACTION REQUIRED: Same as 'All Classed Local'.	ACTION REQUIRED: Same as 'All Classed Local'.
2 Security Factor	NO ACTION REQUIRED: As local charges were created to deal with different levels of security, the existing TNUoS charging methodology implicitly deals with this issue.	ACTION REQUIRED: For the wider transmission network a Global Security Factor of 1.8 is applied. As island transmission links will have less redundancy than the onshore network (due to the cost of the assets involved) a 'work around' would need to be established <u>for each island</u> whereby the expansion factor is adjusted to account for reduced security when links form part of the wider tariff, coupled with a review of access/compensation arrangements to ensure consistency.	ACTION REQUIRED: Same as 'All Classed Wider' <u>for those islands classed as wider.</u>
3 Zoning	NO ACTION REQUIRED: Island generation TNUoS tariffs comprised of both a local circuit tariff and the wider tariff associated with the zone in which the first MITS substation is located.	NO IMMEDIATE ACTION REQUIRED: Under the existing TNUoS zoning criteria of +/- £1kW, island substations would form their own wider TNUoS zone. Zones usually updated once at the start of every TPCR period. However, re-zoning can occur for events with a significant impact on tariffs, such as the connection of an island.	NO IMMEDIATE ACTION REQUIRED: Same as 'All Classed Wider' <u>for those islands classed as wider.</u>
4 Demand Tariffs	NO ACTION REQUIRED: There are no local circuit tariffs for demand. Hence, for the purposes of calculating demand TNUoS tariffs, the islands would be treated in accordance with the existing TNUoS charging methodology. As demand on the islands reduces the need for capacity on the island transmission link, the nodal incremental costs of demand on the islands would be negative. However, due to a	NO ACTION REQUIRED: Same as 'All Classed Local'.	NO ACTION REQUIRED: Same as 'All Classed Local'.

	statutory restriction (applying in northern Scotland) on demand zoning in this area, this benefit will be averaged across all nodes forming part of demand zone 1 (i.e. the north of Scotland).		
<i>New elements introduced in CMP213</i>			
5 Sharing	<p><i>Original Proposal</i> NO ACTION REQUIRED: To date there has been no evidence of sharing on local transmission circuits and the Original proposal assumes that sharing does not occur on this part of the network.</p> <p>Nevertheless, the Workgroup has discussed the possibility of applying sharing, where demonstrable, on local transmission circuits, as set out in b) (ii), below, and in great detail under 'Sharing applies to local' in Section 4.</p>	<p><i>Original Proposal</i> ACTION REQUIRED: For simplicity the Original does not differentiate between which elements of the wider transmission network are shared and which are not. This is currently deemed a reasonable simplification when compared to the associated impact on the cost reflectivity of TNUoS tariffs.</p> <p>If <u>all islands</u> were classed as wider, the balance between simplicity and cost reflectivity is altered and should therefore be re-assessed. Consideration of zonal diversity may be required in this instance.</p>	<p><i>Original Proposal</i> ACTION REQUIRED: Same as 'All Classed Wider' for <u>those islands classed as wider</u>.</p>

Table 19 – Issues to be addressed for island connections as Local or Wider

- 6.49 Some in the Workgroup believed that the unique cost and configuration characteristics of island connections were closer to that of local, rather than wider, circuits from the perspective of incremental transmission network costs.
- 6.50 Considering the issues needing to be addressed for each course of action set out in Table 19 above table to incorporate island transmission links into the TNUoS charging methodology and the fact that any approach that is cost reflective would ultimately result in the same TNUoS tariffs for island Users, the Proposer believed that the best course of action would be to explicitly define transmission connections with the same characteristics as island links as local for TNUoS charging purposes.
- 6.51 This approach would maintain the balance between simplicity and cost reflectivity inherent within the Original to continue across the wider transmission network (i.e. nodes classed as MITS). Any sharing that was deemed to take place on island transmission circuits, and all other local circuits, could be dealt with on a case-by-case basis as set out in (b) (ii), below.
- 6.52 Other members in the Workgroup noted that this would require a change to the definition of a MITS node and that this change would have to apply across the entire transmission network.

b) ii) Apply sharing to local circuits incl. Scottish islands

- 6.53 As set out above, the Original proposal applies the principles of sharing within it to all parts of the transmission network considered to be part of the Main Interconnected Transmission system (MITS; i.e. 'wider') for TNUoS charging purposes. Implicitly this would also include island connections that are classed as 'wider'. However, the Original does not extend sharing to

local transmission circuits due to the fact that these circuits are not generally planned, in accordance with the NETS SQSS, taking sharing into account.

6.54 However, the Workgroup did consider that the principles of sharing could be extended to local transmission circuits where sharing of that capacity could be demonstrated. This discussion is recorded in the Section 4, “Summary of Workgroup Discussions on Sharing”, above.

Q10: Do you believe that the Workgroup has considered all the options and potential alternatives for island nodes classed as part of the Main Interconnected Transmission System (MITS) and those classed as local? If not, what other options would you like the Workgroup to consider and why?

c) Whether the expansion factor should be calculated in a generic manner across all Islands or whether it should be island link specific

6.55 The Original proposal would calculate a specific expansion factor for each island transmission circuit connection on the basis that the transmission technologies and hence unit costs could vary greatly across each connection. In addition, where HVDC transmission circuits are used the converter station costs are included in the expansion factor calculation, and hence circuit specific (i.e. with fixed length) would be necessary in order to maintain cost reflectivity.

6.56 The Workgroup considered that generic, rather than specific, expansion factors would generally rely on a sufficiently large population of cost data (i.e. installed transmission network components of a given technology) in order to reduce volatility and smooth out the obvious ‘winners’ and ‘losers’ that would arise from averaging just 2 or so numbers.

6.57 In addition, as one of the primary objectives of the TNUoS charging methodology is to be cost reflective in nature, the more averaging that takes place in coming up with a ‘generic’ number the less cost reflective the resultant TNUoS tariff will be. This trade off between cost reflectivity and stability occurs throughout the charging methodology.

6.58 The Workgroup put together a summary table of the pros and cons of having a generic vs. more specific expansion factor, from the perspective of some members, for island transmission connections. This is set out in Table 20, below.

Pros and Cons of Original proposal and Potential Options for Islands Expansion Factor		
Expansion Factor Potential Alternatives	Pros	Cons
Original proposal – Project specific (actual cost of the transmission project is used as basis for EF).	<ul style="list-style-type: none"> Fully cost reflective. Stable once set. Could only benefit from potential drop in price of transmission asset when EF updated for new projects 	<ul style="list-style-type: none"> No opportunity to average costs across all Users as in the wider transmission network. All costs included in the locational signal Cannot know TNUoS until very close to the time of build.
i) Generic – e.g. based on and linked to onshore 132kV underground cable or other.	<ul style="list-style-type: none"> Tariffs predictable ahead of transmission project-specific costs. 	<ul style="list-style-type: none"> Does not reflect unit costs of transmission assets used. Less cost reflective than specific (i.e. Original). Could be based on generic HVDC costs.

CMP213 Amendment
 Proposal
 07 December 2012
 Version 1.0

Page 124 of 199

ii) Generic across relevant technologies e.g. one for island AC and one generic for DC.	<ul style="list-style-type: none"> • More cost reflective than generic (i). • Tariffs more predictable than Original ahead of transmission project specific costs. 	<ul style="list-style-type: none"> • Less cost reflective than specific (i.e. Original). • Equivalent to treatment in onshore wider and local. if also differentiates across voltage types
iii) Island or Island Group specific – but not transmission project specific; i.e. actual cost of cables to the Islands aggregated or averaged over all projects and islands in the 'group'. or certain cost elements specifically removed.	<ul style="list-style-type: none"> • More cost reflective than generic (i.) and (ii) • Allows island-specific factors to be incorporated .for potential alternatives • For second and subsequent transmission cables – more chance of predicting TNUoS. 	<ul style="list-style-type: none"> • Less cost reflective than specific (i.e. Original). • Limited opportunity to average-out a very high single transmission asset cost. • Generators on first cable cannot know TNUoS until very close to the time of transmission build. • Some Islands or projects could subsidise others.

Table 20 – Pros and Cons of a generic and specific expansion factor

c) i) Across all islands regardless of technology

6.59 The Workgroup discussed the possibility of calculating a single generic expansion factor for all island transmission connections.

6.60 It was recognised by the Workgroup that the planned transmission connections to Scottish islands are to be comprised of AC and HVDC technology of different voltages and capacities. As such, the unit cost of each transmission circuit is likely to vary considerably across each connection.

6.61 The majority of the Workgroup believed that any advantages in simplicity and predictability of TNUoS tariffs by use of a generic factor was outweighed by the significant lack of cost reflectivity associated with such an approach.

6.62 Other members in the Workgroup felt that a generic factor would be appropriate on the basis that the reduction in cost reflectivity is outweighed by the benefits of predictability for generation projects still under development.

c) ii) One generic expansion factor for AC, and one for DC

6.63 The Workgroup considered that using one generic factor for AC transmission connections to the islands and a separate one for DC island links would be more cost reflective and has the potential to be slightly less stable than a single generic factor for all island transmission connections.

6.64 Given the significant unit cost differences of the proposed island transmission connections the Workgroup felt that a single generic factor may be difficult to justify in comparison to the rest of the TNUoS charging methodology. However, breaking this out into an AC and DC factor might be easier to justify against the primary (cost reflectivity, effective competition) and secondary (predictability, transparency, stability, etc.) objectives of the TNUoS charging methodology.

c) iii) Island (i.e. not connection) or Island Group specific

6.65 The Workgroup discussed a third potential option, which would calculate expansion factors on an island or island group (i.e. the three Scottish island groups of (i) the Western Isles (ii) Orkney and (iii) Shetland), rather than on a transmission circuit specific basis.

- 6.66 This particular approach would only alter TNUoS tariffs compared to the Original proposal where more than one transmission connection was established between a particular island, or group of islands, and the rest of the transmission network.
- 6.67 An additional benefit highlighted for this approach was that of enhanced predictability and stability of TNUoS tariffs.
- 6.68 One member of the Workgroup considered that one of the benefits of such an approach would be that it would allow other aspects of costs, such as savings in diesel fuel running costs, to be incorporated into the expansion factor calculation.
- 6.69 The Workgroup debated whether such costs were relevant in the context of a TNUoS charging methodology which sought to signal incremental costs of investment in transmission network capacity. The Workgroup concluded that diesel running costs were not relevant to the calculation of the (transmission network) expansion factor and that these costs were already subsidised through (i) demand TNUoS charges and (ii) the “Assistance for Areas with High Distribution Costs” scheme where SHEPD is subsidised with respect to these diesel running costs.
- 6.70 The Workgroup recognised that further detailed development would be required for such an approach (e.g. how would islands be grouped) if it were to be considered as a potential option.

d) Whether, for islands classed as ‘wider’, the global locational security factor should be used without further modification or whether any lack of redundancy should be reflected in the expansion factor calculation

- 6.71 As set out in Section 5, “Summary of Workgroup Discussions on HVDC”, above, the prevailing security factor for the wider transmission network is 1.8 and is based on an average from a number of studies conducted by NGET to account for future transmission network developments. The security factor is reviewed for each Transmission Price Control Review period and fixed for the duration.
- 6.72 The 1.8 security factor is calculated on a nodal basis and averaged using a least squares fit method to derive a transmission system wide figure, which ultimately is multiplied times the zonal locational tariff before application of the residual element in order to arrive at the TNUoS tariffs paid by generators. Currently this factor is applied to all MITS (i.e. wider) nodes on the transmission network.
- 6.73 The Workgroup discussed the fact that a straight extrapolation of the current charging methodology would lead to island nodes that are classed as wider also having TNUoS tariffs multiplied by 1.8. This was also a topic of some debate in the Project TransmiT SCR Technical Working Group, at which time it was concluded that charging island Users that had a transmission circuit with a significant proportion of no redundancy a TNUoS tariff multiplied fully by the 1.8 security factor (as applied, to mainland connections, where such redundancy did exist) would not be cost reflective.
- 6.74 Therefore, the Original proposal would adjust the length of any portion of an Island link with no redundancy in the Transport model to compensate by multiplying its actual length by $1/(\text{Locational Security Factor})$. The result would be that when the TNUoS tariff was later multiplied by the locational (MITS) security factor (currently 1.8) this would cancel out and only be reflected as a single transmission circuit in the TNUoS tariff; i.e. it would result in an island security factor of 1.0, rather than 1.8.

6.75 Discussion in the Project TransmiT SCR Technical Working Group also considered that the transmission access rights of Users on islands who were not charged the full (MITS) locational security factor (of 1.8) should be commensurate with this lower (1.0) level of redundancy, such that generation Users would not be eligible for CUSC compensation for loss of the single transmission circuit element.

6.76 The Workgroup investigated alternatives to this approach, as set out below.

d) i) Apply 1.8 in all cases

6.77 Based on the lengthy debates in the Project TransmiT SCR Technical Working Group on this option and further discussion within the CMP213 Workgroup, the Workgroup agreed that an application of the 1.8 security factor to radial transmission circuits with large sections of no redundancy would not be cost reflective and that a more appropriate security factor should apply.

6.78 Hence, if islands were to be classed as 'wider' for TNUoS charging purposes, the Workgroup agreed that the application of 1.8 in all cases would not be appropriate and no potential alternatives were being considered in this area.

d) ii) Apply a factor between 1.0 and 1.8 in all cases

6.79 The approach to local circuits onshore is that the security factor applied is either 1.0 or 1.8, depending on the number of circuits making up the connection (i.e. 1 circuit = 1.0 and 2 circuits = 1.8). With the introduction of the offshore regulatory regime and associated offshore charging arrangements, the concept of partial redundancy was introduced. These allowed security factors of between 1.0 and 1.8 to be applied based on both the number and capacity of circuits.

6.80 Whilst the Workgroup discussed the concept of partial redundancy, as applied to offshore TNUoS charging, and a number supported its application to islands on the basis that it was accurate and cost reflective. Others felt that the proposed island transmission connections would not be part of the offshore regime and that it may therefore be difficult to justify different treatment to onshore.

6.81 Nevertheless there was support for this approach in the Workgroup.

Q11: Do you believe that the Workgroup has considered all relevant options and potential alternatives for how the global locational security factor could be applied to island connections with little or no redundancy? If not, what other options would you like the Workgroup to consider and why?

e) Whether the expansion factor calculation for radial island links comprising HVDC technology should be the same as that for HVDC links that parallel the AC network

6.82 The Original proposal would calculate the expansion factor for HVDC island transmission links in the same manner as for those that parallel the AC transmission network.

6.83 As part of the Original proposal all converter station costs are included in the calculation of the HVDC transmission circuit expansion factor.

6.84 The Workgroup investigated a potential alternative to this approach, as set out below.

e) i) Yes, for all aspects of the methodology

6.85 The Workgroup considered whether this would be the case for all the aspects of the HVDC TNUoS charging as discussed in Section 5, above.

6.86 The Workgroup agreed that, due to the radial nature of the proposed island HVDC transmission links, the calculation of impedance for these links as is necessary when they parallel the AC transmission network was not required.

6.87 In terms of the calculation of the expansion factor for HVDC transmission links the Workgroup considered complete removal and partial removal of the converter station costs from the expansion factor calculation as well as treating HVDC as onshore in Section 5.

6.88 The justification for complete removal of the converter station costs was on the basis that these elements constitute a fixed cost and hence somehow have a negative effect on cost reflectivity. Whilst this was disputed by some of the Workgroup, this justification would also apply to island HVDC links and therefore for this potential alternative the calculation should remain the same.

6.89 The interaction and potential read across to offshore transmission circuits where HVDC converter costs are included in the expansion factor calculation was noted by the Workgroup. Some believed that this inconsistency was not acceptable and that converter station costs would also have to be removed from the offshore TNUoS calculation in this case.

6.90 Some in the Workgroup also noted that, unlike offshore transmission circuits, the island links did include demand Users and, furthermore, islands are not considered to be offshore as they are part of the (onshore) TO's Transmission Licence area (and are not part of an OFTO's Transmission Licence area). These members believed that these reasons alone were sufficient to warrant a different treatment of HVDC converter station costs when calculating TNUoS between islands and offshore.

6.91 As set out above, in Section 5, the Workgroup also identified 3 possible alternatives for the removal of a portion of the converter station costs from the expansion factor calculation:

- i) Remove a percentage of, the costs based on those elements of the converter station that are similar to elements of the (onshore) AC transmission network that are currently not included in the locational signal (such as substation equipment); and/or
- ii) Remove a portion of the costs based on the similarity between the power flow redirecting capability of HVDC converter stations and that of Quadrature Boosters (QBs) that are currently not included in the locational signal
- iii) Remove a portion of costs based on the benefit to the transmission network arising from the operation of HVDC technology. This is particularly relevant to voltage source converters (VSC), which will be used for island links, which can be beneficial to system performance and can provide overall a more effective solution than traditional HVAC.

6.92 For the first option devised for incorporating HVDC circuits that parallel the AC network, the Workgroup noted that this justification would also apply for radial island HVDC transmission circuits. However, as with the potential alternative removing all converter station costs from the expansion factor

calculation, some in the Workgroup believed that the logic for applying this option could also be read across to the existing TNUoS charging methodology with respect to offshore (OFTO) transmission.

6.93 Nevertheless, some of the Workgroup believe that offshore should not be used as a precedent to determine the charging structure for island links. Whilst there are some similarities there are also important commercial and technical differences between the two types of connection:

- Specific commercial arrangements have been put in place to help facilitate the development of offshore wind technology, including levels of policy support and the OFTO arrangements in respect of connections. Offshore connections tend to be radial links to individual generator stations.
- Island links will be part of the onshore TO's Transmission Licence area and are not part of an OFTO's Transmission Licence. The island links will connect multiple generator stations covering different technologies. The island links will also serve to benefit the islands themselves improving the quality and security of supplies in these remote areas, providing capacity to facilitate demand side growth, and relieving reliance on local carbon standby generation. The links to certain islands will also relieve congestion on other sections of the transmission network.

6.94 The second option devised for incorporating HVDC circuits that parallel the AC network for removal of a portion of the converter station costs is associated with the power flow re-directing capability of HVDC transmission links and their similarity to Quadrature Boosters (QBs) in this respect. As such, some in the Workgroup believed that the radial nature of the island HVDC transmission links precluded this option from applying to the expansion factor calculation for island links comprised of HVDC transmission technology.

6.95 The third option is to recognise the benefits arising from the VSC converter technology, which is based on transistor valves which are much more controllable than conventional thyristor based current source converters (CSC). In the correct circumstances, installation of HVDC VSCs links can be beneficial to overall transmission system performance.

6.96 VSC technology can rapidly control both active and reactive power independently of one another. Reactive power can also be controlled at each terminal independent of the DC transmission voltage. VSC can also permit black start where the converter station can be used to bring parts of the transmission network back online following outages. The dynamic support of the AC voltage at each converter terminal improves the voltage stability and can increase the transfer capability of the connected AC transmission systems.

6.97 In the case of island transmission links, HVDC based on VSC technology can provide a better solution than traditional HVAC, taking into account technical capability, cost and environmental impact.

6.98 Further work is being undertaken by some Workgroup members to reflect how this could be translated into TNUoS, either through a new potential alternative, or through current alternatives to remove all, or a portion of, the converter station costs from the expansion factor calculation.

6.99 Hence the Workgroup agreed that the aspects of the modification proposal for incorporating HVDC circuits that parallel the AC network should also apply to island transmission connections comprised of HVDC technology and that some of the options discussed for calculation of the expansion factor

could also apply to island connections (although these could be limited due to their radial nature). Some Workgroup members believed all options could apply including removal of all, or all options for removal of a portion of, the converter costs.

Q12: Do you believe that the Workgroup has sufficiently considered the options and potential alternatives for how the expansion factor (i.e. unit cost) for sub-sea cables and/or radial HVDC circuits forming part of an island connection should be calculated for inclusion in the TNUoS charging calculation? If not, please provide suggestions with an associated justification.

f) Whether an anticipatory application of the MITS definition to islands is appropriate and how this could be done.

6.100 Currently a node on the transmission network is classed as MITS for the charging year in question based solely on the network configuration in place at the time TNUoS charges are set.

6.101 As set out in paragraph 6.42, all Workgroup members appreciated the fact that a cost reflective island TNUoS tariff should be similar whether the island transmission node is classed as local or wider for charging purposes, but also noted the interaction with the sharing aspect of the Original proposal where the application of a sharing factor may differ between local and wider.

6.102 The Original proposal would utilise the existing local/wider definition and only apply one treatment or another when the relevant criteria are met and not in advance as would be the case if applied in an anticipatory fashion.

6.103 If an anticipatory approach were to be used the Workgroup understood this to mean, for the purposes of their deliberations, that the existing definition of a MITS substation would be applied (in advance of it actually occurring) to an island transmission link (for the purposes of TNUoS charging) where it was reasonably 'anticipated', by the SO, that such a MITS substation would exist at some point in the future. The timeframe as to how far in advance the SO should consider when looking to 'anticipate' the establishment of the MITS substation onto a particular island was debated by the Workgroup.

6.104 There were was a cross section of views on whether an anticipatory application of the MITS definition was appropriate and, if so, how this could be achieved.

6.105 The Workgroup agreed that the relevance of an anticipatory application of the MITS substation definition to the islands is material because the sharing factor under the Original proposal is applied to island nodes classed as MITS.

6.106 The Workgroup had concerns in this area, which are set out in Section 4 above.

6.107 This was considered in the potential alternatives, set out below.

6.108 The Workgroup noted that the potential alternatives in this area interacted heavily with those discussed under sharing where application of sharing to local transmission circuits, including on an anticipatory basis, was considered.

f) i) Yes, just for islands

6.109As set out in paragraph 6.42, all Workgroup members appreciated the fact that a cost reflective island TNUoS tariff should be similar whether the island transmission node was classed as local or wider for charging purposes, but also noted the interaction with the sharing aspect of the Original proposal where the application of a sharing factor may differ between local and wider.

6.110Some members of the Workgroup, therefore did not see any justification for an anticipatory application of the MITS substation definition to anywhere on the transmission network; be that onshore, on the islands or offshore. Nevertheless, others in the Workgroup believed that an anticipatory application of the MITS substation definition may be justified in some cases.

6.111Nevertheless, some in the Workgroup considered that, should such an anticipatory application only apply to island transmission connections that this would be discriminatory in nature and would need to be applied across the transmission network as a result.

f) ii) Yes, for all areas

6.112Whilst some in the Workgroup did not see any justification for an anticipatory application of the MITS substation definition to any part on the transmission network, others did believe that it may be justified.

6.113As a result, these members of the Workgroup are developing an option for island charging that would include this approach.

Q13: Do you consider that the Workgroup has adequately considered all relevant options and alternatives for an anticipatory application of the MITS definition to island nodes? If not, please provide suggestions with an associated justification.

Q14: Do you consider that the Workgroup has adequately set out and considered all relevant options and potential alternatives on the “island connection” aspect of this modification proposal? If not, what other options would you like the Workgroup to consider and why?

Q15: What are your overall views on how best to include island connections comprising sub-sea cable and/or HVDC technology, such as those proposed in Scotland, into the TNUoS charging methodology?

7 Impacts

Impact on the CUSC

- 7.1 CMP213 requires amendments to the following parts of the CUSC:
- i. Section 14 – Charging Methodologies
 - ii. Section 11 – Interpretation and Definitions
- 7.2 CMP213 represents a significant incremental change to the TNUoS charging methodology. As such, substantial redrafting of Section 14 of the CUSC relating to Charging Methodologies will be required. In particular those sections relating to TNUoS and associated examples (14.14 – 14.28) will need to be overhauled. In addition, as noted under paragraphs 4.32-4.34, there is likely to be consequential changes required to the CUSC if CMP213 is implemented, with respect to STTEC and LDTEC, given that both are linked to TNUoS charges (which would be altered, if CMP213 was implemented).
- 7.3 This substantial change is made more complex due to the fact that CMP213 focuses on three different areas of change to Section 14. Due to the large volume and interdependency of changes in these areas the proposed legal text will be drafted once a firmer picture of the suite of proposed changes is established. The summary below demonstrates the broad changes required for each topic area:

Sharing

- 7.4 Substantial updates would be required to sections 14.14-14.28 to incorporate the move to a sharing approach. For example, should the Original proposal be taken forward, the approach, in the charging methodology, around the use of the dual background (Peak Security and Year Round elements) would need to be demonstrated as well as calculation of the generator's Annual Load Factor, inclusion of a generation plant type scalar for the Peak Security element and additional tariff assumptions would need to be included.

HVDC

- 7.5 A methodology is being developed for taking account of HVDC transmission circuits that parallel the AC network within the calculations of the Transport model. For the Original proposal this would be mean treating HVDC circuits as a pseudo-AC transmission circuit. Therefore a new section would be required to detail the methodology for determining the 'impedance' of these HVDC transmission circuits. In addition, new expansion factors would need to be added.

Islands

- 7.6 A methodology is being developed for calculating cost reflective TNUoS charges for transmission spurs connecting generation and demand and comprised of network technology not included in the expansion factors set out in clause 14.15.47 and 14.15.49 of the CUSC (i.e. sub-sea cables); such as those which may be established between the Scottish mainland and the Scottish islands of the Western Isles, Orkney and Shetland. Whilst many aspects of island connections are covered under the other two aspects of CMP213, there will be additional items that are island specific which will need to be reflected into the charging methodology.

Impact on Greenhouse Gas Emissions

- 7.7 As some of the options being considered under CMP213 will affect decisions about where to open new generation plant and where to close existing plant, the Panel agreed that CMP213 will have a material impact on Greenhouse Gas emissions and has tasked the Workgroup with considering this.

Impact on Core Industry Documents

- 7.8 Neither the Proposer nor the Workgroup have identified any impacts on Core Industry Documents at this stage, although the Workgroup noted that some changes to the STC might be possible in the future.

Impact on other Industry Documents

- 7.9 Neither the Proposer nor the Workgroup have identified any impacts on other Industry Documents at this stage.

8 Proposed Implementation

- 8.1 The implementation date of CUSC Modification Proposals is ultimately decided by the Authority when approving a CUSC change. However, the Workgroup and the CUSC Panel have a role in providing advice and evidence to Ofgem on potential implementation dates.
- 8.2 The Workgroup also considered the need for any transition arrangements associated with CMP213. These would normally recognise that any significant change to commercial arrangements should be implemented in an efficient manner that allows industry parties time to efficiently adapt to such changes.
- 8.3 Transition arrangements are often also required where changes would lead to significant changes, for example, to of IS systems. Some examples are: (i) to allow parties generation Users to adjust their transmission access rights without with no penalty; (ii) recognise that certain categories of User may need specific treatment (e.g. LCPD generation plant), (iii), to allow the development of supporting IS systems (e.g. implementation with temporary 'work-arounds' on existing systems); and (iv) to allow industry contracting arrangements (e.g. PPAs) to be amended.
- 8.4 The Workgroup discussed the various statements by Ofgem on the need to implement any Project Transmit change to TNUoS charging in a timely, but robust manner. For example, the Authority Direction issued to National Grid and in particular the comments in the covering letter²⁴, of 25th May 2012, that:-
- "Industry will decide the manner and timing of the industry process, but we continue to urge industry to expedite this process and submit a final CUSC modification proposal report, with all the requisite justification and evidence, in a timely manner to ensure benefits are realised as quickly as possible."*
- 8.5 In respect of the issue that changes should be managed efficiently the Workgroup noted that industry has been aware of the possibility of a substantial change to the basis on which TNUoS tariffs are calculated since at least September 2010, when Ofgem initiated its Project Transmit SCR work. However, it also recognised that there was a significant range of potential options and so there still remains a considerable amount of uncertainty.
- 8.6 The Workgroup will finalise its conclusion on the lead time for the implementation of CMP213 Original and any WACM(s) when these are fully developed after this consultation. . However, at this stage the Workgroup welcomes views and evidence from the industry which could assist in any recommendations conclusions the Workgroup might reach on for either the potential implementation date or any transitional arrangements associated with CMP213 (Original and any WACM(s)).

Initial thoughts on implementation dates

- 8.7 At this stage the Workgroup believes that given the likely workload after this Workgroup consultation (which includes (i) ; the requirement to for development the for legal text for all the options, including; for the working the Original and any WACM(s); (ii) for the Work group to model the impact of various potential options on the market and sustainability; (iii) the need to carry out a CUSC Code Administrator consultation; and (iv) also for Ofgem

²⁴<http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/Final%20SCR%20cover%20letter%2025%20May.pdf>

to carry out a Regulatory Impact Assessment (RIA,) that implementation (of CMP213) in April 2013 is not possible.

- 8.8 On this understanding the Workgroup have identified four suggestions for possible implementation dates and one option for transition associated with CMP213 (Original and any WACM(s)). The need for transition is directly related to the implementation date.
- 8.9 Possible target implementation dates:
- 1) 'mid year' during the 2013/2014 TNUoS Charging Year; or
 - 2) 1st April 2014; or
 - 3) 'mid year' during the 2014/2015 TNUoS Charging Year; or
 - 4) 1st April 2015.

Possible transition option

- 8.10 Where the CMP213 implementation date does not allow generation Users sufficient time to adjust their transmission access (TEC) holdings in response to the CMP213 change then a shorter than (i) one year and five Working Days notice period for existing generation plant); and (ii) three years and five days notice period for (new generation plant (as per the recent changes (with CMP192) to User Commitment liabilities) notice period should be considered in the determination of User Commitment liabilities (recently changed with CMP192).

Impact on Users

- 8.11 In terms of the impact on Users the CMP213 Workgroup noted that any change to TNUoS tariffs should only directly impact on the allocation of TNUoS between individual generators. However, some members noted that there could be a minor impact on demand as generation reacts to the changed signals, either in the strength of the locational signals or changes to transmission investments and therefore the absolute level of transmission costs.

Timeline and resourcing issues

- 8.12 Having reviewed the timeline the Workgroup considers that the earliest the Authority could, practically, make a decision on CMP213 Original and any WACM(s) is approximately September 2013. This leaves just sufficient time to allow National Grid to produce draft 'indicative' TNUoS tariffs in December (2013), with the final tariffs being produced by the end of January (2014).
- 8.13 Workgroup members noted that there could be a strong argument, in this particular case, for the Authority to authorise National Grid (if necessary) to undertake preparatory work on the final generation TNUoS tariffs prior to an Authority decision.
- 8.14 If this 'pre-approval' work were to be undertaken then it would feasibly be possible for National Grid to produce final TNUoS tariffs (as they did with the 2010 'mid year' TNUoS tariff change) much earlier than January 2014 (assuming an Authority decision in September 2013).
- 8.15 It was also noted by the Workgroup that as part of the Final Modification Report submitted by the CUSC Panel to the Authority (anticipated to be in spring 2013) the analysis presented to tariff would be include TNUoS tariffs and therefore Users would have a relatively up-to-date forecast of TNUoS charges if CMP213 (Original and any WACM(s)) was approved. National Grid is currently reviewing the full impact on its IS systems of the changes

CMP213 Amendment
Proposal

07 December 2012

Version 1.0

Page 135 of 199

associated with CMP213, although this cannot be fully established until all any WACM(s) are finalised. National Grid also noted that parallel production of TNUoS tariffs under the different options being considered would be resource intensive and given that this resource is specialised in nature. Therefore it is, therefore, unlikely that TNUoS tariffs could, practically, be developed for all the options currently being considered by the Workgroup.

Implementation options

Option (1) mid year 2013/14

- 8.16 In respect of option (1) ('mid year') the CMP213 Workgroup was mindful that this did not necessarily mean exactly midway or halfway through the 2013/14 Charging Year; i.e. 1st October 2013 (or 1st October 2014 with option (43)); rather it could occur at any point during the Charging Year. There has already been one previous example of a 'mid year' TNUoS tariff change and this had actually been put into effect on 1st December (2010)²⁵.
- 8.17 The Workgroup noted that the Project Transmit Technical Working Group²⁶ had considered, and discounted, a 'mid year' TNUoS tariff change, although this had included a 'postage stamp' option, which is specifically excluded from CMP213. The CMP213 Workgroup is minded to agree that a 'mid year' change was not desirable for a number of reasons, but principally it creates tariff volatility. Particularly in respect of option (1) this volatility would not be predicted so was, in the view of the majority of Workgroup members, likely to create windfall gains and losses. Counter to this, some Workgroup members considered that the timely and expeditious introduction ensures that a fairer more cost reflective allocation is achieved at the earliest practical opportunity and therefore a 'mid year' TNUoS tariff change should be considered.

Option (2) April 2014

- 8.18 The CMP213 Workgroup noted that the Project Transmit Technical Working Group²⁷ favoured an implementation from 1st April 2014. Some CMP213 Workgroup members considered that given the potentially significant material impact on some Users that it would not be beneficial to implement from the 1st April 2014.
- 8.19 The main concern of those members is around the ability of supply Users to take account of potential generation TNUoS changes efficiently during the demand contracting rounds prior to 1st April 2014. It was noted that the draft generation TNUoS tariff would be created as part of the CMP213 Final Modification Report submitted to the Authority as part of the assessment process in the spring of 2013 and this would limit the potential volatility on Users. In addition, as noted in paragraph 8.11, some Workgroup members believed there would be a "minor impact on demand as generation reacts to the changed signals" arising from the implementation of CMP213.
- 8.20 The initial view of the majority of the Workgroup is that option (2), implementation on 1st April 2014, represents a reasonable balance between predictability and stability whilst acting in an expeditious manner as requested by Ofgem.

²⁵ <http://www.nationalgrid.com/NR/rdonlyres/11407548-92EE-485B-9A1C-5DBFAAD17F42/43351/NoticeofFINALtariffs.pdf>

²⁶ <http://www.ofgem.gov.uk/Pages/MoreInformation.aspx?docid=166&refer=Networks/Trans/PT/WF>

²⁷ <http://www.ofgem.gov.uk/Pages/MoreInformation.aspx?docid=166&refer=Networks/Trans/PT/WF>

Option (3) mid year 2104/15

- 8.21 This option would be the same as option (1) except it would occur sometime during the following Charging Year; i.e. from 1st April 2014 to 31st March 2015.
- 8.22 Some members of the CMP213 Workgroup felt, in light of the Workgroup deliberations noted under option (1) above, that it would be practical to implement CMP213, in terms of a generation TNUoS tariffs, ‘mid year’ during Charging Year 2014/15.
- 8.23 The majority of the Workgroup considered that whilst the change would have been predicted, it could not reasonably be taken into account of in forward demand contracting structures and so any ‘mid year’ TNUoS tariff change should be avoided. Other members of the Workgroup noted, as per paragraph 8.19, that the draft generation TNUoS tariff would be created as part of the CMP213 Final Modification Report submitted to the Authority in the spring of 2013 and this would limit the potential volatility on Users and, furthermore, some Workgroup members believed that there would be a minor impact on demand as generation reacts to the changed signals arising from the implementation of CMP213.

Option (4) April 2015

- 8.24 Some members of the CMP213 Workgroup having considered the options and being mindful of the timeline, believed that the implementation of CMP213 (if approved by the Authority) should be made from 1st April 2015. This would allow Users to fully include the effect, of CMP213, in wholesale prices and so promote confidence in the overall regulatory regime.
- 8.25 However, the majority of Workgroup members believed; in light of the Authority’s Project Transmit SCR Direction letter of 25th May 2012, about acting in a “*timely manner*” and “*to ensure benefits are realised as quickly as possible*”; that it would be inappropriate to unduly delay the benefits associated with CMP213 (if approved by the Authority) by postponing the implementation of CMP213 until 1st April 2015.

Q16: The CMP213 Workgroup would welcome your views on which, if any, of the four implementation options set out in Section 8 should be adopted.

Transition

- 8.26 The Workgroup noted that during the normal course of events a User with generation assets has to provide notice (to reduce their TEC) to the System Operator (NGET) at least one year and five Working Days prior to the start of the Charging Year in question in order to avoid paying those TNUoS charges. However, in giving that notice the User is unaware of what the actual TNUoS tariffs will be in that Charging Years (starting 1st April) as these are not published until some two months before (at the end of January).
- 8.27 For example, with option (2) a generator would, if it wished to avoid paying TNUoS from 1st April 2014, need to notify National Grid of its TEC reduction (to zero MW if it wished to avoid the charge entirely) at least five Working Days prior to the 31st March 2013.
- 8.28 The Workgroup considered that a practical way to deal with this issue of the generator notice period would be to allow a shorter than one year and five Working Days notice period as a ‘one off’ CMP213 transitional approach.

- 8.29 However, it was also noted that for new plant the lead time for User Commitment was up to 4 years. If exiting generation Users were able to avoid User Commitment it was not clear why new generation Users, whose projects may as a result of CMP213 become marginal or even no longer viable, should not be able to benefit from similar transitional arrangements; i.e. provide less than the current three years and five Working Days notice.
- 8.30 It was also noted that Project TransmiT and CMP213 had been conducted in a transparent manner and so both existing and new Users were able to consider the potential risks that this change (to the TNUoS charging methodology) might (or might not) be approved by the Authority. There was also a concern that generation projects which for reasons other than CMP213 were considering terminating or closing would be able to inappropriately use such a transitional arrangement, thus undermining User Commitment and potentially exposing end consumers to additional costs.

Initial conclusion on Transition of CMP213

- 8.31 In light of the above deliberations, the Workgroup was unable to come to an initial consensus on (a) whether there should be a transitional approach to the implementation of CMP213 and (b) how many Working Days Notice Period should be allowed what, if any, transitional arrangements should apply, following an Authority decision, for a generator to notify National Grid of any change to their TEC levels.

Q17: The CMP213 Workgroup would welcome your views on (a) whether or not there should be a transitional approach to the implementation of CMP213 and, if so, how many working days notice period should be allowed as well as (b) what those transitional arrangements should be.

Assessment against Applicable CUSC Objectives

- 9.1 The Proposer considers that CMP213 would better facilitate the following Applicable CUSC objectives for the reasons set out in the CMP213 proposal shown in Annex 2.
- 9.2 For reference the Applicable CUSC Objectives are:
- (a) that compliance with the use of system charging methodology facilitates effective competition in the generation and supply of electricity and (so far as is consistent therewith) facilitates competition in the sale, distribution and purchase of electricity;
 - (b) that compliance with the use of system charging methodology results in charges which reflect, as far as is reasonably practicable, the costs (excluding any payments between transmission licensees which are made under and in accordance with the STC) incurred by transmission licensees in their transmission businesses and which are compatible with standard condition C26 (Requirements of a connect and manage connection);
 - (c) that, so far as is consistent with sub-paragraphs (a) and (b), the use of system charging methodology, as far as is reasonably practicable, properly takes account of the developments in transmission licensees' transmission businesses.

10 How to Respond

- 10.1 The Workgroup is seeking the views of CUSC Parties and other interested parties in relation to the issues noted in this document and specifically in response to the questions highlighted in the report and summarised below:

Sharing

- Q1:** Do you believe that the Workgroup has fully considered the range of options for addressing how charging structures should be applied geographically to areas dominated by one type of generation, including on local circuits? If not, what other options would you like the Workgroup to consider and why?
- Q2:** Do you believe that the Workgroup has sufficiently reviewed all the necessary options on how a sharing factor (i.e. ALF) could be calculated. Are there any areas that you think may need further development? If so, please specify along with an associated justification.
- Q3:** On the subject of whether intermittent generation should be exposed to a Peak Security element of the tariff, do you have any views in addition to those discussed by the Workgroup?
- Q4:** Do you consider that the Workgroup has adequately set out and considered all relevant options and potential alternatives on the *sharing* aspect of this modification proposal? If not, what other options would you like the Workgroup to consider and why?
- Q5:** What are your overall views on how best to reflect the differential impact of generators with distinct characteristics on incremental network costs into the TNUoS charging methodology?

HVDC Circuits

- Q6:** Do you believe that the Workgroup has considered all relevant options and potential alternatives for how the expansion factor (i.e. unit cost) for an HVDC circuit paralleling the AC network should be calculated for inclusion in the TNUoS charging calculation? If not, please provide suggestions with an associated justification.
- Q7:** Do you believe that the Workgroup has satisfactorily considered all the options and potential alternatives for how an HVDC circuit paralleling the AC network should be modelled in the DC load flow element of the TNUoS charging calculation? If not, what other options would you like the Workgroup to consider and why?
- Q8:** Do you consider that the Workgroup has adequately set out and considered all relevant options and potential alternatives on the *HVDC circuit* aspect of this modification proposal? If not, what other options would you like the Workgroup to consider and why?
- Q9:** What are your overall views on how best to incorporate HVDC circuits that parallel the AC network into the TNUoS charging methodology?

Island Connections

- Q10:** Do you believe that the Workgroup has considered all the options and potential alternatives for island nodes classed as part of the Main Interconnected Transmission System (MITS) and those classed as local? If not, what other options would you like the Workgroup to consider and why?

- Q11:** Do you believe that the Workgroup has considered all relevant options and potential alternatives for how the global locational security factor could be applied to island connections with little or no redundancy? If not, what other options would you like the Workgroup to consider and why?
- Q12:** Do you believe that the Workgroup has sufficiently considered the options and potential alternatives for how the expansion factor (i.e. unit cost) for sub-sea cables and/or radial HVDC circuits forming part of an island connection should be calculated for inclusion in the TNUoS charging calculation? If not, please provide suggestions with an associated justification.
- Q13:** Do you consider that the Workgroup has adequately considered all relevant options and alternatives for an anticipatory application of the MITS definition to island nodes? If not, please provide suggestions with an associated justification.
- Q14:** Do you consider that the Workgroup has adequately set out and considered all relevant options and potential alternatives on the “island connection” aspect of this modification proposal? If not, what other options would you like the Workgroup to consider and why?
- Q15:** What are your overall views on how best to include island connections comprising sub-sea cable and/or HVDC technology, such as those proposed in Scotland, into the TNUoS charging methodology?

Implementation and Transition

- Q16:** The CMP213 Workgroup would welcome your views on which, if any, of the four implementation options set out in Section 8 should be adopted.
- Q17:** The CMP213 Workgroup would welcome your views on (a) whether or not there should be a transitional approach to the implementation of CMP213 and, if so, how many working days notice period should be allowed as well as (b) what those transitional arrangements should be.

Governance

- Q18:** Do you wish to raise a Workgroup Consultation Alternative Request for the Workgroup to consider?

10.2 If you wish to make a representation on this Workgroup Consultation, please use the response proforma which can be found under CMP213 at the following link:

<http://www.nationalgrid.com/uk/Electricity/Codes/systemcode/amendments/currentamendmentproposals/>

10.3 In accordance with Section 8 of the CUSC, CUSC Parties, BSC Parties and the National Consumer Council may also raise a Workgroup Consultation Alternative Request. If you wish to raise such a request, please use the relevant form available at the web link below:

http://www.nationalgrid.com/uk/Electricity/Codes/systemcode/amendments/forms_guidance/

10.4 Views are invited upon the proposals outlined in this report, which should be received by **15 January 2013**.

10.5 Your formal responses may be emailed to: cusc.team@nationalgrid.com

CMP213 Amendment Proposal
07 December 2012
Version 1.0
Page 141 of 199

10.6 If you wish to submit a confidential response please note the following:

Information provided in response to this consultation will be published on National Grid's website unless the response is clearly marked "Private & Confidential", we will contact you to establish the extent of the confidentiality. A response marked "Private and Confidential" will be disclosed to the Authority in full but, unless agreed otherwise, will not be shared with the CUSC Modifications Panel or the industry and may therefore not influence the debate to the same extent as a non confidential response. Please note an automatic confidentiality disclaimer generated by your IT System will not in itself, mean that your response is treated as if it had been marked "Private and Confidential".

Workgroup Terms of Reference and Membership TERMS OF REFERENCE FOR CMP213 WORKGROUP

Responsibilities

1. The Workgroup is responsible for assisting the CUSC Modifications Panel in the evaluation of CUSC Modification Proposal CMP213 "Project TransmiT TNUoS Developments", tabled by National Grid Electricity Transmission plc at the CUSC Modifications Panel meeting on 29 June 2012.
2. The proposal must be evaluated to consider whether it better facilitates achievement of the Applicable CUSC Objectives. These can be summarised as follows:

Use of System Charging Methodology

- (a) that compliance with the use of system charging methodology facilitates effective competition in the generation and supply of electricity and (so far as is consistent therewith) facilitates competition in the sale, distribution and purchase of electricity;
 - (b) that compliance with the use of system charging methodology results in charges which reflect, as far as is reasonably practicable, the costs (excluding any payments between transmission licensees which are made under and in accordance with the STC) incurred by transmission licensees in their transmission businesses and which are compatible with standard condition C26 (Requirements of a connect and manage connection);
 - (c) that, so far as is consistent with sub-paragraphs (a) and (b), the use of system charging methodology, as far as is reasonably practicable, properly takes account of the developments in transmission licensees' transmission businesses.
3. It should be noted that additional provisions apply where it is proposed to modify the CUSC Modification provisions, and generally reference should be made to the Transmission Licence for the full definition of the term.

Scope of work

4. The Workgroup must consider the issues raised by the Modification Proposal and consider if the proposal identified better facilitates achievement of the Applicable CUSC Objectives.
5. In addition to the overriding requirement of paragraph 4, the Workgroup shall consider and report on the following specific issues:

Network Capacity Sharing

- a) whether intermittent generation should contribute to the peak element of the tariff
- b) whether load factor is an appropriate measure of the level of sharing
- c) whether the proposed method for calculating load factor is an appropriate measure of forward looking charges (subject to item b)
- d) whether to use maximum line flow when attributing circuit MWkm to the Peak and Year Round elements or an alternative approach
- e) whether shortening circuit MWkm may be an alternative to the use of load factor in reflecting sharing
- f) compare modelled charging outputs to real network investment costs

HVDC

- g) how often the parameters associated with the proposed approach should be updated (e.g. annually, every 4 years, every 8 years)

Island Links

- h) ensure that the charging solution is commensurate with access rights
- i) consider appropriate approach for islands that form part of integrated offshore networks
- j) review the application of the expansion factor in the tariff calculation

General

- k) consider and undertake appropriate economic analysis including the impact on current and future consumers on a national and regional basis
- l) consider and undertake appropriate environmental analysis and review illustrative legal text including an assessment of likely impact on electricity generation carbon intensity

- 6. The Workgroup is responsible for the formulation and evaluation of any Workgroup Alternative CUSC Modifications (WACMs) arising from Group discussions which would, as compared with the Modification Proposal or the current version of the CUSC, better facilitate achieving the Applicable CUSC Objectives in relation to the issue or defect identified.
- 7. The Workgroup should become conversant with the definition of Workgroup Alternative CUSC Modification which appears in Section 11 (Interpretation and Definitions) of the CUSC. The definition entitles the Group and/or an individual member of the Workgroup to put forward a WACM if the member(s) genuinely believes the WACM would better facilitate the achievement of the Applicable CUSC Objectives, as compared with the Modification Proposal or the current version of the CUSC. The extent of the support for the Modification Proposal or any WACM arising from the Workgroup's discussions should be clearly described in the final Workgroup Report to the CUSC Modifications Panel.
- 8. Workgroup members should be mindful of efficiency and propose the fewest number of WACMs possible.
- 9. All proposed WACMs should include the Proposer(s)'s details within the final Workgroup report, for the avoidance of doubt this includes WACMs which are proposed by the entire Workgroup or subset of members.

10. There is an obligation on the Workgroup to undertake a period of Consultation in accordance with CUSC 8.20. The Workgroup Consultation period shall be for a period of 4 weeks as determined by the Modifications Panel.
11. Following the Consultation period the Workgroup is required to consider all responses including any WG Consultation Alternative Requests. In undertaking an assessment of any WG Consultation Alternative Request, the Workgroup should consider whether it better facilitates the Applicable CUSC Objectives than the current version of the CUSC.

As appropriate, the Workgroup will be required to undertake any further analysis and update the original Modification Proposal and/or WACMs. All responses including any WG Consultation Alternative Requests shall be included within the final report including a summary of the Workgroup's deliberations and conclusions. The report should make it clear where and why the Workgroup chairman has exercised his right under the CUSC to progress a WG Consultation Alternative Request or a WACM against the majority views of Workgroup members. It should also be explicitly stated where, under these circumstances, the Workgroup chairman is employed by the same organisation who submitted the WG Consultation Alternative Request.

12. The Workgroup is to submit its final report to the Modifications Panel Secretary on 6 December 2012 for circulation to Panel Members. The final report conclusions will be presented to the CUSC Modifications Panel meeting on 14 December 2012.

Membership

13. The Workgroup has the following members:

Role	Name	Representing
Chairman	Patrick Hynes	Code Administrator
National Grid Representative*	Ivo Spreeuwenberg	National Grid
Industry Representatives*	James Anderson	ScottishPower
	Garth Graham	SSE
	Simon Lord	First Hydro
	Stuart Cotten	Drax Power
	Paul Jones	E.ON UK
	Frank Prashad	RWE
	Michael Dodd	ESBI
	Stefan Leedham	EDF
	Dennis Gowland	Fairwind Orkney Ltd
	Ricky Hill	Centrica
	Helen Snodin	Xero Energy
	Maf Smith	RenewableUK
	Patrick Smart	RES
	Nick Fedorkiw	Mainstream Renewable Power
	Peter Waghorn	Phillips 66 / Immingham CHP LLP
	Ebba John	DONG Energy

Role	Name	Representing
Authority Representatives	Anthony Mungall	Ofgem
Technical secretary	Jackeline Crespo-Sandoval	Code Administrator
Observers		

NB: A Workgroup must comprise at least 5 members (who may be Panel Members). The roles identified with an asterisk in the table above contribute toward the required quorum, determined in accordance with paragraph 14 below.

14. The chairman of the Workgroup and the Modifications Panel Chairman must agree a number that will be quorum for each Workgroup meeting. The agreed figure for CMP213 is that at least 5 Workgroup members must participate in a meeting for quorum to be met.
15. A vote is to take place by all eligible Workgroup members on the Modification Proposal and each WACM. The vote shall be decided by simple majority of those present at the meeting at which the vote takes place (whether in person or by teleconference). The Workgroup chairman shall not have a vote, casting or otherwise. There may be up to three rounds of voting, as follows:
 - Vote 1: whether each proposal better facilitates the Applicable CUSC Objectives;
 - Vote 2: where one or more WACMs exist, whether each WACM better facilitates the Applicable CUSC Objectives than the original Modification Proposal;
 - Vote 3: which option is considered to BEST facilitate achievement of the Applicable CUSC Objectives. For the avoidance of doubt, this vote should include the existing CUSC baseline as an option.

The results from the vote and the reasons for such voting shall be recorded in the Workgroup report in as much detail as practicable.
16. It is expected that Workgroup members would only abstain from voting under limited circumstances, for example where a member feels that a proposal has been insufficiently developed. Where a member has such concerns, they should raise these with the Workgroup chairman at the earliest possible opportunity and certainly before the Workgroup vote takes place. Where abstention occurs, the reason should be recorded in the Workgroup report.
17. Workgroup members or their appointed alternate are required to attend a minimum of 50% of the Workgroup meetings to be eligible to participate in the Workgroup vote.
18. The Technical Secretary shall keep an Attendance Record for the Workgroup meetings and circulate the Attendance Record with the Action Notes after each meeting. This will be attached to the final Workgroup report.
19. The Workgroup membership can be amended from time to time by the CUSC Modifications Panel.

Appendix: Indicative Workgroup Timetable

The following timetable is indicative for the CMP213 Workgroup.

w/c 2 July	Send out request for WG nominations
10 July	First Workgroup meeting
July – September	Fortnightly Workgroup meetings
8 October	Issue draft Workgroup Consultation for Workgroup comment (5 working days)
15 October	Deadline for comments on draft Workgroup Consultation
17 October	Publish Workgroup consultation (for 4 weeks)
14 November	Deadline for responses to Workgroup consultation
w/c 19 November	Post-consultation Workgroup meeting
27 November	Circulate draft Workgroup Report
4 December	Deadline for comment on Workgroup report
6 December	Submit final Workgroup report to Panel Secretary
14 December	Present Workgroup report to CUSC Modifications Panel

CUSC Modification Proposal Form (for Charging Methodology proposals)	CMP213
Title of the CUSC Modification Proposal: <i>(mandatory by proposer)</i> Project TransmiT TNUoS Developments	
Submission Date <i>(mandatory by Proposer)</i> 20/06/2012	
Description of the CUSC Modification Proposal: <i>(mandatory by proposer)</i> This modification proposal is submitted in order to fulfil the requirements of the direction to NGET by the Authority, arising from the TransmiT TNUoS SCR process. In line with that direction, there are three main elements making up this proposal: <ul style="list-style-type: none"> (i) Recognition of network capacity sharing by generators in the Investment Cost Related Pricing (ICRP) TNUoS charge calculation; (ii) Introduction of an approach for including HVDC links that parallel the onshore AC network into the charging methodology; (iii) Introduction of an approach for including Island links in the charging methodology. <p>The specific proposals that follow are expected to facilitate and not preclude any further consideration of the relevant issues and / or development of different approaches that may better achieve the purposes and objectives of this proposal as required by the miscellaneous terms set out in the Authority's direction that this proposal should be developed so as to be consistent with the principles of cost reflectivity, whilst having regard to the desirability for stability and simplicity in transmission pricing, and as far as possible it should:</p> <ul style="list-style-type: none"> a) further the applicable relevant objectives, b) maximise value for money to existing and future consumers, c) be supported by a robust evidence base, and d) give due consideration to the interests of existing and future consumers in the achievement of sustainable development. <p>A detailed description of the aforementioned three main elements follows.</p> <p>(i) Network Capacity Sharing</p> <p>In addition to recovering allowed revenue, Transmission Network Use of System (TNUoS) charges reflect the cost of installing, operating and maintaining the transmission system for the Transmission Owner (TO) activity functions of each GB Transmission Licensee. These activities are undertaken to the standards prescribed by the Transmission Licences, to provide the capability to allow the flow of bulk transfers of power between connection sites over a year of operation and to provide transmission system security.</p> <p>The underlying rationale behind TNUoS charges is that efficient economic signals are provided to Users when services are priced to reflect the incremental costs of supplying them. Therefore, charges should reflect the impact that users of the transmission system at different locations would have on the Transmission Owner's costs, if they were to increase or decrease their use of the respective systems. This rationale is currently accounted for using the Investment Cost Related Pricing (ICRP) methodology which considers the incremental effect of generation and demand via a DC load flow (DCLF) based "Transport" model. The derivation of the incremental investment costs at different points on the system is currently determined against the requirements of the system at the time of peak demand.</p> <p>As a greater proportion of variable, renewable generation connects to the transmission network, the output of many conventional generators has also become more variable in nature. As generators of different types change the way in which they use the transmission network, the nature of transmission capacity investment planning has also altered to ensure efficient investment is undertaken. This is</p>	

exemplified in the recent changes to the NETS SQSS (GSR-009) and the increasing amount of investment justified on the basis of avoided future constraint costs (i.e. outside of the deterministic NETS SQSS standards). However, the associated commercial arrangements have yet to fully evolve to reflect these underlying physical changes.

The industry began a process of reviewing the commercial framework to reflect the aforementioned changes through the Transmission Access Review (TAR) process from 2007 to 2010. Through this process, the possibility of explicitly recognising the differential impact on network costs by generators with different characteristics into charging and access arrangements was considered. However, this process culminated in the Secretary of State rejecting this explicit recognition in favour of a form of Connect and Manage. As a result, this modification proposal does not propose to alter the form of access rights afforded to generators (in the form of Transmission Entry Capacity - TEC) through the government's decision. Rather, it seeks to improve the cost-reflectivity of TNUoS tariffs for generators by implicitly recognising that this sharing takes place and is taken into account in an equally implicit manner in the network investment planning process.

This proposal seeks to recognise the implicit sharing of the wider transmission network (local circuits are not planned on the basis of being shared and are therefore not deemed to be shared) by altering the way in which the wider tariff is calculated within the Transport and Tariff model, thus improving its cost-reflectivity.

Transport Model

This proposal seeks to replace the existing peak background in the Transport model with two separate background conditions, representing peak security and year round conditions respectively. Whilst the existing DCLF in the Transport model sets up the peak demand background by scaling down the contracted TEC of all generators equally to meet total demand, the proposal would setup two peak demand conditions and scale generation differently under each to reflect the values used in the NETS SQSS. Some of these values would be fixed year on year and some would vary depending on the demand level in the year under consideration. The values that would have arisen from 2011/12 data are as follows:

Generator Type	TEC	Current Methodology	Peak Security Background	Year Round Background
Intermittent	5,460	65.5%	0%	70%
Nuclear & CCS	10,753	65.5%	72.5%	85%
Interconnectors	3,268	65.5%	0%	100%
Hydro	635	65.5%	72.5%	66%
Pumped Storage	2,744	65.5%	72.5%	50%
Peaking	5,025	65.5%	72.5%	0%
Other (Conventional)	61,185	65.5%	72.5%	66%

Values in grey vary depending on the total demand level, whilst values in black are fixed scaling factors corresponding to those used in the NETS SQSS

In order to ascertain whether the incremental investment driver on a given circuit is related to peak security or year round conditions, the power flows on each circuit are compared and a proportion of the circuit is allocated to a given investment driver (i.e. peak security or year round). It is proposed that the allocation is done on the basis of whole circuits being either peak security or year round driven, with the background leading to the highest flows on a given circuit dictating its investment driver and allocation.

Once the allocation process is complete an incremental MW would be applied at each node in the DCLF model, as occurs in the existing methodology, in order to establish the effect of that additional MW on the transmission network as a whole. Under this proposal, the incremental MW process would occur at each node in turn for both the peak security and year round conditions. Ultimately, this process results in the incremental impact (i.e. MWkm) for each circuit under both conditions. These MWkm would subsequently be allocated to either the peak security or year round conditions, based on the aforementioned allocation of a given circuit to an investment driver. The splitting of MWkm across two background conditions, representative of different investment drivers, is the first in a two step process. A further step is required in order to make an improvement to the cost-reflectivity of this approach.

As transmission investment is no longer solely planned for peak security conditions the proposal recognises that the impact of an incremental MW on the need for network capacity varies depending on the type of generation, as well as its location. This proposal would scale the year round incremental MWkm of each individual generator depending on its impact on the transmission network, as detailed in the following paragraph. For the peak incremental MWkm it is proposed to maintain the existing uniform treatment of generation (i.e. treat all generation capacity the same regardless of plant type), with the exception that the incremental MWkm of intermittent plant is scaled to 0% in recognition of the assumptions made when planning network capacity. Where a different approach is developed through the working group process that is reasonably considered by the proposer to better meet the miscellaneous terms set out in the Authority's direction, it shall be substituted into this proposal in accordance with the proposer's rights under clauses 8.16.10 and 8.20.23 of the CUSC. It is recognised that stand-alone alternatives may also be developed through the working group process.

Explicit commercial arrangements are not in place that provide Transmission Licensees with information to assess the impact on the need for transmission network investment arising from an individual generator when planning investment. Therefore implicit assumptions over input prices (fuel, CO₂, subsidy, etc.) and generator characteristics (efficiency, availability, etc.) relative to the remainder of the market are made. In order to remain cost-reflective, any proposed scaling factor needs to be reflective of the implicit assumptions made when planning network capacity. This proposal puts forward a form of generator specific annual load factor, based on 5 years historic output, as representative of the assumptions made when planning investment and achieving an appropriate balance between simplicity and cost-reflectivity. In order to maintain what is deemed to be an appropriate balance it is proposed that the annual load factor be applied in an equal manner across all wider TNUoS zones regardless of generation plant mix. Where a different approach is developed through the working group process that is reasonably considered by the proposer to better meet the miscellaneous terms set out in the Authority's direction, it shall be substituted into this proposal in accordance with the proposer's rights under clauses 8.16.10 and 8.20.23 of the CUSC. It is recognised that stand-alone alternatives may also be developed through the working group process.

Tariff Model

The Tariff model utilises the incremental MWkm and the unit cost of these MWkms (i.e. the expansion constant and expansion factors) in order to calculate the locational signal, which forms part of the wider TNUoS tariff. Once this is completed and the proportion of revenue collected from the locational element is known, the Tariff model also calculates the non-locational, residual element to ensure that the total allowed revenue is recovered in the proportion of 27% from generators and 73% from demand users of the network. Together the locational and residual elements of the tariff form the wider TNUoS tariff in the existing methodology.

Under this proposal the structure of the wider TNUoS tariff would change to mirror the changes in the Transport model, such that the locational element is split into a peak security element and a year round element. As a result the TNUoS charge for an individual generator arising from the wider element of the TNUoS tariff would be calculated as follows:

$$(\text{Peak Security } \text{£/kW} + \text{Year Round } \text{£/kW} + \text{Residual } \text{£/kW}) \times \text{TEC kW} = \text{£ wider TNUoS charge}$$

For the avoidance of doubt the methodology for calculating demand charges would be based on the existing approach.

(ii) Inclusion of HVDC in charging calculation

When calculating the wider TNUoS tariff utilising the Transport and Tariff model, various AC transmission technologies are modelled in the Loadflow element. This is done in order to include the various unit costs of these technologies into the calculation of the locational signal. Whilst overhead lines and cables of different voltage levels are included no DC technology, outside of the offshore charging methodology, is currently taken account of. With the first of two planned HVDC links (or "bootstraps") committed, the need to be able to suitably represent these links in the methodology is imminent.

Two main issues need to be addressed in order to facilitate HVDC circuits in the charging model:

- (a) The treatment of base case and incremental power flows in the DC load flow element of the charging model, in light of the inherent controllability of flows through an HVDC link that parallels the AC network;
- (b) The calculation of the expansion factor (i.e. relative unit cost) for HVDC circuits.

a) Power Flow

It is proposed that the treatment of power flow on an HVDC link in the Transport Model be based on a simplifying assumption. This treatment can be made due to the controllable nature of these links relative to power flows on the AC network, which are dictated solely by the impedance of a circuit and that of the remaining network. As a result, this proposal asserts that the modelling of an HVDC link as an AC circuit, for the purposes of calculating the incremental power flow element of the locational signal, represents a reasonable simplification. This approach requires the calculation of impedance for the equivalent AC transmission circuit (i.e. the circuit characteristic that dictates power flow).

This proposal would calculate the impedance by adjusting the impedance of the HVDC circuit in the DC load flow in order to achieve a pre-determined power flow through it in the base case. This power flow is determined as a proportion of the average circuit ratings of all the circuits comprising the main transmission boundaries that the HVDC circuit crosses. That is, it is assumed that the HVDC circuit is loaded to the same extent on average as the equivalent AC circuits that it parallels.

To achieve this one would first sum the ratings of all transmission circuits that cross each transmission boundary individually, excluding the HVDC circuit itself. Subsequently, the power flow across each boundary without any flow on the HVDC circuit would be used to produce a ratio of power flow to boundary total circuit rating (accounting for the direction of the boundary flow in the base case). These ratios can be used to calculate an average for all transmission boundaries that the HVDC circuit crosses. This average power flow to total circuit rating figure is used to set the impedance of the AC equivalent HVDC circuit to produce the power flow that gives this ratio to the HVDC circuit rating.

b) Expansion Factor

The charging methodology incorporates the unit cost of various transmission technologies by calculating the cost of a given technology relative to the cost of 400kV overhead line. This allows for the calculation of a multiplier, known as an expansion factor, which is used in the Transport model to calculate the locational signal within TNUoS charges. As HVDC technology does not currently exist in the Transport model, a method of incorporating its unit cost is also required.

This proposal would introduce a new expansion factor for each HVDC circuit depending on its voltage. In addition, as HVDC converters are an integral element of the distance related locational signal of the link, it is proposed to include the cost of these converters into the expansion factor calculation for each circuit. Currently HVDC converters can be broadly split into two different types, current source converters and voltage source converters, leading to the potential for two additional expansion factor types. Where a different approach is developed through the working group process that is reasonably considered by the proposer to better meet the miscellaneous terms set out in the Authority's direction, it shall be substituted into this proposal in accordance with the proposer's rights under clauses 8.16.10 and 8.20.23 of the CUSC. It is recognised that stand-alone alternatives may also be developed through the working group process.

(iii) Inclusion of Island links into the charging methodology

A methodology for calculating cost reflective TNUoS charges for transmission spurs connecting generation and demand and comprised of network technology not included in the expansion factors set out in clause 14.15.47 and 14.15.49 of the CUSC, such as those which may be established between the Scottish mainland and the Scottish islands of Western Isles, Orkney and Shetland is not currently included in the methodology.

In order to calculate cost reflective charges for this type of transmission circuit this proposal addresses how the expansion factor should be calculated for underground and subsea technologies not included in the methodology.

As outlined in (ii), above, the charging methodology incorporates the unit cost of various transmission technologies by calculating the cost of a given technology relative to the cost of 400kV overhead line. This allows for the calculation of a multiplier, known as an expansion factor, which is used in the Transport model to calculate the locational signal within TNUoS charges. As the sub-sea and HVDC technologies proposed do not currently exist in the Transport model, a method of incorporating their unit cost is required.

For transmission spurs, such as those connecting Scottish islands, it is proposed to calculate new expansion factors for each type of circuit technology proposed. Where such circuits are comprised of HVDC technology, the methodology would be consistent with that outlined in (ii) above. In addition, where a significant proportion of the spur has no redundancy, but is still deemed to be part of the wider network for charging purposes, the length of that portion of the circuit in the transport model would be adjusted to compensate by multiplying its actual length by 1/(Locational Security Factor). Where a different approach is developed through the working group process that is reasonably considered by the proposer to better meet the miscellaneous terms set out in the Authority's direction, it shall be substituted into this proposal accordance with the proposer's rights under clauses 8.16.10 and 8.20.23 of the CUSC. It is recognised that stand-alone alternatives may also be developed through the working group process. Development of these alternatives should consider any precedents which it may be setting for other aspects of the charging methodology.

Description of Issue or Defect that the CUSC Modification Proposal seeks to Address:
(mandatory by proposer)

(i) Network Capacity Sharing

As a greater proportion of variable, renewable generation connects to the transmission network, the output of many conventional generators has also become more variable in nature. As generators of different types change the way in which they use the transmission network, the nature of transmission capacity investment planning has also altered to ensure efficient investment is undertaken. This is exemplified in the recent changes to the NETS SQSS (GSR-009) and the increasing amount of investment justified on the basis of avoided future constraint costs (i.e. outside of the deterministic NETS SQSS standards). In order to maintain a consistent level of cost reflectivity, Transmission Network Use of System charges must also evolve.

(ii) Inclusion of HVDC in charging calculation

With the first of two planned HVDC links paralleling the existing AC network committed, there is a requirement to properly take account of changes in the Transmission business and produce cost reflective tariffs through the ability to represent these links in the charging methodology.

(iii) Inclusion of Islands links into the charging methodology

With three links to the Islands of northern Scotland planned in the near future, each of which is likely to be in the form of a transmission spur connecting generation and demand and comprised of network technology not included in the expansion factors set out in clause 14.15.47 and 14.15.49 of the CUSC, there is a requirement to properly take account of changes in the Transmission business and produce cost reflective tariffs through the ability to represent these links in the charging methodology

Impact on the CUSC: (this should be given where possible)

Significant impact on Section 14 and impact on Definitions. Further impacts to be determined.

Do you believe the CUSC Modification Proposal will have a material impact on Greenhouse Gas Emissions? Yes/No (mandatory by Proposer. Assessed in accordance with Authority Guidance – see guidance notes for website link)

Yes

Impact on Core Industry Documentation. Please tick the relevant boxes and provide any supporting information: (this should be given where possible)

BSC

Grid Code

STC

Other
(please specify)

Possible impact on STC in order to facilitate acquisition of sufficient data for calculation of expansion factors for technologies used in island links.

Urgency Recommended: Yes / No (optional by Proposer)

No

Justification for Urgency Recommendation (mandatory by Proposer if recommending progression as an Urgent Modification Proposal)

N/A

Self-Governance Recommended: Yes / No (mandatory by Proposer)

No

Justification for Self-Governance Recommendation (mandatory by Proposer if recommending progression as Self-governance Modification Proposal)

N/A

Should this CUSC Modification Proposal be considered exempt from any ongoing Significant Code Reviews? (mandatory by Proposer in order to assist the Panel in deciding whether a Modification Proposal should undergo a SCR Suitability Assessment)

No ongoing SCRs.

Impact on Computer Systems and Processes used by CUSC Parties: (this should be given where possible)

To be considered.

Details of any Related Modifications to Other Industry Codes (including related CUSC Modification Proposals): (where known)

CMP207

CMP213 Amendment
Proposal

07 December 2012

Version 1.0

Page 153 of 199

Justification for CUSC Modification Proposal with reference to Applicable CUSC Objectives:
(mandatory by proposer)

Please tick the relevant boxes and provide justification for each of the Charging Methodologies affected.

Use of System Charging Methodology

- (a) that compliance with the use of system charging methodology facilitates effective competition in the generation and supply of electricity and (so far as is consistent therewith) facilitates competition in the sale, distribution and purchase of electricity;
- (b) that compliance with the use of system charging methodology results in charges which reflect, as far as is reasonably practicable, the costs (excluding any payments between transmission licensees which are made under and in accordance with the STC) incurred by transmission licensees in their transmission businesses and which are compatible with standard condition C26 (Requirements of a connect and manage connection);
- (c) that, so far as is consistent with sub-paragraphs (a) and (b), the use of system charging methodology, as far as is reasonably practicable, properly takes account of the developments in transmission licensees' transmission businesses.

Full justification:

Submitted in order to fulfil the requirements of the direction to NGET by the Authority, arising from the TransmiT TNUoS SCR process. See proposals and defect description, above.

In summary proposals would facilitate more effective competition by increasing the cost-reflectivity of charges, such that users of the transmission network are exposed to the costs they impose by such use. Proposals would also properly take account of developments in the transmission business by evolving with the charging methodology to reflect the increase in intermittent generation, include HVDC technologies that parallel the onshore network and include links to Scottish islands.

Connection Charging Methodology

- (a) that compliance with the connection charging methodology facilitates effective competition in the generation and supply of electricity and (so far as is consistent therewith) facilitates competition in the sale, distribution and purchase of electricity;
- (b) that compliance with the connection charging methodology results in charges which reflect, as far as is reasonably practicable, the costs (excluding any payments between transmission licensees which are made under and in accordance with the STC) incurred by transmission licensees in their transmission businesses and which are compatible with standard condition C26 (Requirements of a connect and manage connection);
- (c) that, so far as is consistent with sub-paragraphs (a) and (b), the connection charging methodology, as far as is reasonably practicable, properly takes account of the developments in transmission licensees' transmission businesses;
- (d) in addition, the objective, in so far as consistent with sub-paragraphs (a) above, of facilitating competition in the carrying out of works for connection to the national electricity transmission system.

CMP213 Amendment
Proposal

07 December 2012

Version 1.0

Page 154 of 199

Full justification:

Details of Proposer: (Organisation's Name)	National Grid Electricity Transmission
Capacity in which the CUSC Modification Proposal is being proposed: (i.e. CUSC Party, BSC Party, "National Consumer Council" or Materially Affected Party)	CUSC Party
Details of Proposer's Representative: Name: Organisation: Telephone Number: Email Address:	Ivo Spreeuwenberg National Grid Electricity Transmission 01926 655897 ivo.spreeuwenberg@nationalgrid.com
Details of Representative's Alternate: Name: Organisation: Telephone Number: Email Address:	Andrew Wainwright National Grid Electricity Transmission 01926 655944 andy.wainwright@nationalgrid.com
Attachments (Yes/No): If Yes, Title and No. of pages of each Attachment: N/A	

CMP213 Amendment
Proposal

07 December 2012

Version 1.0

Page 155 of 199

Annex 3 – Workgroup Attendance Register

Name	Organisation	Role	Number of meetings attended*	Able to vote**
Patrick Hynes	National Grid	Chairman	14	No
Jackeline Crespo-Sandoval	National Grid	Technical Secretary	16	No
Ivo Spreeuwenberg	National Grid	National Grid representative	15	Yes
Anthony Mungall	Ofgem	Authority Representative	16	No
Dennis Gowland	The European Marine Energy Centre (EMEC) Ltd	Workgroup Member	15	Yes
Ebba John	DONG Energy Burbo Extension (UK) Limited	Workgroup Member	12	Yes
Frank Prashad	RWEnpower	Workgroup Member	16	Yes
Garth Graham	SSE Generation Ltd	Workgroup Member	16	Yes
Helen Snodin	Viking Energy	Workgroup Member	14	Yes
James Anderson	ScottishPower Energy Management Limited	Workgroup Member	14	Yes
Maf Smith	RenewableUK	Workgroup Member	12	Yes
Mark Cox	EDF Energy	Workgroup Member	15	Yes
Michael Dodd	ESB International	Workgroup Member	12	Yes
Patrick Smart	RES UK and Ireland Limited	Workgroup Member	13	Yes
Paul Jones	E.ON UK	Workgroup Member	15	Yes
Peter Waghorn	Phillips 66 / Immingham CHP LLP	Workgroup Member	16	Yes
Ricky Hill	Centrica	Workgroup Member	14	Yes
Simon Lord	First Hydro Company	Workgroup Member	12	Yes
Stuart Cotten	Drax Power Limited	Workgroup Member	8	Yes
Robert Longden	Mainstream Renewable Power	Workgroup Member	5	No
Nick Kay	Verbeia Energy Limited	Observer	9	No

* including Nominated Alternative attendance

** *insert criteria for voting*

Nominated alternatives

Nominated Alternative	For Workgroup member	No. meetings attended
Wayne Mullins	Ivo Spreeuwenberg	2
Geoff Randall	Anthony Mungall	3
Angus MacRae	Garth Graham	1
Bill Reed	Frank Prashad	1
Cem Suleyman	Stuart Cotten	6
Graham Pannell	Patrick Smart	1
Paul Mott	Mark Cox	2
Stefan Leedham	Mark Cox	4

Project TransmiT

Project TransmiT was Ofgem's independent and open review of transmission charging and associated connection arrangements. The stated aim of Project TransmiT was to ensure that arrangements are in place to facilitate the timely move to a low carbon energy sector whilst continuing to provide safe, secure, high quality network services at value for money to existing and future consumers.

Ofgem launched a Call for Evidence²⁸ on 22 September 2010, inviting views on the scope of and priorities for the Project TransmiT review and called for evidence from generators, shippers, suppliers, network companies, consumers and their representatives, the sustainable development community and other interested parties. Ofgem anticipated, at that time, coming to a conclusion in the summer of 2011.

The review initially incorporated charging and connections arrangements for electricity and gas as well as consideration for Carbon Capture and Storage.

In their scoping document²⁹ of 25 January 2011 Ofgem clarified the scope of Project TransmiT. After considering responses to the Call for Evidence and views expressed at a stakeholder event, electricity connection issues and electricity transmission charging arose as the immediate priority.

In parallel, Ofgem commissioned a series of reports from consultants and academics to gather evidence focused on the electricity transmission charging regime, with consideration for interactions with the gas regime and consistency of key principles. These reports were published on the Ofgem Project TransmiT web forum³⁰ in May 2011.

Also in May 2011, Ofgem published an open letter³¹ setting out their approach to work on electricity charging under Project TransmiT. In this letter Ofgem set out that the charging work would focus specifically on charging arrangements that seek to recover the costs of providing electricity transmission assets; i.e. Transmission Network Use of System (TNUoS) Charging.

In addition the aforementioned May 2011 open letter set out the view that this work should be progressed through a Significant Code Review (SCR) and that the approach was consistent with the original scope of Project TransmiT, which was seeking to address issues that are an immediate priority, and should enable any appropriate changes to be introduced in the short term. Ofgem noted they hoped to come to a conclusion in late summer 2011 and that, if appropriate, the aim would be to implement any change to TNUoS in time for the following charging year; i.e. April 2012. However, they recognised that this was an ambitious and challenging timetable and therefore did not rule out the possibility of implementing appropriate changes at a later date. Ofgem subsequently confirmed that changes, where appropriate, would be implemented after April 2012 to allow for further analysis³².

²⁸ <http://www.ofgem.gov.uk/Pages/MoreInformation.aspx?docid=1&refer=Networks/Trans/PT>

²⁹ http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/110125_TransmiT_Scope_Letter_Final.pdf

³⁰ <http://www.ofgem.gov.uk/Networks/Trans/PT/WF/Pages/WebForum.aspx>

³¹ http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/110527_TransmiT_charging_letter.pdf

³² http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/110909_TransmiT_charging_SCR_update.pdf

Significant Code Review (SCR) Technical Working Group (the “Working Group”)

Following a consultation in July 2011, Ofgem announced their intention to launch an SCR³³ on electricity transmission charging issues under Project TransmiT and to conclude by December 2011. The launch statement set out the timetable and next steps for the SCR, making clear that collaborative and constructive input from industry would be essential to timely delivery of any appropriate changes. In its open letter of September 2011 Ofgem indicated that the timetable would be extended to March 2012.

The scope of the SCR was to develop and assess a range of charging options that focus on TNUoS charging alone and therefore excluded options that imply wider changes (i.e. those that would, to varying degrees, impact the current GB electricity trading arrangements). This range is illustrated in Figure A4.1, below.



Figure A4.1 - Range of Charging Options

The scope of the Project TransmiT SCR also excluded any changes to the charges that recover the cost of system operation (i.e. Balancing Services Use of System (BSUoS) charges) and charges that recover the cost of connection (connection charges) were also excluded from the scope of the Project TransmiT SCR.

Currently TNUoS charges are calculated by National Grid as National Electricity Transmission System Operator (NETSO) in accordance with the GB Use of System Charging Methodology³⁴. Changes to the methodology are subject to the Connection and Use of System Code (CUSC) governance process³⁵.

In accordance with National Grid’s Transmission Licence Condition C5, TNUoS charges are currently calculated (and changes assessed) in accordance with the relevant objectives, which state that these charges should (paraphrased for convenience):

- i) Facilitate effective competition in the generation and supply of electricity;
- ii) Reflect, as far as reasonably practicable, the costs incurred by transmission licensees in their transmission businesses;
- iii) Properly take account of the developments in transmission licensees’ transmission businesses.

In addition to the relevant charging objectives above, the Transmission Licence (Standard Licence Condition C7) also prohibits National Grid from discriminating against any User or class of Users unless such different treatment reasonably reflects differences in the costs of providing a service.

The basis for the current charging methodology is the Investment Cost Related Pricing (ICRP) approach, which calculates TNUoS tariffs that vary according to the

³³ http://www.ofgem.gov.uk/Networks/Trans/PT/Documents/1/110707_Final%20launch%20SCR%20statement.pdf

³⁴ Section 14 of the Connection and Use of System Code, http://www.nationalgrid.com/NR/rdonlyres/8FFA9408-9DC7-44C2-AF68-93E684A176D8/47549/CUSC_Section_14combinedmasterclean5July11_FINAL.pdf

³⁵ Section 8 of the Connection and Use of System Code, http://www.nationalgrid.com/NR/rdonlyres/8B81E9A0-F1B1-47B7-906D-41DA0DB69167/45131/CUSC_Section_8_v19_CAP179_WGAA2_31Jan11.pdf

incremental cost of supplying transmission network capacity at different locations across GB. The principle behind this approach is one of providing economic signals that allow transmission users to factor their impact on the transmission network into siting locational decisions and hence provide an overall economic generation and transmission system for end consumers.

As part of the SCR launch, Ofgem set out to establish a Technical Working Group in order to develop the technical detail of two alternative approaches to TNUoS charging. These approaches, a 'Postage Stamp' model and an 'Improved ICRP' model, were to be assessed alongside the existing 'Status Quo' ICRP model in an impact assessment by Ofgem's appointed economic consultants, Redpoint Consulting Limited. Ofgem also indicated that connection charging arrangements, embedded generation and the small generator discount (Standard Licence Condition C13) were out of scope of the SCR.

The Technical Working Group, comprised of fifteen representatives covering a broad range of stakeholder interests, met on a fortnightly basis between July and September 2011 in order to discuss and develop the aforementioned models to be taken forward for economic analysis. The deliberations of the Technical Working Group focused around six broad themes, categorised by Ofgem as follows:

Theme
1. Reflecting characteristics of transmission users
2. Geographical/topological differentiation of costs
3. Treatment of security provision
4. Reflecting new transmission technology
5. Unit cost of transmission capacity
6. G:D split

The recommendations of the Technical Working Group for each of the six themes under the three charging models that were under consideration are set out below.

For an extension of the Status Quo model out to the end of the modelling time horizon, 2030, the following recommendations were made by the Technical Working Group:

Status Quo (ICRP extended to 2030)	
Theme	Outcome
1	<ul style="list-style-type: none"> no change
2	<ul style="list-style-type: none"> no change
3	<ul style="list-style-type: none"> no change noted that some island connections could be classed as wider for charging purposes and would therefore have a security factor of 1.8
4	<ul style="list-style-type: none"> model HVDC links that parallel the onshore network as an equivalent AC circuit by: <ol style="list-style-type: none"> determining impedance from an HVDC power flow calculated as the average of a ratio of total network boundary rating versus HVDC link rating for all boundaries that the link crosses No consensus on calculating expansion factor for the HVDC link; choice of either: <ol style="list-style-type: none"> excluding converter costs or including all costs
5	<ul style="list-style-type: none"> no change
6	<ul style="list-style-type: none"> move from a G/D revenue collection split of 27/73 to 15/85 from 2015

The economic modelling of the Status Quo was undertaken, by Redpoint Consulting Limited, on a charging approach consistent with the Technical Working Group's recommendations, set out above. Where there was no consensus, on the costs that should be incorporated into the HVDC expansion factor calculation, Ofgem decided to undertake the modelling including all costs.

The Technical Working Group's recommendations for the Improved ICRP model were as follows:

Improved ICRP	
Theme	Outcome
1	<ul style="list-style-type: none"> Dual background approach to the Transport Model used in calculating locational differentials (Peak Security and Year Round backgrounds) Background scaling factors for plant types consistent with NETS SQSS proposals under GSR009 The use of a two part tariff commensurate with the dual backgrounds No consensus on plant contributing to tariff elements; choice of: <ol style="list-style-type: none"> Intermittent plant only contributes to Year Round element; or All plant contribute to both Peak Security and Year Round element No consensus on tariff calculation for Year Round element; choice of: <ol style="list-style-type: none"> TEC only TEC x specific historic load factor TEC x generic load factor for plant type TEC x specific forecast load factor (with reconciliation) TEC x ex-post MWh
2	<ul style="list-style-type: none"> no change to zoning criteria or local/wider boundary
3	<ul style="list-style-type: none"> no change for island connections that would be classed as wider for charging purposes and that have significant sections of single circuit (i.e. islands with single circuit sub-sea connections) the expansion factor for this section would be calculated by dividing the unit cost by 1.8
4	<ul style="list-style-type: none"> focus on HVDC links only model HVDC links that parallel the onshore network as an equivalent AC circuit by: <ol style="list-style-type: none"> Determining impedance from an HVDC power flow calculated as the average of a ratio of total network boundary rating versus HVDC link rating for all boundaries that the link crosses No consensus on calculating expansion factor for the HVDC link; choice of either: <ol style="list-style-type: none"> excluding converter costs or including all costs
5	<ul style="list-style-type: none"> no change
6	<ul style="list-style-type: none"> move from a G/D revenue collection split of 27/73 to 15/85 from 2015

In addition to the areas where the Technical Working Group did achieve consensus, there were a few areas under Themes 1 and 4 where Ofgem had to make a decision on how they would be modelled by Redpoint Consulting Limited. These were as follows:

Theme 1 – Intermittent plant would contribute to the Year Round element of the tariff only and the tariff calculation would include a generation plant specific historic load factor.

Theme 4 – When calculating the expansion factor for HVDC links all asset costs would be included.

The Technical Working Group's recommendations for the Postage Stamp (a.k.a. 'Socialised') model were as follows:

Postage Stamp	
Theme	Outcome
1	<ul style="list-style-type: none"> no consensus on reflecting user characteristics; choice of allocating charges based on: <ol style="list-style-type: none"> MW or MWh
2	<ul style="list-style-type: none"> no consensus on differentiation of costs; choice of: <ol style="list-style-type: none"> maintain existing local/wider boundary remove local/wider boundary and socialise all costs continue to calculate an ICRP based demand charge charge demand on the same basis as generation (i.e. socialised)
3	<ul style="list-style-type: none"> not relevant for wider tariffs no change for local if maintaining local/wider boundary
4	<ul style="list-style-type: none"> not relevant for a postage stamp model
5	<ul style="list-style-type: none"> no change for local if maintaining local/wider boundary
6	<ul style="list-style-type: none"> move from a G/D revenue collection split of 27/73 to 15/85 from 2015

Under the Postage Stamp model there was a lack of consensus under Theme 1 and Theme 2. Here Ofgem decided that the following would be taken forward for economic modelling:

Theme 1 – Postage Stamp charges were to be calculated on a MWh basis

Theme 2 – Remove the local/wider boundary and socialise all costs; charge demand on the same basis as generation (i.e. socialised)

In addition to model development, the Technical Working Group was also given the opportunity to comment on the input assumptions to the economic modelling exercise being undertaken in parallel by Redpoint Consulting Limited.

A record of the SCR Technical Working Group's deliberations and recommendations to Ofgem on the form of the alternative approaches under consideration (i.e. Postage Stamp and Improved ICRP) is available in the form of the Technical Working Group's initial report³⁶ published on the 6th of October 2011. In addition, the comments and feedback from the Technical Working Group on the various inputs and outputs of the economic modelling exercise is logged in an November 2011 addendum to the initial report³⁷.

Economic Analysis and SCR Conclusions

Redpoint Consulting Limited as commissioned by Ofgem to provide a quantitative assessment of how the different charging options might impact on the objectives of Project TransmiT, as set out above.

The analytical approach taken by Redpoint in this modelling assessed the impact of the transmission charging options on investment in generation and transmission. Transmission charges will influence the decisions of generators regarding where to locate their plant, and which plant to retire. This in turn has an impact on transmission charges; as well affecting the level of constraint costs which will drive future decisions on when and where to reinforce the transmission network. These reinforcements then feed into transmission charges which then also influence generators' decisions.

³⁶ <http://www.ofgem.gov.uk/Networks/Trans/PT/WF/Documents1/TransmiT%20WG%20Initial%20Report.pdf>

³⁷ http://www.ofgem.gov.uk/Networks/Trans/PT/WF/Documents1/TransmiT%20WG%20Addendum%20to%20Initial%20Report_final.pdf

To undertake the analysis a modelling framework was developed by Redpoint that incorporated modules for transmission charging, system despatch, market pricing, constraint forecasting, and generation and transmission investment decision making within GB. This was done with input from National Grid Electricity Transmission and Ofgem, as well as with feedback from the aforementioned Technical Working Group. A full report of the modelling approach, assumptions and results is available on Ofgem's website³⁸.

Utilising the outcome of the Redpoint economic analysis, Ofgem published their assessment³⁹ of the options for change to TNUoS charges on the 20th of December 2011. This assessment covered the three main options set out above in addition to two policy variants (an Improved ICRP model that excludes converter station costs from HVDC and a Postage Stamp variant that retains the local tariff for generators).

The assessment was carried out against the three broad aims of Project TransmiT:

- i) deployment of low carbon generation across Great Britain (GB) and impact on achieving the UK Government's Renewable Energy Strategy target of 30% of generation from renewable sources by 2020 and reduced carbon intensity by 2030.;
- ii) quality and security of supply across GB; and
- iii) overall cost of the transmission system as a whole and customer bill impacts.

Ofgem noted that the charging options modelled by Redpoint resulted in very different patterns of TNUoS charges across generators, but that each was consistent with meeting the UK Government's 2020 renewable target and carbon intensity goals with no material differences in the implications for security of supply. They noted that the key differences between the options were the impacts on power sector costs and consumer bills.

Based on the evidence and their assessment of it, Ofgem consulted on ruling out socialised TNUoS charging (a Postage Stamp approach) as an option primarily due to the disproportionate costs and associated impacts on consumer bills associated with such an approach.

Subsequently, in their Significant Code Review conclusions document⁴⁰ published on the 4th of May 2012, Ofgem confirmed that a socialised approach to TNUoS charging should not be progressed and reaffirmed the principle of cost reflectivity in transmission charging. Whilst it was considered that the choice between Improved ICRP and maintaining the Status Quo was not clear cut, Ofgem remained of the view that an improved form of ICRP was the best way forward.

In their conclusions Ofgem noted that only one form of Improved ICRP was modelled by Redpoint and that they expected the approach could be improved further and that industry was best placed to further progress the work and consider alternatives that best deliver the objectives of Project TransmiT.

As such, Ofgem set out to direct National Grid Electricity Transmission to raise an amendment proposal to the Connection and Use of System Code (CUSC) to ensure that the TNUoS methodology:

- i) Better reflects the costs imposed by different types of generators on the electricity transmission network (a.k.a. network **sharing**);
- ii) Takes account of the development of **HVDC links** that will run parallel to the onshore transmission network; and

³⁸ <http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/Modelling%20the%20impact%20of%20transmission%20charging%20options.pdf>

³⁹ <http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/Project%20TransmiT%20Dec11.pdf>

⁴⁰ <http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/TransmiT%20SCR%20conclusion%20document.pdf>

- iii) Takes into account the potential **island links**, such as those that are currently being considered for Scottish islands.

On the 25th of May 2012, Ofgem directed NGET⁴¹ to raise a modification proposal to the CUSC.

SCR Direction

The terms of the SCR Direction set out the specific issues that NGET's Proposal to modify the Use of System Charging Methodology should consider and address under each of the three aforementioned areas.

Sharing

For reflecting the costs imposed by different types of generations the Direction obliged NGET to include proposals suggestions for modifying TNUoS:

- i) so that generator charges are calculated using a dual background approach, by reference to the impact of different types of generation located at different points on the network on the incremental costs of transmission infrastructure required to secure demand at the system peak (the peak security condition), and the incremental costs of transmission infrastructure investment associated with efficient year round operation of the transmission system (the year round condition) in a manner consistent with the SQSS;
- ii) so that the peak condition is calculated by reference to the generation background scaling factors used in the derivation of the Security Planned Transfer condition under Appendix C of the NETS SQSS;
- iii) taking into consideration whether a factor of zero or some other value should apply to intermittent generation technology types for the purposes of calculating the peak security element of the charge;
- iv) taking into consideration how best the year round element of the tariff might best be structured and levied to more accurately reflect the incremental costs of transmission infrastructure investment from a particular generator on the costs of efficient year round operation of the transmission system (as informed by analysis of the relative costs and benefits of infrastructure investment against operational expenditure); and
- v) taking into consideration how the peak security and year round elements should be applied geographically, particularly having regard to those zones that are, or which may become, dominated by one type of generation technology.

Parallel HVDC Links

For taking account of the HVDC links that parallel the AC network, the Direction obliged NGET to include proposals suggestions for modifying TNUoS:

- i) so that where account is taken of the impedance from an HVDC power flow, it is calculated as the average of a ratio of total network boundary rating versus HVDC link rating for all boundaries that the link crosses; and
- ii) taking into account which costs should be incorporated into the expansion factor calculation for an HVDC link.

Scottish Island Links

For appropriately taking account of Scottish Island links that are currently being considered, the Direction obliged NGET to include proposals suggestions for modifying TNUoS:

⁴¹ <http://www.ofgem.gov.uk/Networks/Trans/PT/Documents1/Final%20direction%2025%20May%202012.pdf>

- i) taking into consideration whether islands classed as 'wider' for charging purposes should have a two part tariff as determined by the sharing element of the proposal;
- ii) taking into consideration whether islands classed as 'local' for charging purposes should have tariffs consistent with the current methodology for local circuit and local substation tariffs;
- iii) taking into consider whether, for islands classed as 'wider', the global locational security factor should be used without further modification or whether any lack of redundancy should be reflected in the expansion factor calculation;
- iv) taking into consideration whether the expansion factor calculation for radial island links comprising HVDC technology should be the same as that for HVDC links that parallel the AC network; and
- v) taking into consideration whether an anticipatory application of the MITS definition to islands is appropriate and how this could be done.

The CMP213 Original Proposal, addressing the three areas and associated issues required by the Direction (as set out above), was submitted to the CUSC Modifications Panel for their consideration on 29th June 2012. The Panel set up a Workgroup to develop and assess the proposed modification and provided Terms of Reference for the Workgroup ([Annex 1](#)).

Annex 5 – Detail of Original Proposal


The following Annex sets out further detail of the Original proposal to address the capacity sharing defect as set out in the modification proposal document.

The proposal makes a number of suggested incremental improvements to the existing Investment Cost Related Pricing (ICRP) methodology used to calculate users' TNUoS charges, as directed in the Authority's Significant Code Review Direction⁴². These incremental improvements can be broken down into; (1) Transport model changes, and (2) Tariff model changes.

1) Proposed Changes to the Transport Model

The locational element of the wider TNUoS tariff is calculated through consideration of the relative impact of an additional MW, applied on a nodal basis, within a DC load flow. This is done by first calculating the total network requirements required to accommodate the existing generation and demand at peak followed by the addition of an incremental MW of generation at each node in turn whilst at the same time removing a MW from the centre of the transmission network. This process establishes the nodal incremental network requirements. Currently, the setting of this DC load flow is based on a peak background, with all contracted generation uniformly scaled to match peak demand. In addition, each incremental MW applied is treated equally (i.e. it does not distinguish between generation plant type).

The Dual Background Approach



Under this proposal, an additional “Year Round” background would be used alongside “Peak Security” considerations, to represent future transmission system development requirements. This Year Round background would group generation into types based on their technology and perceived future operating regimes, and then either flat or variably scale their aggregated capacity to meet demand in a manner consistent with that outlined in the NETS SQSS, as amended by GSR00943. The level of scaling is shown in

Table 1, below, with flat scaling in black, and variable scaling in grey. It should be noted that the Peak Security background sets intermittent generators and interconnectors to zero; i.e. it assumes no contribution from energy sources that cannot be controlled cannot be relied upon by the system operator to supply energy at times of peak demand. The scaling factors given in Table 1 are a result of the detailed cost-benefit analysis work undertaken by the NETS SQSS review group as part of GSR009 to represent transmission network investment requirements for year round conditions in a single snapshot. It is proposed that the scaling factors given in Table 1 are treated similarly to other charging data which may change with time (e.g. expansion constant) and that they are reviewed at each Transmission Price Control Review (TPCR) or at a greater frequency as set out in the NETS SQSS. This approach of linking to the NETS SQSS is consistent with the existing link between TNUoS charging and the security standards set out in Section 14 of the CUSC.

⁴² <http://www.ofgem.gov.uk/NETWORKS/TRANS/PT/Documents1/Final%20direction%2025%20May%202012.pdf>

⁴³ NETS SQSS Review of Required Boundary Transfer Capability with Significant Volumes of Intermittent Generation – GSR009 Consultation Document v1.0 11 June 2010; <http://www.nationalgrid.com/NR/rdonlyres/E22B1547-D4CC-4F88-AEEF-C76305718C25/41720/GSR009SQSSConsultation.pdf>

Generator Type	TEC in Transport Model	Current Methodology	Peak Security Background	Year Round Background
Intermittent	5,460	65.5%	0%	70%
Nuclear & CCS	10,753	65.5%	72.5%	85%
Interconnectors	3,268	65.5%	0%	100%
Hydro	635	65.5%	72.5%	66%
Pumped Storage	2,744	65.5%	72.5%	50%
Peaking	5,025	65.5%	72.5%	0%
Other (Conv.)	61,185	65.5%	72.5%	66%

(source 2011/12 Transport Model)


Table A5.1 – Example dual background generation scaling factors

In the above table, peaking plant is defined as oil and OCGT technologies and Other (Conv.) represents all remaining conventional plant not explicitly scaled. In the event that a power station is made up of more than one technology type, the type of the higher Transmission Entry Capacity (TEC) would apply.

Utilising the Transport Model from 2011/12 as an example, generation would be scaled using the factors set out in Table A5.1, above, to create two balanced DC load flow models. Combined these models would represent the total network requirements for existing generation and demand, as the single background flows do in the existing approach. It should be noted that, consistent with the current DC load flow model, no circuit ratings would be considered, and no level of redundancy would be assessed at this stage.

Allocating Incremental Network Requirements

Flows on individual transmission circuits in these two models would subsequently be compared. As part of the original modification proposal, the background giving rise to the higher flow on a circuit would be considered to be the 'triggering criterion' for future investment. Triggering criteria for all circuits in the model would then be ascertained and recorded; i.e. circuits will be tagged as either Peak Security or Year Round. In the rare event that both triggering criteria give rise to identical circuit flow the Peak Security background would be taken as the triggering criterion. This reflects the order of priority given to these two backgrounds when considering transmission investment requirements. An alternative approach to allocating incremental network requirements to both triggering criterion in proportion to circuit power flow was discussed in the group and a separate paper was developed to expand on this.



As outlined above, the current ICRP methodology uses an incremental MW applied to a DC load flow at each node in turn (and removed at the reference node), in order to establish the effect of that additional MW on the transmission system as a whole. Under the proposed methodology, this assessment would be carried out at each node in turn for both Peak Security and Year Round backgrounds.

Currently a single reference node is selected. This selection is arbitrary as, due to the re-referencing process, only the relative locational charges are of relevance. However, due to the use of two background criteria in the Transport Model, the re-referencing process would require minor modifications. In order to simplify this revised re-referencing process as much as possible, it is proposed to use a distributed reference node rather than a single reference node. This would effectively split the incremental 1MW removed at the reference node from a single point to proportions on each demand node in the Transport Model. The proportion allocated to a given node would be based on the background nodal demand in the model. For example, with a GB demand of 60GW in the Transport Model a node

with a demand of 600MW would contain 1% of the distributed reference node (i.e. 0.01MW).

On a transmission node by node (i.e. substation by substation) basis, the impact of the incremental MW (i.e. the net change in power flow) would need to be recorded for each circuit's triggering criterion. Therefore, an incremental MWkm would need to be established for each node and attributed to the appropriate circuit triggering criterion; i.e. Peak Security or Year Round. This process results in a set of Peak Security MWkm and Year Round MWkm which combined amount to approximately the same level of total incremental MWkm as the existing ICRP approach. For the 2011/12 Transport and Tariff model, net Peak Security MWkm represent 13.5% of the total network incremental MWkm.

An overview of the proposed process is given below in Figure A5.1.




Figure A5.1 – Illustrative Dual Background Transport Model Logic

Using the expansion constant (£/MWkm) data from the Tariff Model, the nodal incremental MWkm are subsequently averaged into zones.

Weighted Average Zoning

The current methodology for setting generation TNUoS tariff zones requires that these zones should be electrically and geographically proximate and contain relevant nodes whose wider incremental costs are all within +/-£1.00/kW across the zone (i.e. a £2.00/kW spread). Under this proposal it is recommended that zoning assessment is undertaken in exactly the same manner as now, utilising the background with the most MWkm (i.e. the Year Round background) and that it continues to be undertaken such that wider incremental costs (i.e. marginal kilometres) are within +/-£1.00/kW (i.e. +/-50km with EC=£10/MWkm and SF=1.8). Unless there are exceptional circumstances, generation charging zones are normally fixed for the duration of each Transmission Price Control Review.

2) Proposed Changes to the Tariff Model

As in the current version of the Transport and Tariff Model, the zonal incremental MWkm are passed from the Transport Model into the Tariff Model in order to calculate the locational differentials in the tariff. In the case of this strawman two sets of MWkm are passed into the Tariff Model representing both the Peak Security and Year Round backgrounds as set out above.

This proposal intends that the zonal incremental MWkm for Peak Security and Year Round backgrounds be converted into tariffs, which would ultimately lead to

the creation of two wider locational tariff components in addition to the residual. Therefore, under this proposal, a generator's wider TNUoS tariff would be comprised of the following three components;

- i) Peak Security,
- ii) Year Round,
- iii) Residual

The original proposal assumes that sharing of capacity only occurs by generators on the wider transmission network. Therefore, a generator's local substation and local circuit tariff and demand tariffs would not generally be affected by the proposed changes.

Generation Local Tariffs

Local tariffs can consist of a local substation tariff and a local circuit tariff. National Grid's proposal will not to alter the local substation tariff calculation, and therefore will have no impact on local substation charges. Similarly, it is not proposed that there is any explicit change to the calculation of local circuit tariffs. However, due to the categorisation of circuits as either Peak Security or Year Round in the Transport Model, there can be an indirect impact on local circuit tariffs in instances where local circuits are not purely radial in nature. It is proposed that all local circuits will have a Year Round triggering criterion, so as to avoid any perverse incentives in the choice of level of security for design variations on local circuits.

Demand Tariffs

As the incremental impact of demand at a node is calculated as the equal and opposite of generation, demand tariffs are also consequentially calculated using the Peak Security and Year Round backgrounds as outlined above. Demand tariffs, although also split into Peak Security and Year Round components in order to complete the overall tariff calculation, would remain largely unaffected as both these components along with the residual are all charged on the same basis. The reason chargeable capacity for the Peak Security and Year Round elements of the demand tariff remain the same, unlike those for generation, is that the very nature of demand is different within the commercial arrangements. Unlike individual generating units connected directly to the transmission network, each having explicit firm access rights and specific measurable characteristics, demand is amalgamated to Grid Supply Point Groups with implicit access rights resulting in its homogeneous characteristics.

Hence, setting out each individual demand tariff component times the chargeable capacity would result in the same charge as combining the tariff components and subsequently multiplying by chargeable capacity. As such, combining the tariff components to achieve one £/kW tariff maintains simplicity in this area. This is not possible for generation tariffs as the chargeable capacity is necessarily different for each component.

Calculating Wider Locational Tariffs

The following section provides an overview of the Tariff Model process and describes the proposed approach to each of the wider locational tariff components for generation in greater detail.

It is proposed that locational tariffs are derived, as per the existing transmission charging methodology, from the nodal marginal km output of the Transport Model, and the associated zoning exercise. However, as there are two sets of generation MWkm created in the Transport Model corresponding to the Peak Security and Year Round criteria there would ultimately be two wider locational tariff components for generation (as described above).

Conversion from zonal incremental MWkm to unadjusted tariffs follows the existing process through multiplication by the expansion constant and locational security

factor. The subsequent re-referencing process maintains a 27% of revenue from generation and 73% of revenue from demand split on both the Peak Security and Year Round components separately. This individual re-referencing is necessary as, whilst both these wider locational tariff components are charged based on a generator's TEC (i.e. MW capacity), the actual application for specific users will depend on that user's characteristics and is different for both components. This process is illustrated, below, in Figure A5.2.




Figure A5.2 – Illustrative Tariff Model Logic: Part 1

Finally, the re-referenced zonal tariff components are used to calculate the proportion of Maximum Allowed Revenue (MAR) that remains to be collected from the wider tariff for both generation and demand. This is done through the calculation of a residual component for each. The remainder of the process set out in Figure 2 for generation tariffs is illustrated in Figure A5.3, below.




Figure A5.3 – Illustrative Tariff Model Logic: Part 2

i) Peak Security Component

It is proposed that the Peak Security tariff component is only levied on those generators that have a high probability of operating at significant volumes during peak demand periods, consistent with the Security and Quality of Supply Standards (SQSS). As a result of changes to the SQSS through GSR-009, transmission network development for Peak Security requirements is triggered by such generation and hence it is proposed that it is appropriate that this component

of the wider locational tariff be directed towards this generation. As noted above, for the generation background in a 2011/12 model, the net Peak Security MWkm represents 13.5% of the total incremental MWkm.

The revenue from a specific generator due to the Peak Security locational tariff is equal to that component of the tariff multiplied by the forecast generation capacity. This also needs to be multiplied by the appropriate Peak Security flag. The Peak Security (PS) flags indicate whether a generation type contributes to the need for transmission network investment at peak demand conditions. As such, they are consistent with the background generation scaling used in the Peak Security Transport Model assessment (see Table 1 above) and the SQSS. These flags are given below in Table A5.2.

Generation Type	PS Flag
Intermittent	0
Other	1

Table A5.2 – Peak Security Flags

The revenue recovery from the Peak Security component for a given generator is calculated as;

$$UZRR_{PS} = G_{TEC} \times F_{PS} \times UZT_{PS}$$

Where;

$UZRR_{PS}$ = Unadjusted Zonal Revenue Recovery from Peak Security component

G_{TEC} = Forecast generation capacity

F_{PS} = Peak Security flag appropriate to that generator type

UZT_{PS} = Unadjusted Zonal Peak Security Tariff (£/kW)

ii) Year Round Component

National Grid's analysis of the relationship between load factor and incremental transmission constraint costs has indicated a broadly linear relationship largely independent of generation technology (this will be explored further as part of the Working Group process). It is therefore proposed that a generator's specific output over an extended period of time is reflective of the assumption used in transmission network planning timescales and thus the transmission investment it triggers. It follows that the Year Round tariff component for a generation user could be based on the specific output of that generator over time.

In order to maintain a simple and transparent approach, it is proposed that historic generation annual load factors (ALF) be used as scaling factors which more accurately represent the impact of an incremental MW of a given generation type to the need for network investment in under the Year Round background.

The ALF is taken to be indicative of assumptions made about a generator's operating regime in transmission planning timescales, and therefore its effect on transmission investment required for year round operation of the system. As such it is not intended to be an accurate reflection of a generator's actual output over a particular twelve month charging period. Whilst several potential options exist for the calculation of the ALF based on forecast or historical load factor, this proposal puts forward a fixed, historical based approach that precludes the need for an end of year reconciliation. The benefits of this fixed approach are added certainty and stability as a result of increased predictability of tariffs and accuracy of within year revenue collection. In addition, of all the alternatives considered, this approach is deemed most representative of assumptions made in transmission network planning timescales.

Calculation of User Specific ALF

Historic annual load factors would be calculated (for each power station) for each of the last five complete financial years (years -5 to -1) (with the highest and lowest load factors removed) using the formula below;

$$ALF = \frac{MWh_output}{TEC \times 8760}$$

The TEC figure used in each calculation would be the highest TEC applicable to that power station for that financial year. The MWh output figure would be derived from published historic user data available to National Grid. Alternative sources for this data could include Final Physical Notification (FPN) and metering data used for settlements purposes. The benefit of FPN data is that it better represents a generator’s intended system usage as it accounts for some SO constraint actions taken to manage the system. However, it should be noted that longer timescale SO actions would not be captured. The use of FPN data may also require the development of a new process to obtain validated historic FPN data, as this data is not currently used for settlement purposes for all users.

Once all five historic load factor figures have been calculated they would be compared, and the highest and lowest figures are discarded. The discarding of these outermost figures ensures that the final ALF is representative of an indicative operating regime for a particular generator as would have been assumed when planning network investment, and has not been influenced by atypical behaviours. Such behaviours can range from unseasonal weather conditions through to response to System Operator instructions. In addition, such an approach increases the stability of charges year on year.

The ALF, to be used for transmission charging purposes, is calculated as the average of the remaining three historic load factor figures. The process, with example figures, is illustrated in Figure A5.4, below.



Figure A5.4 – Proposed Calculation of Annual Load Factor (ALF)

In the event that only four years of complete metered data are available for a generator then the higher three years load factor would be used in the calculation of ALF. In the event that only three years of complete metering data are available then these three years would be used.

Due to the aggregation of metered data for dispersed generation (e.g. cascade hydro schemes), where a single generator BMU consists of geographically separated power stations, the annual load factor would be calculated based on the total output of the BMU and the overall TEC of the BMU.

In the event that there are not three full years of a generator’s output available, missing historical information would be replaced by generic data for that generator type to ensure three years of information are available for the user.

Derivation of Generic Generator Data

Generic data would be derived from the average annual output of all GB generation of a particular fuel type over the last five years, using an identical methodology to that used for the user specific calculation. The proposed fuel type categories and illustrative data are listed in Table A5.3, below;

Fuel Type	Generic Load Factor
Biomass	N/A
Coal	43%
Gas	57%
Hydro	12%
Nuclear	60%
Oil	2%
Pumped Storage	15%
Wind	16%

Table A5.3 – Fuel Type Categories to be used to derive generic load factor

For new and emerging technologies, where insufficient data is present to allow a generic load factor to be developed from historic information, a generic load factor could be produced by National Grid using an agreed forecast modelling tool. For new generation connecting mid-year, a prorated ALF would be derived using the figures in Table 4. When used for this purpose, it is assumed that the output of the generator is apportioned evenly across a twelve month period.

Generic load factors would be reviewed annually in the period November – December (i.e. at the same time as user specific ALFs) and would be published, in a form similar to Table 4 above, within the Statement of Use of System Charges (the Charging Statement). ALF forecasts would be provided to all generation users at the same time as draft TNUoS tariffs are published.

The revenue recovery from the Peak Security component for a given generator is calculated as;

$$UZRR_{YR} = G_{TEC} \times ALF_{gen} \times UZT_{YR}$$

Where;

- $UZRR_{YR}$ = Unadjusted Zonal Revenue Recovery from Year Round component
- G_{TEC} = Forecast generation capacity
- ALF = Annual Load Factor specific to that generator (as set out above)
- UZT_{YR} = Unadjusted Zonal Year Round Tariff (£/kW)

Re-referencing of Unadjusted Transport Zonal Tariffs

Presently, for both generation and demand users, zonal marginal km (ZMkm) are multiplied by the expansion constant and the global security factor (SF) to give an unadjusted zonal transport tariff. These unadjusted tariffs are multiplied by the expected total metered triad demand and total generation TEC capacity (MW) to calculate the initial revenue recovery. These initial revenue recoveries are then corrected to obtain a 27:73 split in revenue collection between generation and demand respectively. This is achieved through the calculation of a single constant, C, which is then added to the total zonal marginal km for generation and demand as below;

$$\sum_{Gi=1}^{21} [(ZMkm_{Gi} + C) \times EC \times SF \times G_{Gi}] = CTRR_G$$

$$\sum_{Di=1}^{14} [(ZMkm_{Di} + C) \times EC \times SF \times D_{Di}] = CTRR_D$$

- Where EC = expansion constant
- LSF = locational security factor
- G = generation within [a] [each] zone
- D = demand within [a] [each] zone
- CTTR = 'generation / demand split' corrected transport revenue recovery

In addition to the existing re-referencing process ensuring the correct revenue split, the introduction of the C constant also ensures that the transmission charging methodology is stable for any changes to the reference node⁴⁴. Effectively, the C constant readjusts for the position of the reference node when ensuring the 27:73 (G:D) revenue recovery split.

In order to ensure the aforementioned calculation remains robust in a methodology with two different locational elements and a residual component of the tariff, each with different charging bases, a distributed reference node is utilised. This ensures that the tariff is reference node invariant and that revenue recovery is not transferred between tariff components. In addition it is proposed that each locational revenue component would not be re-referenced and the proportion of revenue collected from each tariff element arising from the Transport model would be maintained. The combination of a distributed reference node and two locational tariff elements that are not referenced ensures that the locational signal remains robust, whilst leaving the residual element of the tariff to ensure a correct G:D split in revenue recovery.

Relevant Chargeable Capacities for Generator Charge Calculations

For the Peak Security component it is proposed that there is no change to the existing definitions of chargeable capacity. Hence, the chargeable capacity for power stations with a positive wider Peak Security tariff will be the highest TEC (MW) applicable to that power station for that Financial Year. The chargeable capacity for power stations with negative wider Peak Security tariffs would continue to be the average of the capped metered volumes during three settlement periods of the highest and next highest metered volumes which are separated from each other by at least 10 Clear Days, between November and February of the relevant Financial Year inclusive. These settlement periods do not have to coincide with the demand Triad.

For the Year Round component it is proposed that the chargeable capacity for all power stations would be based on the highest TEC (MW) applicable to that power station for the Financial Year. This is correct for the Year Round criterion, as the load factor used in tariff calculation has been calculated on the TEC (MW) of the power station rather than its highest output during the winter period.

The Residual Component of the Tariff

As with the existing process there is still a requirement for a residual charge in order to ensure the necessary revenue recovery. Assuming that the revenue to be collected from generation users is 27% of the Maximum Allowed Revenue, the required revenue to be recovered from the generation residual charge can be calculated as;

$$R_{RG} = 0.27MAR - R_{LS} - R_{LC} - R_{PSG} - R_{YRG}$$

Where;

- R_{RG} = required revenue from generation residual charge
- MAR = Maximum Allowed Revenue
- R_{LS} = revenue from local substation charges
- R_{LC} = revenue from local circuit charges
- R_{PSG} = revenue from Peak Security locational charges
- R_{YRG} = revenue from Year Round locational charges

The £/kW generation residual component of the tariff can then be calculated from the division of this required revenue by the chargeable generation capacity which, for the residual charge, would be equal to the total GB Transmission Entry Capacity (TEC) of connected generation. This process is illustrated in Figure 3, above.

⁴⁴ The reference node is required to ensure balancing of the incremental MW DC load flow analysis in the Transport model.

Final Generation Tariff

Ultimately, each generator will be liable for the tariff components illustrated in Figure A5.5, below. These tariff components will be levied on the relevant chargeable capacities as outlined above.




Figure A5.5 – Final Proposed Tariff Components

Annex 6 – ALF vs. Annual Incremental Cost Analysis

The graphs that follow represent analysis undertaken using the interface for the Electricity Scenario Illustrator (ELSI) model created for the CMP213 process. ELSI is a Microsoft Excel based model, created by National Grid, which does not require any additional plug-ins or software to operate. It is a simple representation of the Great Britain electricity market, which performs an optimum economic dispatch and re-dispatch of generation to meet demand and rectify transmission network constraints in the most cost effective manner. It was initially devised as part of the RIIO Transmission Price Control Review process to demonstrate to network users the consequences of National Grid's transmission investment plans.

The interface developed for CMP213 utilises the ELSI functionality to explore the relationship between generation annual load factor and annual incremental impact on transmission system constraint costs, which is the basis of the Original proposal, for different generation technology types and location. This interface was developed specifically for the Project TransmiT and CMP213 process to promote transparency and to allow stakeholders to conduct their own analysis of this relationship.

The generation annual load factors and constraint costs are obtained by:

- i) Calculating annual GB wide constraint costs for a given scenario of transmission network capability, generation capacity and demand;
- ii) Incrementing the capacity of a generation technology, in a given SYS zone and re-calculating the impact on annual GB constraint costs. The difference between (ii) and (i) is the incremental impact on constraint costs; and
- iii) Calculating the annual load factor of the zonal generation technology using the unconstrained dispatch (equivalent to Final Physical Notifications)

The incremental impact on constraint costs against the annual load factor of each generation type per SYS network zone is then presented in the form of a graph. User defined data sets and results can be saved for future reference.

The numerous generators, grid supply points, substations and circuits that comprise the GB electricity transmission system are represented in the ELSI model by dividing the transmission network into a series of zones separated by transmission boundaries. Within each SYS zone, the total level of generation and demand is modelled such that each zone will contain (i) a total installed capacity of generation (GW) of various fuel types (nuclear, CCGT, onshore wind, etc.) and (ii) a percentage of overall GB demand. As generation rarely equals demand in a given zone a level of connectivity is required to allow the transmission system to balance overall (i.e. total GB generation = total GB demand). The boundaries, which represent the actual transmission circuits facilitating this connectivity, have a maximum capability (expressed in GW) that restricts the amount of power which can be transferred across them. A map of the geographical location of the actual zones used within the ELSI model is shown in Figure A6.1, below.



























Figure A6.1 – Geographical Map of ELSI Zones

The following analysis was undertaken on a 2011/12 generation and demand background within the ELSI market model. As the Original proposal would utilise the relationship between transmission network long run costs (i.e. network costs) and short run costs (i.e. re-dispatch costs), which occurs when the transmission network is planned to its optimum capacity the analysis was undertaken on a transmission network that is as far as possible sized optimally. Whilst the assumption of optimum transmission network boundary capability may not represent reality (due to historic network build, the lumpy nature of transmission investment and the effect of connect and manage) this approach is consistent with the existing ICRP assumption that does not account for spare capacity or under capacity in the transmission network.

Analysis of Annual Load Factor vs. Annual Incremental Costs Using ELSI







Annex 7 – ALF and Changes to Plant Running Profiles

Members of the CMP213 Workgroup have raised concerns over the “backwards looking” nature of the proposed sharing factor for generation – i.e. Annual Load Factor (ALF) – approach set out in the Original proposal. The ALF methodology approach takes a generator’s load factor for each of the last five (charging) years, removes the two extreme values (i.e. highest and lowest) and then calculates a mean average of the three remaining values. The resulting figure is then used as part of the calculation to determine the given generator’s transmission TNUoS charge for the following charging year.

A key concern is that the proposed ALF methodology approach does not take account of situations where a generating plant is subject to a change in its role in the wholesale electricity market. There are two high-level types of change in a generating plant’s role:

- Periodic step changes:
 - These changes may occur on a regular (e.g. change in season) or irregular (external influence) basis;
 - Regular changes are more likely to “average out” (charging) year to (charging) year, meaning the generator would only be subject to short-term gains and losses; and
 - Irregular changes are less likely to average out and could be unidirectional;
- One-off step changes:
 - These changes will tend to have a unidirectional effect on a plant’s load factor that will not change in the foreseeable future;
 - The event may be predictable, such as the date that a new regulation comes into force or a fuel supply contract ends; and
 - It could also be unpredictable, such as a catastrophic plant failure.

The remainder of this Annex considers a number of scenarios where such issues may arise. The points raised are not intended to compare the ALF methodology approach against the charging principles in place today. The intention of the discussion was in this Annex is to highlight, and spark record the debate within the CMP213 Workgroup on a number of scenarios where the ALF methodology approach may be considered less reflective of how generation Users contribute to the creation of constraints on the transmission system. This allowed the Workgroup to determine which scenarios are considered desirable and which scenarios are considered anomalies and thereby require mitigation.

Change to input costs

Market prices (e.g. fuel switching and carbon price)

Description

The cost of generation depends upon a number of variable input prices, such as fuel costs, the cost of carbon, SO_x and NO_x permitting, etc. These input prices are variable due to their value being set by market forces (supply and demand). As different generating plant types have different fuel and emission permitting requirements, their relative positioning in the merit order will “switch” over time. An example often quoted is fuel switching between gas and coal fired generators.

Concern

As ALF will “lag” behind (charging) year-on-year changes in a generating plant load factor, it may take a number of years (with CMP213) for transmission TNUoS charging to catch up (if at all) with actual within-year running profiles of that plant.

This effect may average out where fuel switching occurs on a regular and steady basis. However, should there be a dominant fuel type over prolonged periods with only occasional fuel switching over short periods of time (e.g. fuel supply issues over a winter period), then such single-year occurrences may be overlooked by the ALF methodology approach.

End of long-term fuel supply contracts and PPAs

Description

Long-term fuel contracts may provide generators with a level of protection against the volatility of fuel prices. The cost of purchasing fuel may be based on a discounted reference price or linked to a basket of indices. Over time, the cost of the contract holder's fuel may diverge and converge with market prices, providing them with an advantage (or disadvantage) against those that are price takers in their respective fuel market. Some fuel supply contracts may also contain "take or pay" provisions, meaning that generators must take delivery of a certain volume of fuel, regardless of the price. The generator must decide which action provides the best financial outcome: sell the fuel or produce power, potentially at a cost to the business.

PPAs provide longer-term certainty to power producers that there will be an off-take of the power they produce. Such contracts may guarantee a minimum number of running hours or capacity usage. An example of the latter is where a generator has CHP capability and is contracted to deliver a rate of heat to an adjacent industrial application.

Concern

If such contracts end and are not replaced, the generating plant will be forced to trade on a merchant basis. Depending upon where the generating plant sits in the merit order (prior to and after the contract ends), there could be a significant disparity between a generator's transmission TNUoS charge and its use of the transmission system. Whilst the ALF methodology approach will catch up over time, the generator's TNUoS charges may not average out due to the generating plant never returning to higher, prolonged annual load factors.

Plant lifecycle

Lifecycle transition

Description

Advances in generation technology (leading to higher fuel efficiencies) mean that generators of the same asset class will have different merit order positions. The majority of plant can expect its position in the merit order to change over time (i.e. over its lifecycle). This change is generally unidirectional, until such time as investment is made in the generating plant to reverse or slow the trend.

Concern

Historically, movement from a high merit position to an out-of-merit position has been gradual over the period of the generating plant's lifecycle. However, movements between different points in the scale could occur as step changes,; i.e. the annual load factor of a mid-merit CCGT could be considerably different to a low-merit CCGT. The timing of movements in the merit order position will depend upon the level of generation investment across the system,; i.e. investment in both the same and different technology classes,; and will be outside the control of a given generator.

Commissioning

Description

Commissioning generation plant will have no historic data to feed into the ALF calculation. The Proposer has made provisions for commissioning plant under the ALF approach. Such plant will be provided with a generic annual load factor that is representative of its type of generation.

Concern

The trend over recent years suggests that commissioning new plant rarely goes smoothly. The Workgroup should consider whether an annual load factor that is representative of “proven” plant (or proven technologies, as further advancements are made) is an appropriate proxy for new plant (or new technologies) in the early days of generation.

Upgrade / conversion

Description

The upgrading (e.g. installation of new, more efficient equipment on an existing plant) and converting (e.g. change of fuel mix with modifications to existing plant infrastructure) of generating plant may lead generators to temporarily reduce their load factor (e.g. unit by unit modification) or close plant whilst work is completed.

Concern

Short-term, one-off plant (or unit) closures may not be effectively captured by the ALF approach. If the reduction in generation occurs over multiple charging years, then the effect on ALF could be expected to average out. This is due to the calculation lagging behind, meaning the generator is expected to be assigned an ALF greater than the output when the generating plant first reduces load / switches off, then be assigned an ALF lower than the output for a period following the completion of the work.

An anomaly occurs where the work is completed over the course of a single charging year. In this situation, the charging year in which the generator contributes less to the exacerbation of transmission constraints is removed from the ALF calculation (i.e. via the removal of the extreme data points over the five year ALF period). This is a similar situation to a single charging year fuel switching (highlighted above).

However, an additional question for consideration is whether the generating plant can be considered to be the same technology following the upgrade or conversion. For example, does the plant move from being a low-merit generator to a mid-merit generator? Will the plant be expected to operate in the same manner as it did previously, i.e. is the five year historic data for the plant still relevant, or should it be treated similar to a newly commissioning plant?

Replanting

Description

Replanting could be considered to be a more substantive change to generating plant than an upgrade or conversion. It may involve the installation of a new technology as a replacement to the old plant. As a result it may also involve a significant change to the generator’s connection agreement and a possible need to re-issue TEC to the new station.

Concern

Presumably, regardless of whether the generator continued to hold TEC (or not) from the point that the old equipment is decommissioned, through to the point that the new equipment is commissioned, the resulting plant would be treated as a newly commissioned plant.

Policy changes

LCPD / IED Running Hours

Description

Environmental legislation, such as the LCPD and IED, may accelerate a generating plant's lifecycle due to the imposition of a restriction on running hours over a number of years. Whilst the LCPD and IED arrangements do not change a given generator's position in the merit order (i.e. it does not have an effect on the efficiency of the plant), it may cause the generator to operate differently. The generator's decision will depend upon a number of factors, including market conditions, maintenance requirements, regulatory outlook, etc.

For example, a generator may wish to use its legislatively limited running hours when it is able to capture higher market prices, such as in the winter peak. In contrast, a generator may decide to utilise their hours over a shorter period of time in order to avoid maintenance costs.

Concern

The key issue is where a generator feels compelled to make a step-change in their behaviour. As with the lifecycle scenario, this change is likely to be unidirectional, therefore the effect of the ALF approach on the generators TNUoS charge will not average out over a number of years.

Other

Catastrophic plant failure

Description

In this scenario, a generator may have a significant failure of equipment that may take all, or a proportion, of its plant offline. For example, a generator permanently loses one of its two units due to a fire.

Concern

As with previous scenarios above, the generator could shift from a high annual load factor across both units (e.g. 75% across plant) to a high annual load factor across one unit (e.g. 37.5% across plant). Presumably, transmission TNUoS charging (and the annual load factor profiling) for the damaged unit would continue until such time that as the associated TEC can be released or the ALF approach averages out the step change (whichever occurs first).

Mothballing of plant

Description

Mothballed generating plant will be taken offline semi-permanently, although maintained to ensure it is still capable of being brought back to service. It is likely

that the plant will be kept in a condition that means it cannot be brought back to service at short notice. The owner of the plant may continue to hold TEC throughout the period that the generating plant is mothballed, although the introduction of Connect and Manage may allow the generator the option of releasing TEC and reapplying when market conditions are more favourable.

Concern

Would it be possible for a generating plant to be mothballed for a period of time, continue to pay transmission TNUoS charges for the TEC held, but then return for a winter with a (relatively) high annual load factor for which it pays a substantially reduced transmission TNUoS charge? How would such generating plant be treated if it were to relinquish its TEC and then reapply for it at a later date (effectively “re”-commissioning)?

How would infrequently run OCGT be charged TNUoS under CMP213? In a scenario with high-wind deployment and an (EMR) capacity mechanism, such generating plant may sit unused for long periods of time, but have occasional winters with high usage (for a short period of the charging year).

Annex 8 – Comparison of Tariff Volatility

To assess the potential impact that the CMP213 Original proposal may have on volatility of future TNUoS charges and compare with the potential impact of volatility under the current methodology, generation tariffs were calculated using both the existing and the Original proposal TNUoS charging methodologies. The analysis concentrates on two areas: analysis of historical charging years: 2009/10 to 2012/13 and future charging years: 2013/14 and 2015/16.

1. Historical year's analysis

Data starting from charging year 2009/10 was chosen because this was the first year that local transmission tariffs were introduced to the TNUoS charging methodology. Input assumptions were unchanged from the values used in the final transport and tariff models for those years.

Figures A8.1 and A8.2 below show illustrative TNUoS tariffs derived using the original proposal methodology for a conventional generator with 70% annual load factor and an intermittent generator with 30% annual load factor respectively. Good correlation can be seen in most years with some deviation in charging year 2012/13. This effect is caused by a reduction of 500 MW of TEC in zone 7 which resulted in the re-allocation of some circuits from the Year Round to the Peak Security background. This effect is not seen by the intermittent generator, which is not exposed to the Peak Security element of the TNUoS tariff with the Original proposal.




Figure A8.1 - Original proposal tariffs: Conventional Generation (70% Annual Load Factor)




Figure A8.2 - Original proposal tariffs: Intermittent Generation (30% Annual Load Factor)

Figures A8.3 to A8.6 show the existing methodology (i.e. Status Quo) and the Original proposal generation tariffs where both (Year Round and Peak Security) elements have been combined to aid comparison.




Figure A8.3 - Status Quo and Original proposal 2009/10 tariffs




Figure A8.4 - Status Quo and Original proposal 2010/11 tariffs




Figure A8.5 - Status Quo and Original proposal 2011/12 tariffs




Figure A8.6 - Status Quo and Original proposal 2012/13 tariffs

Figures A8.7 through A8.10 illustrate the year on year differentials in generation tariffs for existing methodology (i.e. Status Quo) and the Original proposal.




Figure A8.7 - Status Quo Year on Year Tariff Differentials




Figure A8.8 – Original proposal Year on Year Tariff Differentials (70% CCGT)




Figure A8.9 - Original proposal Year on Year Tariff Differentials (30% Wind)

2. Future year's analysis

National Grid's Gone Green, Slow Progression and Accelerated Growth generation scenarios were chosen as the main source of generation and demand data. Charging years 2013/14 and 2015/16 were chosen as they were deemed to be a good representation of the future in the short term.

To understand the effect of changes in the generation background, the following assumptions were made across all models to ensure consistency of analysis:

- a) Charging year 2011/12 values for the total transmission owner's allowed revenue (£m 1,724.28), local circuit, substation and offshore local asset charge revenues were kept constant;
- b) National Grid's 2011 Seven Year Statement⁴⁵ transmission network reinforcements were included in this work with the exception of the Western HVDC link in charging year 2015/16;
- c) The expansion constant and circuit length expansion factors were kept unchanged as per the values in the 2011/12 period shown in Table A8.1;

Expansion Constant (£/MWkm)		11.142856	
Expansion factors	NGC	SPT	SHETL
400kV cable factor	22.390	22.390	22.390
275kV cable factor	22.394	22.394	22.394
132kV cable factor	30.220	30.220	27.790
400kV overhead line factor	1.000	1.000	1.000
275kV overhead line factor	1.137	1.137	1.137
132kV overhead line factor	2.796	2.796	2.238

Table A8.1 - 2011/12 Expansion Constant and Factors

- d) Generation annual load factors (ALF) for use in the Original proposal final tariff calculation (charging years 2013/14 and 2015/16) were obtained as follows:

Using the Electricity Scenario Illustrator (ELSI) model, generation annual load factors were obtained for charging years 2011/12, 2013/14 and 2015/16 for each specific generation technology across all three generation scenarios. These load factors were then grouped by generation plant type in order to obtain average load factors across the country and percentages of increase/decrease were then derived between charging years: 2011/12 - 2013/14 and 2013/14 – 2015/16.

⁴⁵ [National Grid: 2011 National Electricity Transmission System \(NETS\) Seven Year Statement](#)

As no major increases or decreases were observed on intermittent generation load factors, it was decided that charging year 2011/12 historic figures were to be maintained in future charging years for purpose of final tariff calculations used in this Annex.

For conventional plant the resulting percentages from the above exercise were then used as a proxy for increasing/decreasing the original charging year 2011/12 historic load factors to bring these up to their correspondent charging year value; and

- e) As a minimum of 5 charging years were needed to calculate the generation Annual Load Factor as per the Original proposal, the average load factors between 2011/12 - 2013/14 and 2013/14 - 2015/16 were used for charging years 2012/14 and 2014/15 accordingly.

For the purpose of this analysis TNUoS tariffs differentials between charging year 2011/12 – 2013/14 and 2013/14 and 2015/12 for intermittent generation with 30% annual load factors and conventional generation with 40% and 70% annual load factors were plotted against tariff differentials for the current methodology. These differentials are shown in figures 10 and 15 using Gone Green, Slow Progression and Accelerated Growth scenarios. It can be observed that the Original proposal does not appear to increase volatility. This effect was attributed to the use of the generation ALF approach.

For intermittent generation, the differential remained in the range between +1 and -1 £/kW for all 20 generation TNUoS charging zones. For conventional generation of similar annual load factor the differential spanned a slightly higher range due to its exposure to the Peak Security background introduced with the Original proposal.

In Figure A8.10, under the existing methodology (i.e. Status Quo), the largest values of differential correspond to TNUoS charging zones 3, 8, 11 and 16. The value in TNUoS zone 3 is the result of commissioning the Beaulieu – Denny transmission circuits. An increase in generation causes the increase in the TNUoS zone 8 tariff, whilst a decrease in generation causes a reduction in the TNUoS zone 11 tariff. Additional generation in the north of the country reverses the change in power flows on London cables affecting Zone 16 - Central London.




Figure A8.10 – Tariff Differentials between years 2011 and 2013




Figure A8.11 – Tariff Differentials between years 2013 and 2015




Figure A8.12 – Tariff Differentials between years 2011 and 2013




Figure A8.13 – Tariff Differentials between years 2013 and 2015




Figure A8.14 – Tariff Differentials between years 2011 and 2013




Figure A8.15 – Tariff Differentials between years 2013 and 2015

Annex 9 – Annual Load Factor Under the Original

Under the CMP213 Original proposal, it is proposed to calculate an generation Annual Load Factor (ALF) in the TNUoS charging methodology calculation. Generation TNUoS charges are required to reflect the cost of transmission to allow generators to internalise the cost of using the transmission system when they are deciding where to site or when to close plant.

The Workgroup has some concerns over how closely generation ALF calculated on historic data, as per the Original proposal, would be to the actual annual load factor of a generator in a given TNUoS charging year. This was investigated, below.

Assumptions:

- Charging years 2010/11 and 2011/12 years were investigated;
- Actual generation annual load factor = $\frac{\text{Metered Output of Generator (MWh)}}{\text{TEC (MW)} \times 8760 \text{ (h)}}$
- 5 Year generation ALF = previous 5 charging years actual generation annual load factor, remove largest and smallest values and average the remaining 3 charging years;
- 3 Year generation ALF = average of previous 3 charging years actual generation annual load factor; and
- 1 Year generation ALF = previous charging year actual generation annual load factor.

Analysis of results

The results of the analysis are shown in Figures A9.1 to A9.12 below. From Figure A9.1 the following observations can be made:

- Average of differences across generators are quite similar; and
- Charging year 2011/12 seems to show an increase in volatility for individual generation plant due to greater maximum difference between ALF and actual




Figure A9.1 – Differentials between Annual Load Factor and Actual Load Factor

Figures A9.2 to A9.11 show distribution curves for all combined generation technologies and specific types. The total number of generation units sampled was 78 as specified in the table below.

Generation technology	Sample size
Intermittent	3
Nuclear and CCS	11
Hydro	6
Other conventional	58
Total	78




Figure A9.2 - Distribution curves for all types of generation technology




Figure A9.3 - Distribution curves for all types of generation technology




Figure A9.4 – 2010/11 Distribution curves for intermittent technology




Figure A9.5 – 2011/12 Distribution curves for Intermittent technology




Figure A9.6 – 2010/11 Distribution curves for Nuclear and CCS technology




Figure A9.7 – 2011/12 Distribution curve for Nuclear and CCS technology




Figure A9.8 – 2010/11 Distribution curves for Hydro generation




Figure A9.9 – 2011/12 Distribution curves for Hydro generation




Figure A9.10 – 2010/11 Distribution curves for other conventional plant




Figure A9.11 – 2011/12 Distribution curves for other conventional plant