

CMP213 – Workgroup Meeting 1



10th July 2012

ENA, London

Agenda

Item	Topic	Lead
1	Introductions / Apologies for Absence	Patrick Hynes
2	Review of Terms of Reference and Meeting Objectives	Patrick Hynes
3	Presentation of CMP213 Original Proposal	Ivo Spreeuwenberg
4	Identify Areas of Proposal to be Developed	Jackeline Crespo-Sandoval
5	Agree Actions and Initial Timetable	Jackeline / Patrick
6	Next Steps	Patrick Hynes

Workgroup Objectives

- To develop the Original proposal
 - A wide range of considerations
 - NGET is the 'owner'
- To evaluate the Original
 - Need to be clear on all aspects of the Original
 - Against the CUSC applicable charging objectives
- Develop and evaluate Alternatives that could better meet the objectives
 - Addressing the proposals defect / issue
- Seek wider Industry views
- Carry out analysis and impact assessment
- Report on wider issues as described in the ToRs
 - Implementation, environmental, impact on customers etc.
- Agree legal text
- Finalise the report on Original and any agreed Alternatives

Ways of working 1

- Must develop an Original based on proposers 'envelope'
 - Understand the defect (this meeting's main objective)
- Capture relevant pros and cons in the Workgroup report
- Whilst developing Original, record possible Alternatives
- Focus on each issue in turn
 - Once an issue has been discussed – it has been discussed
- 'Living' Workgroup report
 - Close off as much as possible each meeting
 - Limit reopening previous discussion / decisions
- Maintain a list of actions – completed and ongoing
- Virtual car park – issue to be progressed at a future meeting
 - Incl. possible Alternatives

Ways of working 2

- Assuming Workgroup members are experts or have relevant experience (CUSC 8.20.3)
- Send Alternates - we will review progress, not repeat a meetings
- Everyone has a view, all views will be represented
 - The best views are those that are evidenced....
- Members will be expected to contribute
 - Particularly where they 'own' / raise an issue
 - Write a paper on the issue, circulate for wider group views (worked well on 192)
- Chair is independent / answerable to Panel / carrying out ToRs

Terms of Reference

- Review of ToR
 - Circulated prior to meeting
- Any feedback to the CUSC Panel ?
- Any other concerns?
- Any other suggestions?

CUSC Objectives

Use of System Charging Methodology:


- that compliance with the use of system charging methodology **facilitates effective competition** in the generation and supply of electricity and (so far as is consistent therewith) facilitates competition in the sale, distribution and purchase of electricity;
- that compliance with the use of system charging methodology results in **charges which reflect, as far as is reasonably practicable, the costs** (excluding any payments between transmission licensees which are made under and in accordance with the STC) incurred by transmission licensees in their transmission businesses and which are compatible with standard condition C26 (Requirements of a connect and manage connection);
- that, so far as is consistent with sub-paragraphs (a) and (b), the use of system charging methodology, as far as is reasonably practicable, properly **takes account of the developments** in transmission licensees' transmission businesses.

CUSC Objectives:

- the **efficient discharge by the Licensee of the obligations** imposed on it by the Act and the Transmission Licence; and
- **facilitating effective competition** in the generation and supply of electricity, and (so far as consistent therewith) facilitating such competition in the sale, distribution and purchase of electricity.
- **compliance with** the Electricity Regulation and any relevant legally binding decision of **the European Commission and/or the Agency**.

Anticipated CUSC Process

- Likely to require longer than standard 4 months



 Meeting dates currently booked into industry calendar

 Potential additional meetings – may extend into 2013



Elements of the Modification Proposal

- Modification to reflect network investment cost impact of different generation technologies (capacity sharing)

1 Capacity Sharing

- Addition of parallel HVDC link charging methodology


2 Parallel HVDC

- Addition of islands charging methodology

3 Islands


Capacity Sharing – Background

- Not all users drive the same requirement for investment
- TAR focus on connection timing; models reflecting network usage not taken forward
- Is there a proxy that could be included in charges?




Background

- Network capacity vs. future savings in operational costs
- Some investment remains demand security driven



- Charging methodology should develop to reflect
- Must remain simple, transparent and non-discriminatory
- Use long term convergence of LRMC and SRMC

Transport Model Background




Generator Type	Background
Intermittent	0%
Controllable	variable

Generator Type	Background Setting
Intermittent	70%
Nuclear & CCS	85%
Interconnectors	100%
Hydro	variable
Pumped Storage	50%
Peaking	0%
Other (conventional)	variable

Translation into Tariff Model


- Revised model allocates circuits to a given background



- Calculates three tariffs




Illustrative Transport MWkms – Generation



Is the impact of every MW the same?

How to incorporate plant type

- Explicit information is not available (TAR)
- Implicit assumptions must be made
- For investment driven by “year round” conditions, these should reflect assumptions made in CBA



- TSOs incentivised to balance SRMC and LRMC

Generator Specific Assumptions


CBA Inputs:

Gen Unit	■ TEC	Prices	■ Fuel Price	BM	■ Bid Price
	■ Unit Avail.		■ CO ₂ Price		■ Offer Price
	■ Fuel Avail.		■ ROC/FiT Price		
	■ Efficiency				

- Generators unable to provide TSO with information
- Significant complexity


Is there a simple alternative?

Plant Type Impact on Constraint Costs?




- Year round (pseudo-CBA) includes contribution to peak periods

Plant Type Impact on Constraint Costs?



Derivation of Annual Load Factor


- Maintain link back to assumptions made when planning investment to avoid future constraint costs




- On balance best meets objectives; compared with alternatives such as MWh, User supplied forecast, NGET forecast, etc. ¹⁹

Calculation of Tariffs

Conventional Tariff =



Intermittent Tariff =



Sharing Proposal Overview


Transport

- Dual background
- SQSS based scaling
- Circuit MWkm 'binning'
- Incremental MW
- Locational differential
- Cost reflective signal

Tariff

- 2 part wider tariff
- Remains £/kW based
- Intermittent = YR only
- Specific historic load factor
- Minimal impact on local
- Minimal impact on demand

Including Parallel HVDC in Charging



- Offshore HVDC links – ‘Bootstraps’
 - Existing charging model based on passive network elements
 - HVDC represents an active component of the network
 - High relative £/MWkm cost
 - Some precedent offshore
1. Which costs go into EF calculation?
 2. Where does incremental MW flow?

Reflecting HVDC in Transport Model

- Impact on tariffs is combination of:

Cost Components
£/MWkm

Marginal MW
flow
MWkm

- Which cost components are included in the model?
 - Need to calculate cost relative to 400kV OHL – Expansion Factor
- How much of the marginal MW flows down the link?
 - Need to calculate an impedance for the model
- Are HVDC links that parallel the AC network different from those that are radial in nature?

Expansion Factor

Annuity Factor:	0.06567
Asset Life:	50
Rate:	0.0625
Overhead Factor %	1.8
Expansion Constant (£/MWkm)	11.142856

Existing Expansion Factor Parameters			
Projected Relative Cost of Asset	NGC	SP	SSE
400kV cable factor	22.390	22.390	22.390
275kV cable factor	22.394	22.394	22.394
132kV cable factor	30.220	30.220	27.790
400kV line factor	1.000	1.000	1.000
275kV line factor	1.137	1.137	1.137
132kV line factor	2.796	2.796	2.238

Calculations

HVDC Details:

- 370.0 Length (km)
- 2,000.0 Rating (MW)
- 1,000.0 Total Cost (£m)
- 65.7 Annuity cost
- 18.0 Overheads cost
- 83.7 Total Annual Cost (£m)

} Assumptions for illustration

£/MWkm:

- 113.1 £/MWkm
- 10.1 HVDC expansion factor

Transport Model:

- 167.7 Equivalent length of 400kV cable
- or
- 3754.4 Equivalent length of 400kV OHL

Bus 1	Bus 2	R	X	OHL Length	Cable Length
DEES40	HUER40	0.000	????	3754.400	0.00

Expansion Factor

Option A	Option B	Option C
No suitable onshore alternative	SO flexibility akin to SVC or QB	Full marginal signal
<ul style="list-style-type: none"> ■ Treat as 400kV OHL ■ Little impact on tariffs ■ Regardless of MW flow 	<ul style="list-style-type: none"> ■ Remove converters from EF ■ Some impact on tariffs ■ Varies by MW flow 	<ul style="list-style-type: none"> ■ Include all elements in EF ■ Significant impact on tariffs ■ Varies by MW flow

Discounted due to lack of cost-reflectivity

Calculation - Option A

HVDC Details: 370.0 Length (km)
2,000.0 Rating (MW)
1,000.0 Total Cost (£m)
- Annuitised cost
- Overheads cost
- Total Annual Cost (£m)

£/MWkm: 11.1 £/MWkm
1.0 HVDC expansion factor

Transport Model: 16.6 Equivalent 400kV cable km
or
370.0 Equivalent 400kV OHL km

Calculation - Option B

HVDC Details: 370.0 Length (km)
2,000.0 Rating (MW)
550.0 Total Cost (£m)
36.1 Annuitised cost
9.9 Overheads cost
46.0 Total Annual Cost (£m)

£/MWkm: 62.2 £/MWkm
5.6 HVDC expansion factor

Transport Model: 92.2 Equivalent 400kV cable km
or
2064.9 Equivalent 400kV OHL km

Calculation - Option C


HVDC Details: 370.0 Length (km)
2,000.0 Rating (MW)
1,000.0 Total Cost (£m)
65.7 Annuitised cost
18.0 Overheads cost
83.7 Total Annual Cost (£m)

£/MWkm: 113.1 £/MWkm
10.1 HVDC expansion factor

Transport Model: 167.7 Equivalent 400kV cable km
or
3754.4 Equivalent 400kV OHL km

Existing Expansion Factor Parameters			
Projected Relative Cost of Asset	NGC	SP	SSE
400kV cable factor	22.390	22.390	22.390
275kV cable factor	22.394	22.394	22.394
132kV cable factor	30.220	30.220	27.790
400kV line factor	1.000	1.000	1.000
275kV line factor	1.137	1.137	1.137
132kV line factor	2.796	2.796	2.238

Transport Model



- Existing charging model based on passive network elements
- Marginal flow dictated by relative impedance of all routes to centre of the network
 - HVDC represents an active component of the network
 - Technical WG accepted principle of modelling as a pseudo-AC circuit
 - Therefore in Transport model need to;
 1. estimate level of power flow
 2. calculate desired impedance

Options for Power Flow

1. Optimal Power Flow

Derive power flow from optimal operation calculation - complex

2. Transmission Routes

Assume equal power flow on each double circuit equivalent route


3. Transmission Circuits

Assume equal power flow on each major circuit

4. Circuit Ratings

Pro-rata flows based on circuit ratings


Managing Multiple Boundaries



- Options 2-4 assume flow setting based on single boundary management
- In reality each bootstrap crosses multiple boundaries
- Option 4B – managing multiple boundaries through ratings

Proposed simplifying assumptions


- Flows based on Transport Model background (Year Round)
- Boundary with fewest onshore circuits used for single boundary approach – most constrained boundary; B6
 - 3 onshore double circuit routes
 - 132kV circuits ignored for options 2&3, i.e. 4 circuits on 2 routes considered, due to relatively small size (capacity approx. 6% of 400kV)



2015 Western HVDC Example

Marginal MW flow
MWkm

- Step 1 – Ascertain total rating of circuits across boundary in Transport model including HVDC
 - B6 total = 10844MW




2015 Western HVDC Example

Marginal MW flow
MWkm

- Step 2 – Ascertain flow across boundary in Transport model YR background without HVDC

- B6 total = 5889MW



2015 Western HVDC Example

Step 3 – Calculation of desired HVDC flow. For single boundaries*;

2. Transmission Routes $BF_{MW} * HVDC_{cap} / N_R$
3. Transmission Circuits $BF_{MW} * HVDC_{cap} / N_C$
4. Circuit Ratings;
 - a. single boundary $BF_{MW} * HVDC_{cap} / BR$

Where;

BF_{MW} = MW boundary flow from Transport model with no HVDC

$HVDC_{cap}$ = MW capacity of HVDC circuit

N_R = No. of routes across boundary


N_C = No. of circuits across boundary

BR = total rating of boundary

*Note: Optimum power flow method not investigated

2015 Western HVDC Example

Marginal MW flow
MWkm



- Step 3– Calculation of HVDC flow. For option 4B;
- Need to repeat 4A calculation for each boundary crossed

■ In this case;

- B6 required HVDC flow = 1086MW
- B7 required HVDC flow = 740MW
- B11 required HVDC flow = 651MW
- B16 required HVDC flow = 753MW

■ Multiple boundary result is average of four boundaries

2015 Western HVDC Example Results

Marginal MW flow
MWkm

2. Transmission Routes *Desired flow: 1963MW*
 3. Transmission Circuits *Desired flow: 1178MW*
 4. Circuit Ratings;
 - a. single boundary *Desired flow: 1086MW*
 - b. multiple boundaries *Desired flow: 808MW*
- Higher 'desired flow' = lower impedance = bigger impact on marginal MW flow

Including Island Links in the Methodology

- Harnessing renewable energy sources on the northern islands of Scotland will require new transmission circuits
- The existing charging methodology does not accommodate this
- Requires consideration of:
 - Expansion Factors
 - Local/Wider
 - Security Factor



Including Island Links in the Methodology

Expansion Factor

- Island links will be constructed of sub-sea cables
- *Expansion factors* represent the various technologies on the network
- Whether 'local' or 'wider' for charging purposes, the calculation of expansion factors for island cables is required
- These would be technology specific and would logically be calculated in the same manner as onshore expansion factors

Local or Wider Circuit

- Under existing definition, some islands may become classed as wider
- As the nodal marginal cost of islands will be greater than the +/- 1£/kW, Islands would become their own generation charging zones under the existing zoning criteria
- With the same expansion factor for local and wider; the tariff would be the same except for the security factor

Including Island Links in the Methodology

Expansion Factor

- Island links will be constructed of sub-sea cables
- *Expansion factors* represent the various technologies on the network
- Whether 'local' or 'wider' for charging purposes, the calculation of expansion factors for island cables is required
- These would be technology specific and could logically be calculated in the same manner as onshore expansion factors

Existing Factors

400kV cable factor:	22.39
275kV cable factor:	22.39
132kV cable factor:	30.22
400kV line factor:	1.00
275kV line factor:	1.14
132kV line factor:	2.80

$$Annuity\ factor = \frac{1}{\left[\frac{1 - (1 + WACC)^{-Asset\ Life}}{WACC} \right]}$$

Capital Cost

Annuity

Overhead


Including Island Links in the Methodology

Local/Wider

- Capacity sharing covered under sharing element of mod.
- Security factor issue remains

Security Factor

- Specific for 'local'
- Currently 1.8 is applied for all wider
- Technical WG agreed that reduced security could be reflected in the Expansion Factor (EF) calculation
- $EF \times (1.0/1.8)$
- Tariff should be commensurate with access rights



Areas of Proposal to be Developed



Elements of the Original Modification Proposal

- Modification to reflect network investment cost impact of different generation technologies (capacity sharing)

1 Capacity Sharing

- Addition of parallel HVDC link charging methodology

2 Parallel HVDC

- Addition of islands charging methodology

3 Islands

- Original Proposal flexible; as per Ofgem Direction

Identify Areas of Proposal to be Developed

Defect	Original	Considerations from Direction	Potential Changes to Original
Sharing	-Applies to 'wider' network only Locational Differential	a) How charging structures should be applied geographically; in particular where zones are dominated by one type of generation technology <i>(Direction 15a)</i>	i. ...
			ii. ...
			iii. ...
			iv. ...
			v. ...
	-Dual background approach <i>(Direction 14a)</i> -NETS SQSS based scaling for backgrounds <i>(Direction 14b)</i>	b) Alternative approaches to ALF for reflecting user characteristics into charging <i>(Direction 15b)</i>	i....
			ii....
			iii....
			iv....
			v....
	-Circuit MWkm 'binning' based on max. flow Plant Type Impact	c) Whether intermittent technology types should be exposed to the peak element of tariff <i>(Direction 16)</i>	i....
			ii....
			iii....
			iv....
			v....
-2 part wider tariff (£/kW) -Intermittent = YR only -Unique historic ALF		v....	

Identify Alternatives to be Developed

Defect	Original	Potential Alternatives	Justification Against Objectives
Sharing	-Applies to 'wider' network only Locational Differential -Dual background approach (<i>Direction 14a</i>) -NETS SQSS based scaling for backgrounds (<i>Direction 14b</i>) -Circuit MWkm 'binning' based on max. flow Plant Type Impact -2 part wider tariff (£/kW) -Intermittent = YR only -Unique historic ALF	i. ...	i. ...
		ii. ...	ii. ...
		iii. ...	iii. ...
		iv. ...	iv. ...
		v. ...	v. ...
		vi. ...	vi. ...
		vii. ...	vii. ...
		viii. ...	viii. ...
		ix. ...	ix. ...
		x. ...	x. ...
		xi. ...	xi. ...
		xii. ...	xii. ...
		xiii. ...	xiii. ...
		xiv. ...	xiv. ...
		xv. ...	xv. ...

Identify Areas of Proposal to be Developed

Defect	Original	Considerations from Direction	Potential Changes to Original
HVDC	<ul style="list-style-type: none"> - Modelled as pseudo-AC circuit - All costs included in Expansion Factor (EF) - Impedance calculated assuming HVDC circuit is loaded to the same extent on average as the equivalent AC circuits it parallels (<i>Direction 19</i>) 	<p>a) Whether the cost of HVDC converter stations should be included in the expansion factor calculation (<i>Direction 20</i>)</p>	i. Remove converter costs from the EF calculation
			ii....
			iii....
			iv....
			v....
			vi. ...

Identify Alternatives to be Developed

Defect	Original	Potential Alternatives	Justification Against Objectives
HVDC	<ul style="list-style-type: none"> - Modelled as pseudo-AC circuit - All costs included in Expansion Factor (EF) - Impedance calculated assuming HVDC circuit is loaded to the same extent on average as the equivalent AC circuits it parallels (<i>Direction 19</i>) 	i. ...	i....
		ii. ...	ii....
		iii. ...	iii....
		iv. ...	iv....
		v. ...	v....
		vi. ...	vi. ...

Identify Areas of Proposal to be Developed

Defect	Original	Considerations from Direction	Potential Changes to Original
Islands	-Technology specific Expansion Factors (EF) consistent with current approach -EF calculation reflects lack of redundancy where islands become 'wider' -HVDC converters included in EF calculation consistent with offshore	a) Whether Islands classed as 'wider' for charging purposes should have a 2 part wider tariff as determined by the sharing element of the proposal (<i>Direction 24a</i>)	i....
			ii....
			iii....
			iv....
			v....
		b) Whether islands classed as 'local' for charging purposes should have tariffs consistent with the current existing methodology for local circuit and local substation tariffs (<i>Direction 24b</i>)	i....
			ii....
			iii....
			iv....
			v....
		c) Whether the expansion factor should be calculated using the existing annuitised capital cost approach or whether the expansion factor should be calculated to recover the actual cost of island links (<i>Direction 24c-i -</i>)	i....
			ii....
iii....			
iv....			
v....			
d) Whether, for islands classed as 'wider', the global locational security factor should be used without further modification or whether any lack of redundancy should be reflected in the expansion factor calculation (<i>Direction 24c-ii -</i>)	i....		
	ii....		
	iii....		
	iv....		
	v....		

References to the Authority's Direction in orange

Identify Areas of Proposal to be Developed

Defect	Original	Considerations from Direction	Potential Changes to Original
Islands	-Technology specific Expansion Factors (EF) consistent with current approach -EF calculation reflects lack of redundancy where islands become 'wider'	e) Whether the expansion factor calculation for radial island links comprising HVDC technology should be the same as that for HVDC links that parallel the AC network. <i>(Direction 24d)</i>	i....
			ii....
			iii....
			iv....
			v....
	-HVDC converters included in EF calculation consistent with offshore	f) Whether an anticipatory application of the MITS definition to islands is appropriate and how this could be done. <i>(Direction 24e)</i>	i....
			ii....
			iii....
			iv....
			v....

Identify Alternatives to be Developed

Defect	Original	Considerations from Direction	Potential Changes to Original
Islands	-Technology specific Expansion Factors (EF) consistent with current approach -EF calculation reflects lack of redundancy where islands become 'wider' -HVDC converters included in EF calculation consistent with offshore	i. ...	i....
		ii. ...	ii....
		iii. ...	iii....
		iv. ...	iv....
		v. ...	v....
		vi. ...	vi....
		vii....	vii....
		viii....	viii....
		ix. ...	ix....
		x. ...	x.

Initial Timetable

Date	Meeting Focus	
July 10 th	Introduction; Work plan	
July 24 th		
July 25 th		
August 7 th		
August 8 th		
August 28 th		
August 29 th		
September 4 th		
September 5 th		
September 11 th		
September 12 th		
October 8 th		
October 9 th		
October 15 th		
October 16 th		
November 5 th		
November 6 th		
November 15 th		
November 16 th		

Next Steps

